

October 21, 1999

Mr. Robert P. Powers, Senior Vice President
Indiana Michigan Power Company
Nuclear Generation Group
500 Circle Drive
Buchanan, MI 49107

SUBJECT: DONALD C. COOK NUCLEAR PLANT, UNITS 1 AND 2 - ISSUANCE OF
AMENDMENTS RE: SAFETY INJECTION PUMP RUNOUT LIMITS
(TAC NOS. MA3715 AND MA3716)

Dear Mr. Powers:

The U.S. Nuclear Regulatory Commission has issued the enclosed Amendment No.229to Facility Operating License No. DPR-58 and Amendment No.212to Facility Operating License No. DPR-74 for the Donald C. Cook Nuclear Plant, Units 1 and 2. The amendments consist of changes to the Technical Specifications in response to your application dated September 14, 1998.

The amendments would revise TS page 3/4 5-6, "Limiting Conditions for Operation and Surveillance Requirements - Emergency Core Cooling Systems (ECCS)," and its associated Bases to change runout limits for a safety injection pump to 675 gallons per minute (gpm) unless the pump is specifically tested to a higher flow rate not exceeding 700 gpm for Units 1 and 2.

A copy of our related Safety Evaluation is also enclosed. Notice of Issuance will be included in the Commission's next biweekly Federal Register notice.

Sincerely,

Original Signed By

John F. Stang, Sr. Project Manager, Section 1
Project Directorate III
Division of Licensing Project Management
Office of Nuclear Reactor Regulation

Docket Nos. 50-315 and 50-316

- Enclosures: 1. Amendment No. 229to DPR-58
- 2. Amendment No. 212to DPR-74
- 3. Safety Evaluation

1/1/01
D

cc w/encls: See next page

DOCUMENT NAME: G:\PD31\DCCOOK12\AMDma3715¹² *See previous concurrence

OFFICE	PM:PD31	E	LA:PD31	E	OGG ²⁵	EMEB	SC:PD31	E
NAME	JStang		Barnhill		R.Bachmann	Elmbro*	CCraig	
DATE	9/18/99		9/22/99		9/24/99	9/26/99	11/1/99	

OFFICIAL RECORD COPY

200005

NRC FILE CENTER COPY



UNITED STATES
NUCLEAR REGULATORY COMMISSION

WASHINGTON, D.C. 20555-0001

October 21, 1999

Mr. Robert P. Powers, Senior Vice President
Indiana Michigan Power Company
Nuclear Generation Group
500 Circle Drive
Buchanan, MI 49107

SUBJECT: DONALD C. COOK NUCLEAR PLANT, UNITS 1 AND 2 - ISSUANCE OF
AMENDMENTS RE: SAFETY INJECTION PUMP RUNOUT LIMITS
(TAC NOS. MA3715 AND MA3716)

Dear Mr. Powers:

The U.S. Nuclear Regulatory Commission has issued the enclosed Amendment No.229 to Facility Operating License No. DPR-58 and Amendment No.212 to Facility Operating License No. DPR-74 for the Donald C. Cook Nuclear Plant, Units 1 and 2. The amendments consist of changes to the Technical Specifications in response to your application dated September 14, 1998.

The amendments would revise TS page 3/4 5-6, "Limiting Conditions for Operation and Surveillance Requirements - Emergency Core Cooling Systems (ECCS)," and its associated Bases to change runout limits for a safety injection pump to 675 gallons per minute (gpm) unless the pump is specifically tested to a higher flow rate not exceeding 700 gpm for Units 1 and 2.

A copy of our related Safety Evaluation is also enclosed. Notice of Issuance will be included in the Commission's next biweekly Federal Register notice.

Sincerely,

A handwritten signature in cursive script, appearing to read "John F. Stang, Sr.".

John F. Stang, Sr. Project Manager, Section 1
Project Directorate III
Division of Licensing Project Management
Office of Nuclear Reactor Regulation

Docket Nos. 50-315 and 50-316

Enclosures: 1. Amendment No. 229 to DPR-58
2. Amendment No. 212 to DPR-74
3. Safety Evaluation

cc w/encls: See next page

Robert P. Powers
Indiana Michigan Power Company

Donald C. Cook Nuclear Plant
Units 1 and 2

cc:

Regional Administrator, Region III
U.S. Nuclear Regulatory Commission
801 Warrenville Road
Lisle, IL 60532-4351

Drinking Water and Radiological
Protection Division
Michigan Department of
Environmental Quality
3423 N. Martin Luther King Jr Blvd
P.O. Box 30630 CPH Mailroom
Lansing, MI 48909-8130

Attorney General
Department of Attorney General
525 West Ottawa Street
Lansing, MI 48913

Gordon Arent
Director, Regulatory Affairs
Indiana Michigan Power Company
Nuclear Generation Group
500 Circle Drive
Buchanan, MI 49107

Township Supervisor
Lake Township Hall
P.O. Box 818
Bridgman, MI 49106

U.S. Nuclear Regulatory Commission
Resident Inspector's Office
7700 Red Arrow Highway
Stevensville, MI 49127

David A. Lochbaum
Union of Concerned Scientists
1616 P Street NW, Suite 310
Washington, DC 20036-1495

Jeremy J. Euto, Esquire
Indiana Michigan Power Company
Nuclear Generation Group
500 Circle Drive
Buchanan, MI 49107

A. Christopher Bakken, Site Vice President
Indiana Michigan Power Company
Nuclear Generation Group
One Cook Place
Bridgman, MI 49106

Mayor, City of Bridgman
P.O. Box 366
Bridgman, MI 49106

Michael W. Rencheck
Vice President, Nuclear Engineering
Indiana Michigan Power Company
Nuclear Generation Group
500 Circle Drive
Buchanan, MI 49107

Special Assistant to the Governor
Room 1 - State Capitol
Lansing, MI 48909

DATED: October 21, 1999

AMENDMENT NO. 229 TO FACILITY OPERATING LICENSE NO. DPR-58, DONALD C. COOK
NUCLEAR PLANT, UNIT 1

AMENDMENT NO. 212 TO FACILITY OPERATING LICENSE NO. DPR-74, DONALD C. COOK
NUCLEAR PLANT, UNIT 2

Distribution:

Docket File

PUBLIC

PD31r/f

OGC

J. Stang (2)

G. Hill, IRM (4)

W. Beckner, TSB

ACRS

G. Grant, RIII

R. Scholl (SE only)

C. Sochor