

October 26, 1999

Mr. Robert P. Powers, Senior Vice President
Indiana Michigan Power Company
Nuclear Generation Group
500 Circle Drive
Buchanan, MI 49107

SUBJECT: DONALD C. COOK NUCLEAR PLANT, UNITS 1 AND 2 - REQUEST FOR
ADDITIONAL INFORMATION RELATED TO LICENSE AMENDMENT
REQUESTING CREDIT OF ROD CLUSTER CONTROL ASSEMBLIES FOR
COLD LEG LARGE BREAK LOSS-OF-COOLANT ACCIDENT (LOCA)
SUBCRITICALITY (TAC NOS. MA6473 AND MA6474)

Dear Mr. Powers:

During the review of your application dated September 17, 1999, documenting your request to take credit for rod cluster assemblies for a cold leg reactor coolant pipe large break LOCA subcriticality, the Nuclear Regulatory Commission staff identified an area in your application which requires further clarification. The following question deals with the leak-before-break (LBB) technology.

Demonstrate that the analysis for normal operating conditions and safe shutdown earthquake for the main reactor coolant loop piping meets the appropriate margins for the application of LBB technology. Your response should consider the replacement of the steam generators in both Units 1 and 2 and any modifications made to the reactor coolant piping and supports since the issuance of the NRC Safety Evaluation Report (SER) dated November 22, 1985. Also, your response should reflect the guidance in NUREG-1061, Volume 3, "Report of the U.S. Nuclear Regulatory Commission Piping Review Committee, Evaluation of Potential for Pipe Breaks," and/or Draft Standard Review Plan Section 3.6.3, "Leak-Before-Break Evaluation Procedures."

The need to provide the additional information and the agreement of the D. C. Cook staff to comply with this request were discussed with members of your staff on October 18 and 19, 1999. A mutually agreed upon due date of November 10, 1999, was established with Mr. Robert Godley of your staff.

Sincerely,
/s/

John F. Stang, Sr. Project Manager, Section 1
Project Directorate III
Division of Licensing Project Management
Office of Nuclear Reactor Regulation

Docket Nos. 50-315 and 50-316

cc: See next page

DISTRIBUTION

File Center	JStang(2)	OGC
PUBLIC	PDIII-1 LA	ACRS
PDIII-1 Reading	WBateman	AVegel, RIII
SBlack	LBerry	CCraig

1/0
DF01

DOCUMENT NAME: G:\PD31\DCCOOK12\RAI6473.wpd

*Previously Concurred

OFFICE	PM:PDIII-1	E	LA:PDIII-1	E	BC:EMCB*	SC:PDIII-1	E
NAME	JStang		MO'Brien KB FOR		WBateman	CCraig	
DATE	10/22/99		10/24/99		10/26/99	10/27/99	

OFFICIAL RECORD COPY

290091

NRC FILE CENTER COPY

Mr. Robert P. Powers, Senior Vice President
Indiana Michigan Power Company
Nuclear Generation Group
500 Circle Drive
Buchanan, MI 49107

October 26, 1999

SUBJECT: DONALD C. COOK NUCLEAR PLANT, UNITS 1 AND 2 - REQUEST FOR ADDITIONAL INFORMATION RELATED TO LICENSE AMENDMENT REQUESTING CREDIT OF ROD CLUSTER CONTROL ASSEMBLIES FOR COLD LEG LARGE BREAK LOSS-OF-COOLANT ACCIDENT (LOCA) SUBCRITICALITY (TAC NOS. MA6473 AND MA6474)

Dear Mr. Powers:

During the review of your application dated September 17, 1999, documenting your request to take credit for rod cluster assemblies for a cold leg reactor coolant pipe large break LOCA subcriticality, the Nuclear Regulatory Commission staff identified an area in your application which requires further clarification. The following question deals with the leak-before-break (LBB) technology.

Demonstrate that the analysis for normal operating conditions and safe shutdown earthquake for the main reactor coolant loop piping meets the appropriate margins for the application of LBB technology. Your response should consider the replacement of the steam generators in both Units 1 and 2 and any modifications made to the reactor coolant piping and supports since the issuance of the NRC Safety Evaluation Report (SER) dated November 22, 1985. Also, your response should reflect the guidance in NUREG-1061, Volume 3, "Report of the U.S. Nuclear Regulatory Commission Piping Review Committee, Evaluation of Potential for Pipe Breaks," and/or Draft Standard Review Plan Section 3.6.3, "Leak-Before-Break Evaluation Procedures."

The need to provide the additional information and the agreement of the D. C. Cook staff to comply with this request were discussed with members of your staff on October 18 and 19, 1999. A mutually agreed upon due date of November 10, 1999, was established with Mr. Robert Godley of your staff.

Sincerely,

/s/

John F. Stang, Sr. Project Manager, Section 1
Project Directorate III
Division of Licensing Project Management
Office of Nuclear Reactor Regulation

Docket Nos. 50-315 and 50-316

cc: See next page

DISTRIBUTION

File Center	JStang(2)	OGC
PUBLIC	PDIII-1 LA	ACRS
PDIII-1 Reading	WBateman	AVegel, RIII
SBlack	LBerry	CCraig

DOCUMENT NAME: G:\PD31\DCCOOK12\RAI6473.wpd

*Previously Concurred

OFFICE	PM:PDIII-1	E	LA:PDIII-1	E	BC:EMCB*	SC:PDIII-1	E
NAME	JStang		M O'Brien KR FR		WBateman	CCraig	
DATE	10/26/99		10/26/99		10/26/99	10/17/99	

OFFICIAL RECORD COPY



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555-0001

October 26, 1999

Mr. Robert P. Powers, Senior Vice President
Indiana Michigan Power Company
Nuclear Generation Group
500 Circle Drive
Buchanan, MI 49107

SUBJECT: DONALD C. COOK NUCLEAR PLANT, UNITS 1 AND 2 - REQUEST FOR
ADDITIONAL INFORMATION RELATED TO LICENSE AMENDMENT
REQUESTING CREDIT OF ROD CLUSTER CONTROL ASSEMBLIES FOR
COLD LEG LARGE BREAK LOSS-OF-COOLANT ACCIDENT (LOCA)
SUBCRITICALITY (TAC NOS. MA6473 AND MA6474)

Dear Mr. Powers:

During the review of your application dated September 17, 1999, documenting your request to take credit for rod cluster assemblies for a cold leg reactor coolant pipe large break LOCA subcriticality, the Nuclear Regulatory Commission staff identified an area in your application which requires further clarification. The following question deals with the leak-before-break (LBB) technology.

Demonstrate that the analysis for normal operating conditions and safe shutdown earthquake for the main reactor coolant loop piping meets the appropriate margins for the application of LBB technology. Your response should consider the replacement of the steam generators in both Units 1 and 2 and any modifications made to the reactor coolant piping and supports since the issuance of the NRC Safety Evaluation Report (SER) dated November 22, 1985. Also, your response should reflect the guidance in NUREG-1061, Volume 3, "Report of the U.S. Nuclear Regulatory Commission Piping Review Committee, Evaluation of Potential for Pipe Breaks," and/or Draft Standard Review Plan Section 3.6.3, "Leak-Before-Break Evaluation Procedures."

The need to provide the additional information and the agreement of the D. C. Cook staff to comply with this request were discussed with members of your staff on October 18 and 19, 1999. A mutually agreed upon due date of November 10, 1999, was established with Mr. Robert Godley of your staff.

Sincerely,

A handwritten signature in black ink, appearing to read "John F. Stang, Sr.", written over a faint, illegible typed name.

John F. Stang, Sr. Project Manager, Section 1
Project Directorate III
Division of Licensing Project Management
Office of Nuclear Reactor Regulation

Docket Nos. 50-315 and 50-316

cc: See next page

Robert P. Powers
Indiana Michigan Power Company

Donald C. Cook Nuclear Plant
Units 1 and 2

cc:

Regional Administrator, Region III
U.S. Nuclear Regulatory Commission
801 Warrenville Road
Lisle, IL 60532-4351

Drinking Water and Radiological
Protection Division
Michigan Department of
Environmental Quality
3423 N. Martin Luther King Jr Blvd
P.O. Box 30630 CPH Mailroom
Lansing, MI 48909-8130

Attorney General
Department of Attorney General
525 West Ottawa Street
Lansing, MI 48913

Gordon Arent
Director, Regulatory Affairs
Indiana Michigan Power Company
Nuclear Generation Group
500 Circle Drive
Buchanan, MI 49107

Township Supervisor
Lake Township Hall
P.O. Box 818
Bridgman, MI 49106

U.S. Nuclear Regulatory Commission
Resident Inspector's Office
7700 Red Arrow Highway
Stevensville, MI 49127

David A. Lochbaum
Union of Concerned Scientists
1616 P Street NW, Suite 310
Washington, DC 20036-1495

Jeremy J. Euto, Esquire
Indiana Michigan Power Company
Nuclear Generation Group
500 Circle Drive
Buchanan, MI 49107

A. Christopher Bakken, Site Vice President
Indiana Michigan Power Company
Nuclear Generation Group
One Cook Place
Bridgman, MI 49106

Mayor, City of Bridgman
P.O. Box 366
Bridgman, MI 49106

Michael W. Rencheck
Vice President, Nuclear Engineering
Indiana Michigan Power Company
Nuclear Generation Group
500 Circle Drive
Buchanan, MI 49107

Special Assistant to the Governor
Room 1 - State Capitol
Lansing, MI 48909

Mr. Robert P. Powers, Senior Vice President
 Indiana Michigan Power Company
 Nuclear Generation Group
 500 Circle Drive
 Buchanan, MI 49107

SUBJECT: DONALD C. COOK NUCLEAR PLANT, UNITS 1 AND 2 - REQUEST FOR
 ADDITIONAL INFORMATION RELATED TO LICENSE AMENDMENT
 REQUESTING CREDIT OF ROD CLUSTER CONTROL ASSEMBLIES FOR
 COLD LEG LARGE BREAK LOSS-OF-COOLANT ACCIDENT (LOCA)
 SUBCRITICALITY (TAC NOS. MA6473 AND MA6474)

Dear Mr. Powers:

During the review of your application dated September 17, 1999, documenting your request to take credit for rod cluster assemblies for a cold leg reactor coolant pipe large break LOCA subcriticality, the Nuclear Regulatory Commission staff identified an area in your application which requires further clarification. The following question deals with the leak-before-break (LBB) technology.

Demonstrate the analysis for normal operating conditions and safe shutdown earthquake for the main reactor coolant loop piping meets the appropriate margins for the application of LBB technology. Your response should consider the replacement of the steam generators in both Units 1 and 2 and any modifications made to the reactor coolant piping and supports since the issuance of the NRC Safety Evaluation Report (SER) dated November 22, 1985. Also, your response should reflect the guidance in NUREG-1061, Volume 3, "Report of the U.S. Nuclear Regulatory Commission Piping Review Committee, Evaluation of Potential for Pipe Breaks," and/or Draft Standard Review Plan Section 3.6.3, "Leak-Before-Break Evaluation Procedures."

The need to provide the additional information and the agreement of the D. C. Cook staff to comply with this request were discussed with members of your staff on October 18 and 19, 1999. A mutually agreed upon due date of November 10, 1999, was established with Mr. Robert Godley of your staff.

Sincerely,

John F. Stang, Sr. Project Manager, Section 1
 Project Directorate III
 Division of Licensing Project Management
 Office of Nuclear Reactor Regulation

Docket Nos. 50-315 and 50-316

cc: See next page

DISTRIBUTION

File Center	JStang(2)	OGC
PUBLIC	PDIII-1 LA	ACRS
PDIII-1 Reading	WBateman	AVegel, RIII
SBlack	LBerry	CCraig

DOCUMENT NAME: G:\PD31\DCCOOK12\RAI6473.wpd

OFFICE	PM:PDIII-1	E	LA:PDIII-1	E	BC:EMCB	SC:PDIII-1	E
NAME	JStang		WBateman		WBateman	CCraig	
DATE	10/22/99		11/1/99		10/26/99	1/1/99	

OFFICIAL RECORD COPY