**Marked-Up Pages of the Technical Specifications** 

RPS Electric Power Monitoring 3.3.8.2

## SURVEILLANCE REQUIREMENTS

SURVEILLANCE		FREQUENCY
SR 3.3.8.2.1	Only required to be performed prior to entering MODE 2 or 3 from MODE 4, when in MODE 4 for ≥ 24 hours.  Perform CHANNEL FUNCTIONAL TEST.	184 days
SR 3.3.8.2.2	Perform CHANNEL CALIBRATION. The Allowable Values shall be:  a. Overvoltage  Bus A ≤ 134.2 V  Bus B ≤ 133.6 V 126.7  b. Undervoltage  Bus A ≥ 214.2 V  Bus B ≥ 115.0  Bus B ≥ 114.7  c. Underfrequency (with time delay ≤ 4.0 seconds)  Bus A ≥ 57 Hz  Bus B ≥ 57 Hz	18 months
SR 3.3.8.2.3	Perform a system functional test.	18 months