

Enclosure 4
to U-603282
LA-98-013
Page 1 of 2

Marked-Up Pages of the Technical Specifications

SURVEILLANCE REQUIREMENTS

SURVEILLANCE	FREQUENCY
<p>SR 3.3.8.2.1 -----NOTE----- Only required to be performed prior to entering MODE 2 or 3 from MODE 4, when in MODE 4 for ≥ 24 hours. ----- Perform CHANNEL FUNCTIONAL TEST.</p>	184 days
<p>SR 3.3.8.2.2 Perform CHANNEL CALIBRATION. The Allowable Values shall be:</p> <p>a. Overvoltage Bus A \leq 134.2 V 127.3 Bus B \leq 133.8 V 126.7</p> <p>b. Undervoltage Bus A \geq 114.2 V 115.0 Bus B \geq 113.0 V 114.7</p> <p>c. Underfrequency (with time delay ≤ 4.0 seconds) Bus A ≥ 57 Hz Bus B ≥ 57 Hz</p>	18 months
<p>SR 3.3.8.2.3 Perform a system functional test.</p>	18 months