

Robert G. Byram
Senior Vice President
Generation and Chief Nuclear Officer
Tel. 610.774.7502 Fax 610.774.5019
E-mail: rgyram@papl.com

PP&L, Inc.
Two North Ninth Street
Allentown, PA 18101-1179
Tel. 610.774.5151
http://www.ppl-inc.com/



NOV 01 1999

U. S. Nuclear Regulatory Commission
Attn.: Document Control Desk
Mail Station P1-137
Washington, D. C. 20555

**SUSQUEHANNA STEAM ELECTRIC STATION
REVISED PROPOSED AMENDMENT NO. 227 TO LICENSE NPF-14:
ANFB-10 CRITICAL POWER CORRELATION AND
MCPR SAFETY LIMITS
PLA-5110**

Docket No. 50-387

Reference 1): PLA-5040, R.G. Byram to USNRC, "Proposed Amendment No. 227 to License NPF-14: ANFB-10 Critical Power Correlation and MCPR Safety Limits," dated March 12, 1999.

The purpose of this letter is to provide a revision to supplemental information supporting PP&L's Proposed Amendment No. 227 to License NPF-14, dated March 12, 1999 [Reference 1].

Enclosure D to Reference 1 provided the Unit 1 Cycle 12 Core Composition. That composition has been updated based on actual energy utilization during Unit 1 Cycle 11. The new Enclosure D provided herein replaces the Enclosure D contained in Reference 1. The need for this change was discussed in a telecon with the NRC Senior Project Manager on September 9, 1999.

This revision does not affect the "Safety Assessment", the "No Significant Hazards Considerations and Environmental Assessment," the applicable pages of the Susquehanna SES Unit 1 Technical Specifications and bases [marked to show the proposed changes], or the cross-reference to applicable Technical Specifications which were provided in Reference 1.

PP&L plans to implement the proposed changes in May 2000 to support the startup of Unit 1 Cycle 12 operation. We request that NRC complete its review of this change by February 11, 2000 and that the changes be made effective upon startup following the Unit 1 11th Refueling and Inspection Outage to support our scheduled implementation date.

A001


NOV 01 1999

- 2 -

PLA-5110
NRC Document Control Desk

Any questions regarding this request should be directed to Mr. M. H. Crowthers at
(610) 774-7766.

Sincerely,

A handwritten signature in black ink, appearing to be 'R. G. Byram', with a long horizontal line extending to the right.

R. G. Byram

Attachments

copy: NRC Region I
Mr. V. Nerses, NRC Sr. Project Manager - OWFN
Mr. S. L. Hansell, Acting NRC Sr. Resident Inspector - SSES
Mr. D. J. Allard, Pa. DEP

ENCLOSURE D TO PLA-5110

UNIT 1 CYCLE 12 CORE COMPOSITION

Assembly Type	Previous Cycle Operational History	Number Of Assemblies
SPC ATRIUM™-10	Fresh	256
SPC ATRIUM™-10	Once-burned	308
SPC 9x9-2	Twice-burned	200

JUL 17 1982

**BEFORE THE
UNITED STATES NUCLEAR REGULATORY COMMISSION**

In the Matter of :

PP&L, INC. :

Docket No. 50-387


**REVISED PROPOSED AMENDMENT NO. 227
FACILITY OPERATING LICENSE NO. NPF-14
SUSQUEHANNA STEAM ELECTRIC STATION
UNIT NO. 1**

Licensee, PP&L, Inc., hereby files a revised proposed Amendment No. 227 to its Facility Operating License No. NPF-14 dated July 17, 1982.

This amendment contains a revision to the Susquehanna SES Unit 1 Technical Specifications.

PP&L, INC.

BY:



R. G. Byram

Sr. Vice President - Generation and Chief Nuclear Officer

Sworn to and subscribed before me
this day of , 1999.

Notary Public