

James A. FitzPatrick
Nuclear Power Plant
268 Lake Road
P.O. Box 41
Lycoming, New York 13093
315-342-3840



Michael J. Colomb
Site Executive Officer

October 26, 1999
JAFF-99-0291

United States Nuclear Regulatory Commission
Attn: Document Control Desk
Mail Station P1-137
Washington, D.C. 20555

Subject: **Docket No. 50-333**
LICENSEE EVENT REPORT: LER-99-007-01 (DERs 99-01376 and 99-01377)

Both Trains of Core Spray Inoperable Due To Out of Tolerance Time Delay In Pump Start Interlock Relays

Reference: 1. Letter to USNRC Document Control Desk from J. Knubel, "Proposed Technical Specification Change (License Amendment) Conversion to Improved Standard Technical Specifications (JPN-99-008, dated March 31, 1999)

Dear Sir:

This report is submitted in accordance with 10 CFR 50.73(a)(2)(vii).

This report revises the scheduled completion date for Corrective Action No. 6 in LER-99-007. Corrective Action No. 6 is a request for an amendment to the Technical Specifications. The scope of this request will include an extension of the surveillance interval for the Residual Heat Removal, Core Spray, and Automatic Depressurization System timer relays to 24 months. This request is consistent with FitzPatrick's Improved Technical Specification submittal (Reference 1).

There are no commitments contained in this report.

Questions concerning this report may be addressed to Mr. Mark Abramski at (315) 349-6305.

Very truly yours,

A handwritten signature in black ink, appearing to read 'Michael J. Colomb'.

MICHAEL J. COLOMB

MJC:MA:las
Enclosure

cc: USNRC, Region 1
USNRC, Project Directorate
USNRC Resident Inspector
INPO Records Center

PDR ADOCK

IE22