

File Center

Mr. William T. Cottle
President and Chief Executive Officer
STP Nuclear Operating Company
South Texas Project Electric
Generating Station
P. O. Box 289
Wadsworth, TX 77483

October 29, 1999

SUBJECT: SOUTH TEXAS PROJECT, UNITS 1 AND 2 - REQUEST FOR ADDITIONAL INFORMATION ON REQUEST FOR AN EXEMPTION FROM SEISMIC INSTRUMENTATION REQUIREMENTS (TAC NOS. MA6128 AND MA6129)

Dear Mr. Cottle:

The Nuclear Regulatory Commission staff is reviewing STP Nuclear Operating Company's July 13, 1999, request for an exemption from seismic instrumentation requirements. On the basis of its review, the staff has determined that additional information is needed as discussed in the enclosed request for additional information.

This request was discussed with Mr. Ken Taplett of your staff on October 18, 1999, and a mutually agreeable response of within 60 days from the date of this letter was established. If circumstances result in the need to revise the target date, please call me at the earliest opportunity. The staff appreciates the efforts expended with respect to this matter.

Sincerely,
ORIGINAL SIGNED BY:
Thomas W. Alexion, Project Manager, Section 1
Project Directorate IV & Decommissioning
Division of Licensing Project Management
Office of Nuclear Reactor Regulation

Docket Nos. 50-498 and 50-499

Enclosure: As stated

cc w/encl: See next page

DISTRIBUTION:

File Center
PUBLIC
PDIV-1 r/f
S. Black
S. Richards (clo)
C. Munson
L. Berry
OGC
ACRS
J. Tapia, RIV

FILE CENTER COPY

DFDI

*No major changes to RAI input.

To receive a copy of this document, indicate "C" in the box						
OFFICE	PDIV-1/PM	C	PDIV-D/LA	C	*EMEB/SC	PD IV-1/SC C
NAME	TAlexion		CJamerson		KManoly	RGramm lb
DATE	10/27/99		10/27/99		10/13/99	10/28/99

DOCUMENT NAME: G:\PDIV-1\SouthTexas\RAIA6128.wpd
OFFICIAL RECORD COPY

South Texas, Units 1 & 2

cc:

Mr. Cornelius F. O'Keefe
Senior Resident Inspector
U.S. Nuclear Regulatory Commission
P. O. Box 910
Bay City, TX 77414

A. Ramirez/C. M. Canady
City of Austin
Electric Utility Department
721 Barton Springs Road
Austin, TX 78704

Mr. M. T. Hardt
Mr. W. C. Gunst
City Public Service Board
P. O. Box 1771
San Antonio, TX 78296

Mr. G. E. Vaughn/C. A. Johnson
Central Power and Light Company
P. O. Box 289
Mail Code: N5012
Wadsworth, TX 74483

INPO
Records Center
700 Galleria Parkway
Atlanta, GA 30339-3064

Regional Administrator, Region IV
U.S. Nuclear Regulatory Commission
611 Ryan Plaza Drive, Suite 400
Arlington, TX 76011

D. G. Tees/R. L. Balcom
Houston Lighting & Power Co.
P. O. Box 1700
Houston, TX 77251

Judge, Matagorda County
Matagorda County Courthouse
1700 Seventh Street
Bay City, TX 77414

Jack R. Newman, Esq.
Morgan, Lewis & Bockius
1800 M Street, N.W.
Washington, DC 20036-5869

Mr. J. J. Sheppard, Vice President
Engineering & Technical Services
STP Nuclear Operating Company
P. O. Box 289
Wadsworth, TX 77483

S. M. Head, Supervisor, Licensing
Quality & Licensing Department
STP Nuclear Operating Company
P. O. Box 289
Wadsworth, TX 77483

Office of the Governor
ATTN: John Howard, Director
Environmental and Natural
Resources Policy
P. O. Box 12428
Austin, TX 78711

Jon C. Wood
Matthews & Branscomb
One Alamo Center
106 S. St. Mary's Street, Suite 700
San Antonio, TX 78205-3692

Arthur C. Tate, Director
Division of Compliance & Inspection
Bureau of Radiation Control
Texas Department of Health
1100 West 49th Street
Austin, TX 78756

Jim Calloway
Public Utility Commission of Texas
Electric Industry Analysis
P. O. Box 13326
Austin, TX 78711-3326

Request for Additional Information

Proposed Exemption from the Seismic Instrumentation Requirements

South Texas Project, Units 1 and 2

The staff has the following questions concerning the licensee's proposed earthquake response plan (Appendix C to Attachment 1) and the statement on page 2 of Attachment 1 that South Texas Project will follow the Electric Power Research Institute (EPRI) "Guidelines for Nuclear Plant Response to an Earthquake," EPRI NP-6695.

1. Do the "acceleration data" referred to on page 1 of Appendix C to Attachment 1 represent the response spectrum and cumulative absolute velocity (CAV) checks required by the operating basis earthquake (OBE) exceedance criterion given in Appendix A of EPRI NP-6695? If not, then explain the term "acceleration data."
2. Are you planning on following the revised OBE exceedance criterion given in EPRI TR-100082, "Standardization of the Cumulative Absolute Velocity?" If not, then what OBE exceedance criterion are you following?
3. Describe the stand-alone seismic instrument, the hardware that you will use to retrieve the ground motion data from the seismic instrument, and the software that you will use to process the ground motion data in order to obtain response spectra and CAV.
4. Describe your procedures for calibrating the seismic instrument and retrieving and processing the ground motion data.
5. Will you be able to process the ground motion record from the stand-alone seismic instrument, which will be maintained at the site, in order to determine the ground motion parameters required by the OBE exceedance criterion (response spectrum and CAV) within a time period of 4 hours as stated on page 4-5 of EPRI NP-6695?
6. Are you planning to locate the stand-alone instrument in either a free-field location adjacent to the plant or at a location in the plant for which there is a design-basis in-structure response spectrum as recommended by EPRI NP-5930, "A Criterion for Determining Exceedance of the Operating Basis Earthquake?" If not, then provide the rationale for the location of the seismic instrument.
7. Page 1 of Appendix C to Attachment 1 states, "Information regarding the earthquake magnitude and epicenter will be readily available from the National Earthquake Resource Center." Identify the "National Earthquake Resource Center" in the event that this organization differs from the National Earthquake Information Center. Also provide the details of the procedure that will be used to "readily" obtain the earthquake epicenter and magnitude information.

ENCLOSURE