

UNITED STATES NUCLEAR REGULATORY COMMISSION

WASHINGTON, D.C. 20555-0001

#### VIRGINIA ELECTRIC AND POWER COMPANY

#### DOCKET NO. 50-280

#### SURRY POWER STATION, UNIT NO. 1

#### AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 222 License No. DPR-32

- 1. The Nuclear Regulatory Commission (the Commission) has found that:
  - A. The application for amendment by Virginia Electric and Power Company (the licensee) dated April 28, 1999, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act) and the Commission's rules and regulations set forth in 10 CFR Chapter I;
  - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
  - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
  - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
  - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.

- 2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment, and paragraph 3.B of Facility Operating License No. DPR-32 is hereby amended to read as follows:
  - (B) <u>Technical Specifications</u>

The Technical Specifications contained in Appendix A, as revised through Amendment No. 222, are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications.

3. This license amendment is effective as of its date of issuance and shall be implemented within 30 days.

FOR THE NUCLEAR REGULATORY COMMISSION

Richard I. Emch, J.

Richard L. Emch, Jr., Chief, Section 1 Project Directorate II Division of Licensing Project Management Office of Nuclear Reactor Regulation

Attachment: Changes to the Technical Specifications

Date of Issuance: November 1, 1999



UNITED STATES NUCLEAR REGULATORY COMMISSION

WASHINGTON, D.C. 20555-0001

#### VIRGINIA ELECTRIC AND POWER COMPANY

# DOCKET NO. 50-281

### SURRY POWER STATION, UNIT NO. 2

### AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 222 License No. DPR-37

- 1. The Nuclear Regulatory Commission (the Commission) has found that:
  - A. The application for amendment by Virginia Electric and Power Company (the licensee) dated April 28, 1999, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act) and the Commission's rules and regulations set forth in 10 CFR Chapter I;
  - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
  - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
  - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
  - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.

- 2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment, and paragraph 3.B of Facility Operating License No. DPR-37 is hereby amended to read as follows:
  - (B) <u>Technical Specifications</u>

The Technical Specifications contained in Appendix A, as revised through Amendment No. 222, are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications.

3. This license amendment is effective as of its date of issuance and shall be implemented within 30 days.

FOR THE NUCLEAR REGULATORY COMMISSION

Richard I. Emch. J.

Richard L. Emch, Jr., Chief, Section 1 Project Directorate II Division of Licensing Project Management Office of Nuclear Reactor Regulation

Attachment: Changes to the Technical Specifications

Date of Issuance: November 1, 1999

#### ATTACHMENT TO

# LICENSE AMENDMENT NO. 222 TO FACILITY OPERATING LICENSE NO. DPR-32 LICENSE AMENDMENT NO. 222 TO FACILITY OPERATING LICENSE NO. DPR-37

# DOCKET NOS. 50-280 AND 50-281

Remove Page	Insert Page
TS 3.4-1	TS 3.4-1
TS 4.1-10	TS 4.1-10

#### 3.4 SPRAY SYSTEMS

#### Applicability

Applies to the operational status of the Spray Systems.

#### Objective

To define those limiting conditions for operation of the Spray Systems necessary to assure safe unit operation.

#### Specification

- A. A unit's Reactor Coolant System temperature or pressure shall not be made to exceed 350°F or 450 psig, respectively, unless the following Spray System conditions in the unit are met:
  - 1. Two Containment Spray Subsystems, including containment spray pumps, piping, and valves shall be OPERABLE.
  - 2. Four Recirculation Spray Subsystems, including recirculation spray pumps, coolers, piping, and valves shall be OPERABLE.
  - The refueling water storage tank shall contain at least 387,100 gallons of borated water at a maximum temperature of 45°F. The boron concentration shall be at least 2300 ppm but not greater than 2500 ppm.
  - 4. The refueling water chemical addition tank shall contain at least 3930 gallons of solution with a sodium hydroxide concentration of at least 17 percent by weight but not greater than 18 percent by weight.
  - 5. All valves, piping, and interlocks associated with the above components which are required to operate under accident conditions shall be OPERABLE.

1

# TABLE 4.1-2B MINIMUM FREQUENCIES FOR SAMPLING TESTS

	DESCRIPTION	TECT	EDEOUENOV	UFSAR SECTION
	DESCRIPTION	<u>1ES1</u>	FREQUENCY	REFERENCE
1.	Reactor Coolant Liquid Samples	Radio-Chemical Analysis(1)	Monthly(5)	
		Gross Activity(2)	5 days/week(5)	9.1
		Tritium Activity	Weekly (5)	9.1
		* Chemistry (CL, F & O <sub>2</sub> )	5 days/week(9)	4
		* Boron Concentration	Twice/week	9.1
		E Determination	Semiannually(3)	
		DOSE EQUIVALENT I-131	Once/2 weeks(5)	
		Radio-iodine Analysis (including I-131, I-133 & I-135)	Once/4 hours(6) and (7) below	
2.	Refueling Water Storage	Chemistry (Cl & F)	Weekly	6
3.	Boric Acid Tanks	* Boron Concentration	Twice/Week	9.1
4.	Chemical Additive Tank	NaOH Concentration	Monthly	6
5.	Spent Fuel Pit	* Boron Concentration	Monthly	9.5
6.	Secondary Coolant	Fifteen minute degassed beta and gamma activity	Once/72 hours	
		DOSE EQUIVALENT I-131	Monthly(4) Semiannually(8)	
7.	Stack Gas Iodine and Particulate Samples	* I-131 and particulate radioactive releases	Weekly	

\* See Specification 4.1.D

.

- (1) A radiochemical analysis will be made to evaluate the following corrosion products: Cr-51, Fe-59, Mn-54, Co-58, and Co-60.
- (2) A gross beta-gamma degassed activity analysis shall consist of the quantitative measurement of the total radioactivity of the primary coolant in units of  $\mu$ Ci/cc.