



UNITED STATES
NUCLEAR REGULATORY COMMISSION

WASHINGTON, D.C. 20555-0001

November 8, 1999

Mr. C. Randy Hutchinson
Vice President, Operations ANO
Entergy Operations, Inc.
1448 S. R. 333
Russellville, AR 72801

SUBJECT: ARKANSAS NUCLEAR ONE, UNIT NOS. 1 AND 2 RE: REVISIONS TO THE
UFSAR - PAST AND FUTURE COMPLIANCE WITH 10 CFR 50.71(e)(4)
(TAC NOS. M72381 AND M72382)

Title 10 of the *Code of Federal Regulations* (10 CFR), Subsection 50.71(e)(4) specifies the schedular requirements whereby licensees are to submit revisions to their Updated Final Safety Analysis Reports (UFSARs). It requires revisions to be made "...annually or 6 months after each refueling outage provided the interval between successive updates does not exceed 24 months." In a 1997 survey, we found numerous incidents of noncompliance by licensees of both single- and multi-unit plants with this schedular requirement. In many cases, licensees for multi-unit sites were basing their UFSAR submissions on the outage schedule of one unit.

We understand that some confusion about the proper interpretation of 10 CFR 50.71(e)(4) may have been caused by an NRC staff letter to Commonwealth Edison Company (ComEd) dated June 15, 1993, which endorsed a submission schedule proposed by ComEd for its plants. Neither ComEd's proposed schedule nor the staff's endorsement were in literal compliance with 10 CFR 50.71(e)(4). Nevertheless, many licensees adopted the staff position expressed in the June 15, 1993, letter and thus deviated from the schedular requirements of this regulation. Recently, the staff granted exemptions to the ComEd plants. The transmittal letter (D. Skay to O. D. Kingsley, dated July 27, 1999) states that "This [Skay] letter and the enclosed exemptions supersede our letter of June 15, 1993."

We note that you have not requested a schedular exemption to 10 CFR 50.71(e)(4) for Arkansas Nuclear One, Unit Nos. 1 and 2. This may indicate that either you intend to comply with the correct interpretation of the regulation, or you may have incorrectly interpreted the regulation in the past. The purpose of this letter is to clarify any misunderstanding of this regulation. We will exercise enforcement discretion, in accordance with Section VII.B.6 of the NRC Enforcement Policy, for any incidents of past violation of 10 CFR 50.71(e)(4). In the future, we will enforce the schedular requirements as prescribed, or as modified by an exemption, for Arkansas Nuclear One, Unit Nos. 1 and 2.

Docket
file

PDR ADOCK.

DF01

C. R. Hutchinson

- 2 -

November 8, 1999

There is no need to respond to this letter. If you have any questions, please call me at 301-415-1320.

Sincerely,

ORIGINAL SIGNED BY

M. Christopher Nolan, Project Manager, Section 1
Project Directorate IV & Decommissioning
Division of Licensing Project Management
Office of Nuclear Reactor Regulation

Docket Nos. 50-313 and 50-368

cc: See next page

DISTRIBUTION:

File Center	PUBLIC	PD4-1 Reading
OGC	ACRS	P. Tam
K. Brockman, RIV	S. Richards	L. Berry

To receive a copy of this document, indicate "C" in the box						
OFFICE	PDIV-1/PM	C	PDIV-1/LA	C	PDIV-1/SC	C
NAME	C.Nolan:db ^{med}		D.Johnson <i>dj</i>		R.Gramm <i>RG</i>	
DATE	11 / 01 / 99		11 / 01 / 99		11 / 1 / 99	

DOCUMENT NAME: G:\PDIV-1\ANO1-2\LtrFSAR1027.wpd
OFFICIAL RECORD COPY

Arkansas Nuclear One

cc:

Executive Vice President
& Chief Operating Officer
Entergy Operations, Inc.
P. O. Box 31995
Jackson, MS 39286-1995

Vice President, Operations Support
Entergy Operations, Inc.
P. O. Box 31995
Jackson, MS 39286-1995

Director, Division of Radiation
Control and Emergency Management
Arkansas Department of Health
4815 West Markham Street, Slot 30
Little Rock, AR 72205-3867

Wise, Carter, Child & Caraway
P. O. Box 651
Jackson, MS 39205

Winston & Strawn
1400 L Street, N.W.
Washington, DC 20005-3502

Manager, Rockville Nuclear Licensing
Framatone Technologies
1700 Rockville Pike, Suite 525
Rockville, MD 20852

Senior Resident Inspector
U.S. Nuclear Regulatory Commission
P. O. Box 310
London, AR 72847

Regional Administrator, Region IV
U.S. Nuclear Regulatory Commission
611 Ryan Plaza Drive, Suite 400
Arlington, TX 76011-8064

County Judge of Pope County
Pope County Courthouse
Russellville, AR 72801