



NOV 08 1999

L-99-242
10 CFR 50.36

U. S. Nuclear Regulatory Commission
Attn: Document Control Desk
Washington, D. C. 20555

Re: Turkey Point Units 3 and 4
Docket Nos. 50-250 and 50-251
Monthly Operating Report - October, 1999

In accordance with the requirements of Turkey Point Units 3 and 4 Technical Specification 6.9.1.5, and the guidance of Generic Letter 97-02, attached are the October, 1999, Operating Data Report and Summary of Operating Experience for Turkey Point Units 3 and 4.

Very truly yours,

A handwritten signature in black ink, appearing to read 'R. J. Hovey', with a long horizontal flourish extending to the right.

R. J. Hovey
Vice President
Turkey Point Plant

DRL

Attachments

cc: Regional Administrator, Region II, USNRC
Senior Resident Inspector, USNRC, Turkey Point Plant

IE24

AVERAGE DAILY UNIT POWER LEVEL

DOCKET NO. 50-250
UNIT: Turkey Point #3
DATE: November 2, 1999
COMPLETED BY: D. R. Lafleur
TELEPHONE: (305) 246-7150

REPORT MONTH October, 1999

DAY	AVERAGE DAILY POWER LEVEL (MWe-Net)
10/1/99	698
10/2/99	703
10/3/99	707
10/4/99	708
10/5/99	706
10/6/99	702
10/7/99	703
10/8/99	706
10/9/99	707
10/10/99	709
10/11/99	707
10/12/99	698
10/13/99	691
10/14/99	710
10/15/99	717
10/16/99	716
10/17/99	711
10/18/99	708
10/19/99	700
10/20/99	703
10/21/99	702
10/22/99	706
10/23/99	713
10/24/99	719
10/25/99	723
10/26/99	723
10/27/99	723
10/28/99	723
10/29/99	721
10/30/99	719
10/31/99	715

OPERATING DATA REPORT

DOCKET NO. 50-250
UNIT NAME TURKEY POINT UNIT 3
DATE November 2, 1999
COMPLETED BY D. R. Lafleur
TELEPHONE (305) 246-7150

REPORTING PERIOD October, 1999
(Month/Year)

1. Design Electrical Rating (MWe-Net)_____ 720
2. Maximum Dependable Capacity (MWe-Net)_____ 693

	<u>MONTH</u>	<u>-YTD-</u>	<u>CUMULATIVE</u>
3. Number of Hours Reactor Was Critical_____	745.0	7269.6	168179.6
4. Number of Hours Generator Was On Line_____	745.0	7263.3	165980.9
5. Unit Reserve Shutdown Hours_____	0.0	0.0	121.8
6. Net Electrical Energy (MWH)_____	528619	5094595	106915454

SUMMARY OF OPERATING EXPERIENCE

DOCKET NO. 50-250
UNIT: Turkey Point #3
DATE: November 2, 1999
COMPLETED BY: D.R. Lafleur
TELEPHONE: (305) 246-7150

REPORT MONTH October, 1999

Unit 3 operated essentially at 100% in the beginning of the month of October, 1999. On October 12, 1999, power was reduced to 90% for repair of the Heater Drain Tank Level Control Valve, CV-3-1510A. Unit 3 resumed 100% power on October 13, and stayed essentially at 100% power for the rest of the month of October, 1999.

UNIT SHUTDOWNS

DOCKET NO. 50-250
 UNIT NAME: Turkey Point #3
 DATE: November 2, 1999
 COMPLETED BY: D. R. Lafleur
 TELEPHONE: (305) 246-7150

REPORT MONTH October, 1999

No.	Date	Type ¹	Duration (Hours)	Reason ²	Method of Shutting Down Reactor ³	Cause & Corrective Action Comments
N/A	N/A	N/A	N/A	N/A	N/A	N/A

1

F - Forced
S - Scheduled

2

Reason
 A - Equipment Failure
 B - Maintenance or Test
 C - Refueling
 D - Regulatory restriction
 E - Operator Training & License Examination
 F - Administrative
 G - Operational Error (Explain)
 H - Other (Explain)

3

Method
 1 - Manual
 2 - Manual Scram
 3 - Automatic Scram
 4 - Continuation
 5 - Other (Explain)

AVERAGE DAILY UNIT POWER LEVEL

DOCKET NO. 50-251
UNIT: Turkey Point #4
DATE: November 2, 1999
COMPLETED BY: D. R. Lafleur
TELEPHONE: (305) 246-7150

REPORT MONTH October, 1999

DAY	AVERAGE DAILY POWER LEVEL (MWe-Net)
10/1/99	698
10/2/99	701
10/3/99	706
10/4/99	708
10/5/99	705
10/6/99	703
10/7/99	707
10/8/99	706
10/9/99	708
10/10/99	710
10/11/99	709
10/12/99	706
10/13/99	708
10/14/99	711
10/15/99	715
10/16/99	718
10/17/99	716
10/18/99	711
10/19/99	705
10/20/99	702
10/21/99	696
10/22/99	698
10/23/99	712
10/24/99	719
10/25/99	721
10/26/99	722
10/27/99	724
10/28/99	723
10/29/99	720
10/30/99	719
10/31/99	716

OPERATING DATA REPORT

DOCKET NO. 50-251
UNIT NAME TURKEY POINT UNIT 4
DATE November 2, 1999
COMPLETED BY D. R. Lafleur
TELEPHONE (305) 246-7150

REPORTING PERIOD October, 1999
(Month/Year)

1. Design Electrical Rating (MWe-Net)_____ **720**
2. Maximum Dependable Capacity (MWe-Net)_____ **693**

	<u>MONTH</u>	<u>-YTD-</u>	<u>CUMULATIVE</u>
3. Number of Hours Reactor Was Critical_____	745.0	6742.7	164810.2
4. Number of Hours Generator Was On Line_____	745.0	6721.8	160458.3
5. Unit Reserve Shutdown Hours_____	0.0	0.0	577.2
6. Net Electrical Energy (MWH)_____	529238	4694743	104367841

UNIT SHUTDOWNS

DOCKET NO. 50-251
 UNIT NAME: Turkey Point #4
 DATE: November 2, 1999
 COMPLETED BY: D. R. Lafleur
 TELEPHONE: (305) 246-7150

REPORT MONTH October, 1999

No.	Date	Type ¹	Duration (Hours)	Reason ²	Method of Shutting Down Reactor ³	Cause & Corrective Action Comments
N/A	N/A	N/A	N/A	N/A	N/A	N/A

1

F - Forced
 S - Scheduled

2

Reason
 A - Equipment Failure
 B - Maintenance or Test
 C - Refueling
 D - Regulatory restriction
 E - Operator Training & License Examination
 F - Administrative
 G - Operational Error (Explain)
 H - Other (Explain)

3

Method
 1 - Manual
 2 - Manual Scram
 3 - Automatic Scram
 4 - Continued
 5 - Other (Explain)

SUMMARY OF OPERATING EXPERIENCE

DOCKET NO. 50-251
UNIT: Turkey Point #4
DATE: November 2, 1999
COMPLETE BY: D. R. Lafleur
TELEPHONE: (305)246-7150

REPORT MONTH October, 1999

Unit 4 operated at essentially 100% for the entire month of October, 1999.