



November 8, 1999

PG&E Letter DCL-99-143

U.S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Washington, DC 20555-0001

Docket No. 50-323, OL-DPR-82
Diablo Canyon Unit 2
Special Report 99-07: Steam Generator Tube Plugging During Unit 2
Ninth Refueling Outage

Dear Commissioners and Staff:

In accordance with Diablo Canyon Power Plant Technical Specifications 4.4.5.5a and 6.9.2, this special report provides the number of steam generator (SG) tubes plugged during the Unit 2 ninth refueling outage completed during October 1999.

A total of 67 tubes were plugged and 138 tubes were unplugged, for a net gain of 71 tubes, as detailed in the following table.

SG	Unplugged Tubes	Plugged Tubes	Notes
2-1	15	8	Net Gain 7 Tubes
2-2	34	29	Net Gain 5 Tubes
2-3	23	5	Net Gain 18 Tubes
2-4	66	25	Net Gain 41 Tubes
Total	138	67	Net Gain 71 Tubes

Unplugging tubes was possible during this outage by the application of alternate repair criteria approved in License Amendments 122 and 127. If there are any questions regarding this special report, contact L. R. Exner at (805) 545-4302.

Sincerely,

Lawrence F. Womack

A001

Document Control Desk
November 8, 1999
Page 2

PG&E Letter DCL-99-143

cc: Steven D. Bloom
Ellis W. Merschoff
David L. Proulx
State of California
Diablo Distribution

DDM/469