

# VERMONT YANKEE NUCLEAR POWER CORPORATION

185 Old Ferry Road, Brattleboro, VT 05301-7002  
(802) 257-5271

November 9, 1999  
BVY 99-144

U.S. Nuclear Regulatory Commission  
ATTN: Document Control Desk  
Washington, DC 20555

**Subject: Vermont Yankee Nuclear Power Station  
License No. DPR-28 (Docket No. 50-271)  
Revision of Technical Specification Bases Page**

This letter provides a revised Technical Specification (TS) Bases page.

Bases page 112 has been revised to include "LPCI subsystems" in the listing of systems that must have full discharge lines to be considered operable. This is an administrative change to achieve consistency as TS 3.5.I already requires this condition.


This change to the TS Bases has been determined to not involve an unreviewed safety question in accordance with 10CFR50.59 and therefore does not require prior NRC approval.

Also attached for your convenience is a marked-up Bases page indicating where the specific changes were made.

Should you have any questions concerning this matter, please contact Mr. Jeffrey T. Meyer at (802) 258-4105.

Sincerely,

VERMONT YANKEE NUCLEAR POWER CORPORATION

  
\_\_\_\_\_  
Gautam Sen  
Licensing Manager

#### Attachments

cc: USNRC Region 1 Administrator  
USNRC Resident Inspector – VYNPS  
USNRC Project Manager – VYNPS  
Vermont Department of Public Service

A001