



November 8, 1999  
LIC-99-0103

U. S. Nuclear Regulatory Commission  
ATTN: Document Control Desk  
Mail Station P1-137  
Washington, DC 20555

Reference: Docket No. 50-285

**SUBJECT: Fort Calhoun Station (FCS) Steam Generator Tube Plugging Report - 1999 Refueling Outage**

The Omaha Public Power District (OPPD) completed eddy current testing of the steam generator tubes at Fort Calhoun Station (FCS) on October 25, 1999, during the eighteenth refueling outage. In accordance with Technical Specification 3.17(5)(i), OPPD reports that 63 tubes were plugged in Steam Generator RC-2A and 57 tubes were plugged in Steam Generator RC-2B. To date, RC-2A has 167 plugged tubes and RC-2B has 157 plugged tubes. Specific details in regard to steam generator tube plugging will be included in the six (6) month report required by Technical Specification 3.17(5)(ii).

Please contact me if you have any questions.

Sincerely,

S. K. Gambhir  
Division Manager  
Nuclear Operations

SKG/mle

C: E. W. Merschoff, NRC Regional Administrator, Region IV  
L. R. Wharton, NRC Project Manager  
W. C. Walker, NRC Senior Resident Inspector  
Winston & Strawn

ADD 1