

From: Joseph Sebrosky
To: internet:rgill@duke-energy.com
Date: Fri, Oct 29, 1999 3:00 PM
Subject: SER OI 2.2.3.4.3.2.1-1 questions

Bob,

The following questions relate to scoping for the subject SER OI.

1. In response to SER OI 2.2.3.4.3.2.1-1 Duke provided drawings highlighting the portions of the chilled water system that are considered to be within scope of license renewal. Regarding these drawings, why does the boundary end at WC-40 on drawing OFD-116J-1.6?
2. In response to SER OI 2.2.3.4.3.2.1-1 Duke states that "portions of the Control Room Pressurization and Filtration System have been added to the scope of license renewal due to the addition of the Chilled Water System." Duke also provided a Table 3 in response to this SER OI. The staff compared Table 3 to table 2.5-13 in the license renewal application. Based on the comparison of the tables it is not clear to the staff what portions of the Control Room Pressurization and Filtration System have been added to the scope of license renewal.

Enclosure 1