



Palo Verde Nuclear
Generating Station

Gregg R. Overbeck
Senior Vice President
Nuclear

TEL (623) 393-5148
FAX (623) 393-6077

Mail Station 7602
P.O. Box 52034
Phoenix, AZ 85072-2034

102-04368-GRO/AKK/RJR

November 8, 1999

U. S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Mail Station P1-37
Washington, DC 20555-0001

Dear Sirs:

**Subject: Palo Verde Nuclear Generating Station (PVNGS)
Units 1, 2, and 3
Docket Nos. STN 50-528/529/530
Updated Final Safety Analysis Report, Revision 10, Errata Pages**

Enclosed are four errata pages for Revision 10 of the PVNGS UFSAR that are being issued to replace previously issued pages that contain minor typographical and printing errors in some copies. These pages are for direct replacement of the existing pages.

Included in this package are the original and 10 copies of the errata pages. One copy is also being provided to the NRC Region IV Office and one copy to the NRC Resident Inspector's Office at PVNGS.

No commitments are being made to the NRC by this letter.

Should you have any questions, please contact Scott A. Bauer at (623) 393-5978.

Sincerely,

GRO/AKK/RJR/rjh

Enclosure

cc: E. W. Merschoff (w/Enclosure)
M. B. Fields (w/o Enclosure)
J. H. Moorman (w/o Enclosure)

0500528 K

A053

PVNGS UPDATED FSAR

METEOROLOGY

j = The j (th) atmospheric stability class, grouped into seven classes according to Regulatory Guide 1.23

k = k (th) wind direction sector

U_i = mid point value of the i (th) wind-speed class (meter/second)

σ_{zj} = the vertical plume spread for stability class j at distance x (meter)

$DEPL_{ij}(x, K)$ = plume depletion reduction factor at distance x for the i (th) wind speed class, the j (th) stability class, and k (th) wind direction sector.

$DEC_i(x)$ = radiodecay reduction factor at distance x for the i (th) wind speed class. Radiodecay is based on a half-life of 2.26 days per Regulatory Guide 1.111.

$RF(x, k)$ = Terrain Adjustment Factor at downwind distance x and k (th) wind direction sector.

$F_{ij}(k)$ = joint probability of occurrence of the i (th) wind speed class, j (th) stability class, and K (th) wind direction sector.

c = mixing volume coefficient (shape factor) in the building-wake term

D_z = building height (meters) used to compute additional atmospheric dispersion due to the building wake. For the PVNGS analysis

$D_z = 58$ meters (the containment building height).

Equation (4) represents the maximum additional atmospheric dispersion due to the building wake, The results of both equations are compared and the largest (most conservative) value is used. In this analysis credit is not taken for depletion, gravitational settling or dry deposition.

June 1999

2.3-72

Revision 10

Table 2.3-33
PVNGS TERRAIN ADJUSTMENT FACTORS

Distance (meters)	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW
402	1.0	1.1	1.1	1.1	1.2	1.1	1.1	1.1	1.1	1.1	1.1	1.1	1.1	1.0	1.0	1.0
805	1.0	1.1	1.2	1.1	1.2	1.2	1.1	1.1	1.1	1.1	1.1	1.1	1.2	1.2	1.3	1.2
1,207	1.2	1.2	1.3	1.2	1.3	1.4	1.2	1.2	1.1	1.2	1.2	1.3	1.2	1.2	1.4	1.4
1,609	1.4	1.4	1.4	1.3	1.4	1.5	1.4	1.3	1.1	1.2	1.4	1.7	1.6	1.4	1.5	1.7
2,414	1.6	1.6	1.5	1.3	1.4	1.4	1.4	1.3	1.1	1.2	1.6	1.7	1.6	1.5	1.7	1.7
3,219	1.8	1.6	1.5	1.4	1.4	1.4	1.4	1.3	1.2	1.3	1.7	1.7	1.8	1.6	1.8	1.9
4,023	1.8	1.6	1.5	1.3	1.4	1.4	1.3	1.3	1.3	1.3	1.6	1.9	1.8	1.5	1.9	2.0
4,828	1.7	1.6	1.5	1.2	1.3	1.3	1.2	1.3	1.4	1.5	1.6	1.9	1.5	1.6	2.0	2.1
5,633	1.8	1.6	1.5	1.2	1.2	1.2	1.2	1.3	1.5	1.5	1.8	1.9	1.5	1.6	2.0	2.2
6,437	1.8	1.5	1.5	1.1	1.0	1.2	1.2	1.3	1.5	1.5	1.8	2.0	1.5	1.6	2.0	2.1
7,242	1.6	1.5	1.4	1.0	1.0	1.0	1.1	1.3	1.6	1.6	1.7	2.0	1.5	1.6	1.9	2.0
8,047	1.6	1.4	1.4	1.0	1.0	1.0	1.0	1.2	1.5	1.6	1.7	1.8	1.5	1.5	2.0	2.0
12,070	1.3	1.2	1.2	1.0	1.0	1.0	1.0	1.1	1.3	1.3	1.4	1.4	1.3	1.3	1.5	1.5
16,093	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0
24,140	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0
32,187	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0
40,234	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0
48,280	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0
56,327	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0
64,374	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0
72,421	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0
80,467	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0

Source: Taken from Appendix I, Analysis, reference 27.

PVNGS UPDATED FSAR

METEOLOGY

2.3.6 REFERENCES

1. Baldwin, J. W., 1973, Climates of the United States, National Oceanic and Atmospheric Administration, Washington, D.C.
2. National Climatic Center, 1949-1977, Local Climatological Data for Phoenix, Arizona-Sky Harbor International Airport. NOAA. U.S. Department of Commerce.
3. Sellers, W. D. and Hill, R. H., 1974, Arizona Climate 1931 - 1972. The University of Arizona Press, Tucson, Arizona.
4. Climates of the States, 1978, Vol. I - Alabama - Montana, NOAA, U.S. Department of Commerce.
5. National Severe Storms Forecast Center 1978, "Tornadoes Within 50 NM of Phoenix, Arizona," Kansas City, Missouri, NOAA.
6. Thom, H. C. S., 1963, "Tornado Probabilities, "Mon. Wea. Rev., 91, 730-736.
7. Brooks, C. E. P., and Carruthers, N., 1953, Handbook of Statistical Methods in Meteorology, M.O. 538, London, England, Her Majesty's Stationery Office, pp 131-136.
8. Thom, H. C. S., 1968, "New Distribution of Extreme Winds in the United States, "Journal of the Structural Division, Proceedings of the American Society of Civil Engineers, pp 1787-1799.
9. Huss, P. O., 1946, Relations Between Gusts and Average Wind Speed for Housing Load Determination, DGAI 140, Daniel Guggenheim Airship Institute, Cleveland, Ohio.

PVNGS UPDATED FSAR

METEOROLOGY

10. ANSI, 1972, "Building Code Requirements for Minimum Design Loads in Buildings and Other Structures," American National Standard Institute, New York, ANSI A58.1-1972 (Revision of A58.1-1055).
11. Golde, R. H., "Protection of Structures Against Lightning," Proceedings, The Institution of Electrical Engineers, Vol 115, No. 10, October 1968.
12. Storm Data (1951-1975), National Weather Records Center, National Oceanic and Atmospheric Administration, Environmental Data Service, Asheville, N.C.
13. Arizona Public Service Company - Environmental Management Department, "Particulate Characteristics of Dust Storms at the Palo Verde Nuclear Generating Station," Final Report, October 1978.
14. Site Analysis Branch Position, "Winter Precipitation Loads," U.S. Nuclear Regulatory Commission, March 24, 1975.
15. Hosler, C. R., 1961, "Low-Level Inversion Frequency in the Continuous United States," Monthly Was. Rev., September 1961.
16. Holzworth, G. C., "Mixing Heights, Wind Speeds, and Potential for Urban Air Pollution Throughout the Contiguous United States," Environmental Protection Agency, AP-101, January 1972.
17. Environmental Science Services Administration, "Buckeye, Arizona, 1893-1957, Climatological Summary." Climatography of the United States, No. 20-2 (1975).
18. Environmental Science Services Administration. "Gila Bend, Arizona, 1893-1957, Climatological Summary," Climatography of the United States, No. 20-2 (1975).

METEOROLOGY

19. Environmental Science Services Administration, "Litchfield Park, Arizona, 1918-1957, Climatological Summary," Climatography of the United States, No. 20-2 (1975).
20. Turner, D. B., "A Diffusion Model for An Urban Area," Journal of Applied Meteorology, 3:1:83-91, February 1964.
21. Fisher, G. E., "FOG Model Description," NUS-TM-S-185 (July 1974).
22. Petterssen, D., "Weather Analysis and Forecasting," Vol. II, McGraw-Hill, New York (1956).
23. Regulatory Guide 1.145 Rev 1.0, "Atmospheric Dispersion Models for Potential Accident Consequence Assessments at Nuclear Power Plants," U.S. Nuclear Regulatory Commission, November 1982.
24. Yanskey, G. R., Markee, E. H., and Richter, A. T., Climatography of the National Reactor Testing Station, IDO-12048, ESSA, Figures 3-4, January 1966.
25. NUREG-0857, November 1981 section 2.3.4
26. "BLANK"
27. Evaluation of Compliance with Appendix I of 10CFR50, Palo Verde Nuclear Generating Station Units 4 and 5, NUS Report No. 3112, 1978.
28. "DELETED"
29. "Dust Concentration Evaluation for Palo Verde Nuclear Generating Station Units 1, 2, and 3," Study No. 13-MS-A44, Revision 0, April 23, 1990.

This Page Intentionally Left Blank

$$f_c = 900 - 582 = 318 \text{ psi (compression)}$$

Locations of cracked neutral axis is:

$$kd = x = \left(\frac{900 - 582}{900} \right) 21 = 7.42 \text{ in.}$$

Self-relieved thermal moment is:

$$M_T = \frac{f_s A_s (d - \frac{x}{3})}{12} = \frac{13970 (1) (40 - 2.47)}{12} = 43,690 \frac{\text{in} - \text{lb}}{\text{in}}$$

3B.9.1.5 Comparison of Results

The rebar and concrete stresses, self-relieved thermal moment, and neutral axis location obtained from the CECAP program are compared with the hand calculations in table 3B.9-1. It can be seen that the CECAP results compare favorably with the hand calculations.

3B.9.1.6 Conclusions

The difference in the stress results are largely due to the accuracy limit defined for the force iterations. Smaller errors would result with smaller accuracy limits, but the trade-off would be with longer run times. The CECAP program is verified for this type of thermal loading.

Table 3B.9-1

CECAP AND HAND CALCULATION COMPARISON - THERMAL GRADIENT

	CECAP	Hand Calculations	Percent Error
f_s	13,150 psi	13,790 psi	5.9
f_c	-331 psi	-318 psi	4.1
k_d	7.55 in.	7.42 in.	1.8
M_T	43,760 in-lb/in	43,690 in-lb/in	0.2

3B.9.2 DESCRIPTION OF VERIFICATION PROBLEMS (CECAP) - CE 987

Eleven example problems were analyzed by the CECAP program and compared to hand-calculated solutions. The problems were chosen to verify the program for various combinations of thermal and nonthermal (real) loads. A list of verification problems with short descriptions follows. More detailed descriptions of the problems and their hand calculated solutions can be found in the appendices.

CECAPVER
Number

Description

- | | |
|---|---|
| 1 | Thermal moment |
| 2 | Thermal moment and real axial load |
| 3 | Real moment |
| 4 | Real moment and real axial load |
| 5 | Thermal moment, real moment and real axial load |
| 6 | Uniaxial tension |
| 7 | Biaxial tension |