

Dr. Robert C. Mecredy
Vice President, Nuclear Operations
Rochester Gas and Electric Corporation
89 East Avenue
Rochester, NY 14649

November 15, 1999

SUBJECT: NOTICE OF CONSIDERATION OF ISSUANCE OF AMENDMENT TO FACILITY
OPERATING LICENSE, PROPOSED NO SIGNIFICANT HAZARDS
CONSIDERATION DETERMINATION, AND OPPORTUNITY FOR A HEARING
(TAC NO. MA6927)

Dear Dr. Mecredy:

Enclosed is a copy of a "Notice of Consideration of Issuance of Amendment to Facility Operating License, Proposed No Significant Hazards Consideration Determination and Opportunity for a Hearing," for your information. This notice relates to your application for amendment dated October 20, 1999, in which you proposed to change the footnote to the Improved Technical Specifications associated with the Design Features Fuel Storage Specification 4.3.1.1.b which required that 2300 ppm boron be maintained in the Spent Fuel Pool for the R. E Ginna Nuclear Power Plant until December 31, 1999. The footnote would be changed to require 2300 ppm boron be maintained until June 30, 2001.

This notice has been forwarded to the Office of the Federal Register for publication.

Sincerely,

Original signed by:

Guy S. Vissing, Sr. Project Manager, Section 1
Project Directorate I
Division of Licensing Project Management
Office of Nuclear Reactor Regulation

Docket No. 50-244

Enclosure: As stated

cc w/encl: See next page

DISTRIBUTION:

File Center
PUBLIC
PDI-1 R/F

E. Adensam
S. Peterson
S. Little

G. Vissing
OGC
ACRS

M. Oprendeck, RI

DOCUMENT NAME: G:\PDI-1\GINNA\INDA6927.WPD

DF01

To receive a copy of this document, indicate in the box: "C" = Copy without attachment/enclosure "E" = Copy with attachment/enclosure "N" = No copy

OFFICE	PM:PDI-1	E	LA:PDI-1	SC:PDI-1				
NAME	GVissing/rs1 <i>GM</i>		SLittle <i>SL</i>	SPeterson <i>SP</i>				
DATE	11/15/99		11/15/99	11/15/99				

Official Record Copy

0500244 P

ARC FILE CENTER

PDR ADOCK

Dr. Robert C. Mecredy
Vice President, Nuclear Operations
Rochester Gas and Electric Corporation
89 East Avenue
Rochester, NY 14649

November 15, 1999

SUBJECT: NOTICE OF CONSIDERATION OF ISSUANCE OF AMENDMENT TO FACILITY
OPERATING LICENSE, PROPOSED NO SIGNIFICANT HAZARDS
CONSIDERATION DETERMINATION, AND OPPORTUNITY FOR A HEARING
(TAC NO. MA6927)

Dear Dr. Mecredy:

Enclosed is a copy of a "Notice of Consideration of Issuance of Amendment to Facility Operating License, Proposed No Significant Hazards Consideration Determination and Opportunity for a Hearing," for your information. This notice relates to your application for amendment dated October 20, 1999, in which you proposed to change the footnote to the Improved Technical Specifications associated with the Design Features Fuel Storage Specification 4.3.1.1.b which required that 2300 ppm boron be maintained in the Spent Fuel Pool for the R. E Ginna Nuclear Power Plant until December 31, 1999. The footnote would be changed to require 2300 ppm boron be maintained until June 30, 2001.

This notice has been forwarded to the Office of the Federal Register for publication.

Sincerely,

Original signed by:

Guy S. Vissing, Sr. Project Manager, Section 1
Project Directorate I
Division of Licensing Project Management
Office of Nuclear Reactor Regulation

Docket No. 50-244

Enclosure: As stated

cc w/encl: See next page

DISTRIBUTION:

File Center
PUBLIC
PDI-1 R/F

E. Adensam
S. Peterson
S. Little

G. Vissing
OGC
ACRS

M. Oprendeck, RI

DOCUMENT NAME: G:\PDI-1\GINNA\INDA6927.WPD

To receive a copy of this document, indicate in the box: "C" = Copy without attachment/enclosure "E" = Copy with attachment/enclosure "N" = No copy

OFFICE	PM:PDI-1	E	LA:PDI-1	SC:PDI-1				
NAME	GVissing/rsi		SLittle	SPeterson				
DATE	11/15/99		11/15/99	11/15/99				

Official Record Copy



UNITED STATES
NUCLEAR REGULATORY COMMISSION

WASHINGTON, D.C. 20555-0001

November 15, 1999

Dr. Robert C. Mecredy
Vice President, Nuclear Operations
Rochester Gas and Electric Corporation
89 East Avenue
Rochester, NY 14649

SUBJECT: NOTICE OF CONSIDERATION OF ISSUANCE OF AMENDMENT TO FACILITY
OPERATING LICENSE, PROPOSED NO SIGNIFICANT HAZARDS
CONSIDERATION DETERMINATION, AND OPPORTUNITY FOR A HEARING
(TAC NO. MA6927)

Dear Dr. Mecredy:

Enclosed is a copy of a "Notice of Consideration of Issuance of Amendment to Facility Operating License, Proposed No Significant Hazards Consideration Determination and Opportunity for a Hearing," for your information. This notice relates to your application for amendment dated October 20, 1999, in which you proposed to change the footnote to the Improved Technical Specifications associated with the Design Features Fuel Storage Specification 4.3.1.1.b which required that 2300 ppm boron be maintained in the Spent Fuel Pool for the R. E Ginna Nuclear Power Plant until December 31, 1999. The footnote would be changed to require 2300 ppm boron be maintained until June 30, 2001.

This notice has been forwarded to the Office of the Federal Register for publication.

Sincerely,

A handwritten signature in cursive script, reading "Guy S. Vissing".

Guy S. Vissing, Sr. Project Manager, Section 1
Project Directorate I
Division of Licensing Project Management
Office of Nuclear Reactor Regulation

Docket No. 50-244

Enclosure: As stated

cc w/encl: See next page

R.E. Ginna Nuclear Power Plant

Peter D. Drysdale, Sr. Resident Inspector
R.E. Ginna Plant
U.S. Nuclear Regulatory Commission
1503 Lake Road
Ontario, NY 14519

Regional Administrator, Region I
U.S. Nuclear Regulatory Commission
475 Allendale Road
King of Prussia, PA 19406

Mr. F. William Valentino, President
New York State Energy, Research,
and Development Authority
Corporate Plaza West
286 Washington Avenue Extension
Albany, NY 12203-6399

Charles Donaldson, Esquire
Assistant Attorney General
New York Department of Law
120 Broadway
New York, NY 10271

Nicholas S. Reynolds
Winston & Strawn
1400 S Street N.W.
Washington, DC 20005-3502

Ms. Thelma Wideman, Director
Wayne County Emergency Management
Office
Wayne County Emergency Operations Center
7336 Route 31
Lyons, NY 14489

Ms. Mary Louise Meisenzahl
Administrator, Monroe County
Office of Emergency Preparedness
111 West Falls Road, Room 11
Rochester, NY 14620

Mr. Paul Eddy
New York State Department of
Public Service
3 Empire State Plaza, 10th Floor
Albany, NY 12223