

TRANSMITTAL OF MEETING HANDOUT MATERIALS FOR IMMEDIATE PLACEMENT IN THE PUBLIC DOMAIN

*This form is to be filled out (typed or hand-printed) by the person who announced the meeting (i.e., the person who issued the meeting notice). The completed form, and the attached copy of meeting handout materials, will be sent to the Document Control Desk on the same day of the meeting; under no circumstances will this be done later than the working day after the meeting.
Do not include proprietary materials.*

DATE OF MEETING
11/16/1999

The attached document(s), which was/were handed out in this meeting, is/are to be placed in the public domain as soon as possible. The minutes of the meeting will be issued in the near future. Following are administrative details regarding this meeting:

Docket Number(s)	50-413, -414, -369, -370
Plant/Facility Name	Catawba and McGuire Nuclear Stations
TAC Number(s) (if available)	MA5989, MA5990, MA5994, MA5995
Reference Meeting Notice	P. Tam to R. Emch, 11/2/99
Purpose of Meeting (copy from meeting notice)	To discuss technical issues related to the proposed amend- ments (reference: letter, M. Tuckman to NRC, 6/24/99) to the Technical Specifications.

NAME OF PERSON WHO ISSUED MEETING NOTICE Peter S. Tam	TITLE Senior Project Manager
---	--

OFFICE
Nuclear Reactor Regulation

DIVISION
Division of Licensing Project Management

BRANCH
Project Directorate II

Distribution of this form and attachments:
Docket File/Central File
PUBLIC

0500413 P

NRC FILE CENTER COPY

DF01

Duke Energy Corporation

DNB License Amendment and Related Methodology Meeting

November 16, 1999

Office of Nuclear Reactor Regulation

Agenda

Introduction and Agenda Review	MTC
Licensing Basis and Submittal	MTC
UCBW/MARP Licensing Process	GBS
Uncontrolled Bank Withdrawal Accident	TRN/GBT
Technical Specifications and Methodology	GBT
Question Review	MTC
Wrap-up	MTC

Introduction and Agenda Review

Duke Participants

Review Agenda

Submittal Summary

Content of Package

Referenced Topical Reports

Previous Discussions with Staff

Purpose of Meeting

Review Licensing Framework

Technical Sufficiency of Methods

Answer Staff's Questions

Importance of Submittal to Duke Reloads

Licensing Basis and Submittal

Duke Safety Analysis in Support of Reload

Since McGuire Unit 1 Cycle 8 1991

Since Catawba Unit 1 Cycle 7 1992

Duke License Amendments use these methods

Methods not materially altered since initial use

Licensing Basis for Methods

Topical Report Submittals

Letters and other Docketed Correspondence

Safety Evaluation Reports

Previous Staff Review and Approval of these Methods

Licensing Basis and Submittal (cont)

Topical Reports of Relevance

DPC-NE-2004, Core Thermal-Hydraulic Methodology Using VIPRE-01,
Revision 1 SER Issued 02/20/97

DPC-NE-3000, Thermal-Hydraulic Transient Analysis Methodology,
Revision 2 SER Issued 10/14/98

DPC-NE-3001, Multidimensional Reactor Transients and Safety Analysis
Physics Parameter Methodology, SER Issued 11/15/91

DPC-NE-3002, UFSAR Chapter 15 System Transient Analysis Methodology,
Revision 3 SER Issued 02/05/99

DPC-NE-1004, Nuclear Design Methodology Using CASMO-3 /
SIMULATE-3P, Revision 1 SER Issued 05/26/96

UCBW/MARP Licensing Process

**DPC-NE-3000 (RETRAN and VIPRE models) submitted
9/87 in response to G. L. 83-11**

**Duke topical submittal plans for B&W fuel transition
communicated to NRC 7/89**

**DPC-NE-3001 (REA, SLB, DR) submitted 1/90 for B&W
fuel transition**

**NRC requests submittal of analysis details for events not
in -3001 in meeting on 7/9/91**

**Duke proposes new DPC-NE-3002 topical with example
by fax dated 7/15/91**

**NRC (R. Jones) agrees to -3002 scope and content by
phone call on 7/16/91**

UCBW/MARP Licensing Process

Duke submits -3002 dated 8/30/91

**NRC meeting at Duke on 10/7&8/91 to walk through
the modeling details related to -3002**

**Duke submits meeting handouts on docket 10/16/91
as requested by NRC**

NRC issues questions / Duke responds

NRC SER issued 11/15/91

**NRC SER refers to 10/16/91 submittal as a
“supplement” to -3002**

**NRC 11/27/91 SER for M1C8 reload refers to the
meeting and the docketed handouts**

UCBW/MARP Licensing Process

Duke Perspective on the 3002 Review Process

Duke prepared 3002 in response to NRC request

NRC requested a meeting format to expedite review

This meeting material is docketed and forms part of the basis of the NRC approval (Current Licensing Basis)

The review was extensive in scope and depth

Significant technical resources were required by Duke and the NRC staff in this previous review

UCBW/MARP Licensing Process

Duke has reviewed the NRC's questions regarding the MARP process and the UCBW accident in detail

Duke is using NRC-approved methods in conformance with the Current Licensing Basis as described in the Topical reports and related docketed information (DPC-NE-3000 and DPC-NE-3002)

The methodology provides a conservative cycle-specific confirmation that the core power peaking will not result in exceeding the DNBR limit for the UCBW transient

Uncontrolled Bank Withdrawal Accident

- System thermal-hydraulic transient analysis (RETRAN)
 - Model - DPC-NE-3000-PA
 - Analysis methodology - DPC-NE-3002-A
- Sensitivity studies:
 - Initial power level (10, 50, 98, 100%)
 - Withdrawal rate (1 - 45 pcm/sec)
 - Burnup (BOC, EOC)
 - Pressurizer pressure control (sprays, PORVs on / off)


Uncontrolled Bank Withdrawal Accident

- Detailed core thermal-hydraulic calculation (VIPRE)
 - Model - DPC-NE-3000-PA
- Transient results taken from RETRAN for use as boundary condition forcing functions:
 - Core exit pressure
 - Core inlet temperature
 - Core inlet flow rate
 - Core average heat flux

Uncontrolled Bank Withdrawal Accident

- Transient DNBR analyses are performed using assumed core power distributions
- The most limiting case is determined based upon these transient DNBR analyses
- From the results of this limiting case, the minimum DNBR statepoint is established
- The time at which the minimum DNBR occurs is independent of the assumed power distribution

Uncontrolled Bank Withdrawal Accident



Uncontrolled Bank Withdrawal Accident

- A family of maximum allowable radial peak (MARP) limits are generated at the DNBR statepoint conditions (heat flux, flow rate, temperature, pressure)
- For each given axial power distribution (peak and location), the radial peak is adjusted until the DNBR limit is attained
- These MARP limits are then used to confirm that the cycle-specific core power peaking at the UCBW statepoint is less than the peaking at which the DNBR limit would be exceeded.

Uncontrolled Bank Withdrawal Accident

UCBW Power Distributions are Evaluated at Three Times During the Cycle, Typically Performed at BOC, MOC, and EOC

The Heat Flux Corresponding to the MDNBR Statepoint for Each Accident (10%, 50%, and 100% FP Events) is Used in the Peaking Evaluation

Rod Positions Over the Range of Allowable Positions as Determined By The Power Dependent Rod Insertion Limit Defined at the Initiating Power Level

Bank Misalignments of 12 Steps Are Considered

Uncontrolled Bank Withdrawal Accident

Power Maneuvers are Performed to Generate Xenon Distributions That Are Conservative Relative Those Expected to Occur

Both Top and Bottom Peaked Xenon Distributions are Generated and Used To Evaluate Operation at the AFD Limits

Variations in the Previous Cycle Length are Considered in The Peaking Evaluation

Acceptable Result Is No Assembly Peaking Values Above the UCBW MARP Limits

Technical Specifications and Methodology

Important Core Limit Technical Specifications

F_Q , $F_{\Delta H}$, Rod Insertion Limits, Core Flow, AFD, QPTR

Power Distribution Measurements for LCO 3.2.1 (F_Q) and LCO 3.2.2 ($F_{\Delta H}$) are Performed at Steady State Nominal Power Levels

LCO 3.2.2 Ensures the DNBR Design Basis is Met for Non-OT Δ T Condition II Transients That Initiate From Steady State Nominal Power Levels, and In Which the Event Itself Does Not Change the Power Distribution

Technical Specifications and Methodology

LCO 3.2.2 Alone Does Not Provide Protection Against DNB for UCBW Accidents Initiated at Less Than Full Power

Instead of Relying on Surveillance Measurements to Confirm Acceptable DNB Results For the UCBW Accident, Cycle Specific Analyses are Performed at the Limiting Statepoint Conditions

Question Review and Wrap Up

General Questions Left Open

Question by Question Review

Wrap Up

Dukes Methods for this submittal are within the CLB
Dukes Methods are adequate and conservative
Additional Actions to Ensure Timely Review