



Omaha Public Power District
444 South 16th Street Mall
Omaha, Nebraska 68102-2247

November 8, 1999
LIC-99-0105

U. S. Nuclear Regulatory Commission
Attn.: Document Control Desk
Mail Station P1-137
Washington, D.C. 20555

Reference: Docket No. 50-285

SUBJECT: October 1999 Monthly Operating Report (MOR)

The October 1999 MOR for Fort Calhoun Station (FCS) Unit No. 1 is attached as required by FCS Technical Specification 5.9.1.

If you have any questions, please contact me.

Sincerely,

S. K. Gambhir
Division Manager
Nuclear Operations

SKG/mle

Attachments

- c: E. W. Merschhoff, NRC Regional Administrator, Region IV
- L. R. Wharton, NRC Project Manager
- W. C. Walker, NRC Senior Resident Inspector
- INPO Records Center
- Winston & Strawn

IE24

0500285 R
10/31/99

**ATTACHMENT I
OPERATING DATA REPORT**

DOCKET NO.	<u>50-285</u>
UNIT NAME	<u>Fort Calhoun Station</u>
DATE	<u>November 2, 1999</u>
COMPLETED BY	<u>M. L. Edwards</u>
TELEPHONE	<u>(402) 533-6929</u>

REPORT PERIOD: October 1999

1. Design Electrical Rating (MWe-Net): 478
2. Maximum Dependable Capacity (MWe-Net): 478

OPERATING STATUS

	THIS MONTH	YR-TO-DATE	CUMULATIVE
3. Number of Hours Reactor was Critical:	22.1	6,573.1	182,693.9
4. Number of Hours Generator was On-line:	22.1	6,573.1	180,769.3
5. Unit Reserve Shutdown Hours:	0.0	0.0	0.0
6. Net Electrical Energy Generated (MWh):	1,975.5	3,057,594.7	77,258,539.9

ATTACHMENT II
UNIT SHUTDOWNS

REPORT MONTH October 1999

DOCKET NO. 50-285
 UNIT NAME Fort Calhoun Station
 DATE November 2, 1999
 COMPLETED BY M. L. Edwards
 TELEPHONE (402) 533-6929

No.	Date	Type F- Forced S- Scheduled	Duration (Hours)	Reason ¹	Method of Shutting Down Reactor ²	Cause & Corrective Action to Prevent Recurrence
99-01	10/01/99	S	722.9	C	1	N/A

(1)

Reason:

- A-Equipment Failure (Explain)
- B-Maintenance or Test
- C-Refueling
- D-Regulatory Restriction
- E-Operator Training/License Examination
- F-Administrative
- G-Operational Error (Explain)
- H-Other (Explain)

(2)

Method:

- 1-Manual
- 2-Manual Trip/Scram
- 3-Automatic Trip/Scram
- 4-Continuation
- 5-Other (Explain)

OPERATIONS SUMMARY:

On October 1, 1999 at 1544 hours, Fort Calhoun Station began a scheduled power reduction from 30% power in preparation for the 1999 Refueling Outage (RO). At 2205 hours the main generator was removed from service and the plant was taken off-line. The Fort Calhoun Station is scheduled to complete the outage and startup in November.

SAFETY VALVES OR PORV CHALLENGES OR FAILURES WHICH OCCURRED:

During the month of October, no power operated relief valves (PORV) or primary system safety valve challenges or failures occurred. While shutdown, the PORVs were tested satisfactorily per OP-ST-RC-3004.