



UNITED STATES
NUCLEAR REGULATORY COMMISSION

WASHINGTON, D.C. 20555-0001

November 16, 1999

Mr. James Scarola, Vice President
Shearon Harris Nuclear Power Plant
Carolina Power & Light Company
Post Office Box 165, Mail Code: Zone 1
New Hill, North Carolina 27562-0165

SUBJECT: COMPLETION OF LICENSING ACTION FOR GENERIC LETTER 98-04,
"POTENTIAL FOR DEGRADATION OF THE EMERGENCY CORE COOLING
SYSTEM AND THE CONTAINMENT SPRAY SYSTEM AFTER A LOSS-OF-
COOLANT ACCIDENT BECAUSE OF CONSTRUCTION AND PROTECTIVE
COATING DEFICIENCIES AND FOREIGN MATERIAL IN CONTAINMENT" -
SHEARON HARRIS NUCLEAR POWER PLANT, UNIT 1, (TAC NO. MA4053)

Dear Mr. Scarola:

On July 14, 1998, the U.S. Nuclear Regulatory Commission (NRC) issued Generic Letter (GL) 98-04, "Potential for Degradation of the Emergency Core Cooling System and the Containment Spray System After a Loss-of-Coolant Accident Because of Construction and Protective Coating Deficiencies and Foreign Material in Containment," to all holders of operating licenses or construction permits. The NRC issued GL 98-04 to determine the status of containment coating programs.

In GL 98-04, the NRC staff specifically requested that the licensees provide information outlined below for each of their facilities.

- (1) A summary description of the plant-specific program or programs implemented to ensure that Service Level 1 protective coatings used inside the containment are procured, applied, and maintained in compliance with applicable regulatory requirements and the plant-specific licensing basis for the facility. Include a discussion of how the plant-specific program meets the applicable criteria of 10 CFR Part 50, Appendix B, as well as information regarding any applicable standards, plant-specific procedures or other guidance used for (a) controlling the procurement of coatings and paints used at the facility; (b) the qualification testing of protective coatings; and (c) surface preparation, application, surveillance, and maintenance activities for protective coatings. Maintenance activities refer to rework of degraded coatings, removing degraded coatings to sound coatings, correctly preparing the surfaces, applying new coating, and verifying the quality of coatings.
- (2) Information demonstrating compliance with item (i) or item (ii).
 - (i) For plants with licensing-basis requirements for tracking the amount of unqualified coatings inside the containment and for assessing the impact of potential coating debris on the operation of safety-related systems, structures, and components (SSCs) during a postulated design basis loss-of-coolant accident (DB LOCA), the following information shall be provided to demonstrate compliance:

NRC FILE CENTER

0500400 P
PDR Adock.


DF01

- (a) The date and findings of the last assessment of coatings and the planned date of the next assessment of coatings.
 - (b) The limit for the amount of unqualified protective coatings allowed in the containment and how this limit is determined. Discuss any conservatism in the method used to determine this limit.
 - (c) If a commercial-grade dedication program is being used at your facility for dedicating commercial-grade coatings for Service Level 1 applications inside the containment, discuss how the program adequately qualifies a coating for Service Level 1. Identify what standards or other guidance are currently being used to dedicate containment coatings at your facility.
- (ii) For plants without the above licensing-basis requirements, information shall be provided to demonstrate compliance with the requirements of 10 CFR 50.46b(5), "Long-term cooling" and the functional capability of the safety-related containment spray system (CSS) as set forth in your licensing basis. If a licensee can demonstrate this compliance without quantifying the amount of unqualified coatings, this is acceptable. The following information shall be provided:

If a commercial-grade dedication program is not being used at your facility for qualifying and dedicating commercial-grade coatings for Service Level 1 applications, provide the regulatory and safety basis for not controlling these coatings in accordance with such a program. Additionally, explain why the facility's licensing basis does not require such a program.

In a letter dated November 9, 1998, you provided the GL 98-04 response for the Shearon Harris Nuclear Power Plant. This submittal provided the information requested by GL 98-04. Clarification was provided during a phone call that took place on August 25, 1999. The staff has reviewed your response and has concluded that all requested information has been provided; therefore, we consider GL 98-04 to be closed for your facility. We thank you for your prompt and complete response.

Sincerely,



Richard J. Laufer, Project Manager, Section 2
Project Directorate II
Division of Licensing Project Management
Office of Nuclear Reactor Regulation

Docket No. 50-400

cc: See next page

- (a) The date and findings of the last assessment of coatings and the planned date of the next assessment of coatings.
 - (b) The limit for the amount of unqualified protective coatings allowed in the containment and how this limit is determined. Discuss any conservatism in the method used to determine this limit.
 - (c) If a commercial-grade dedication program is being used at your facility for dedicating commercial-grade coatings for Service Level 1 applications inside the containment, discuss how the program adequately qualifies a coating for Service Level 1. Identify what standards or other guidance are currently being used to dedicate containment coatings at your facility.
- (ii) For plants without the above licensing-basis requirements, information shall be provided to demonstrate compliance with the requirements of 10 CFR 50.46b(5), "Long-term cooling" and the functional capability of the safety-related containment spray system (CSS) as set forth in your licensing basis. If a licensee can demonstrate this compliance without quantifying the amount of unqualified coatings, this is acceptable. The following information shall be provided:

If a commercial-grade dedication program is not being used at your facility for qualifying and dedicating commercial-grade coatings for Service Level 1 applications, provide the regulatory and safety basis for not controlling these coatings in accordance with such a program. Additionally, explain why the facility's licensing basis does not require such a program.

In a letter dated November 9, 1998, you provided the GL 98-04 response for the Shearon Harris Nuclear Power Plant. This submittal provided the information requested by GL 98-04. Clarification was provided during a phone call that took place on August 25, 1999. The staff has reviewed your response and has concluded that all requested information has been provided; therefore, we consider GL 98-04 to be closed for your facility. We thank you for your prompt and complete response.

Sincerely,

Original signed by:

Richard J. Laufer, Project Manager, Section 2
 Project Directorate II
 Division of Licensing Project Management
 Office of Nuclear Reactor Regulation

Docket No. 50-400

cc: See next page

Distribution

File Center EDunnington PUBLIC HBerkow
 PD II-2 Rdg OGC JZwolinski/SBlack ACRS BBonser, RII
 CLauron RPulsifer JDavis

FILENAME - G:\PDII-2\HARRIS\GL9804MA4053.WPD

OFFICE	PM:PDII/S2	LA:PDII/S2	SC:EMCB	(A)SC:PDII/S2	
NAME	RLaufer <i>RL</i>	EDunnington <i>ED</i>	ESullivan <i>ES</i>	KJabbour <i>KJ</i>	
DATE	11/8/99	11/8/99	11/8/99	11/9/99	1/99
COPY	<input checked="" type="checkbox"/> Yes/ <input type="checkbox"/> No	<input checked="" type="checkbox"/> Yes/ <input type="checkbox"/> No	Yes/ <input type="checkbox"/> No	<input checked="" type="checkbox"/> Yes/ <input type="checkbox"/> No	Yes/ <input type="checkbox"/> No

Mr. James Scarola
Carolina Power & Light Company

Shearon Harris Nuclear Power Plant
Unit 1

cc:

Mr. William D. Johnson
Vice President and Corporate Secretary
Carolina Power & Light Company
Post Office Box 1551
Raleigh, North Carolina 27602

Mr. Chris L. Burton
Director of Site Operations
Carolina Power & Light Company
Shearon Harris Nuclear Power Plant
Post Office Box 165, MC: Zone 1
New Hill, North Carolina 27562-0165

Resident Inspector/Harris NPS
c/o U.S. Nuclear Regulatory Commission
5421 Shearon Harris Road
New Hill, North Carolina 27562-9998

Mr. Robert P. Gruber
Executive Director
Public Staff NCUC
Post Office Box 29520
Raleigh, North Carolina 27626

Ms. Karen E. Long
Assistant Attorney General
State of North Carolina
Post Office Box 629
Raleigh, North Carolina 27602

Chairman of the North Carolina
Utilities Commission
Post Office Box 29510
Raleigh, North Carolina 27626-0510

Public Service Commission
State of South Carolina
Post Office Drawer
Columbia, South Carolina 29211

Mr. Vernon Malone, Chairman
Board of County Commissioners
of Wake County
P. O. Box 550
Raleigh, North Carolina 27602

Mr. Mel Fry, Director
Division of Radiation Protection
N.C. Department of Environment
and Natural Resources
3825 Barrett Dr.
Raleigh, North Carolina 27609-7721

Mr. Richard H. Givens, Chairman
Board of County Commissioners
of Chatham County
P. O. Box 87
Pittsboro, North Carolina 27312

Mr. Terry C. Morton
Manager
Performance Evaluation and
Regulatory Affairs CPB 7
Carolina Power & Light Company
Post Office Box 1551
Raleigh, North Carolina 27602-1551

Ms. Donna B. Alexander, Manager
Regulatory Affairs
Carolina Power & Light Company
Shearon Harris Nuclear Power Plant
P.O. Box 165, Mail Zone 1
New Hill, NC 27562-0165

Mr. Bo Clark
Plant General Manager - Harris Plant
Carolina Power & Light Company
Shearon Harris Nuclear Power Plant
P.O. Box 165
New Hill, North Carolina 27562-0165

Mr. Johnny H. Eads, Supervisor
Licensing/Regulatory Programs
Carolina Power & Light Company
Shearon Harris Nuclear Power Plant
P. O. Box 165, Mail Zone 1
New Hill, NC 27562-0165

Mr. John H. O'Neill, Jr.
Shaw, Pittman, Potts & Trowbridge
2300 N Street, NW.
Washington, DC 20037-1128