



Carolina Power & Light Company
P.O. Box 10429
Southport, NC 28461-0429

NOV 15 1999

SERIAL: BSEP 99-0185

U. S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Washington, DC 20555-0001

BRUNSWICK STEAM ELECTRIC PLANT, UNIT NOS. 1 AND 2
DOCKET NOS. 50-325 AND 50-324 / LICENSE NOS. DPR-71 AND DPR-62
OCTOBER 1999 MONTHLY OPERATING REPORT

Gentlemen:

In accordance with Technical Specification (TS) 5.6.4 for the Brunswick Steam Electric Plant (BSEP), Unit Nos. 1 and 2, Carolina Power & Light (CP&L) Company is submitting the enclosed report of operating statistics and shutdown experience for the month of October 1999. This report is being submitted to the NRC by the 15th day of the month following the calendar month covered by the report as specified in TS 5.6.4. No regulatory commitments are contained in this letter.

Please refer any questions regarding this submittal to Mr. Warren J. Dorman, Supervisor - Licensing, at (910) 457-2068.

Sincerely,

Keith R. Jury
Manager - Regulatory Affairs
Brunswick Steam Electric Plant

DCH/dch

Enclosures:

1. BSEP Unit No. 1 Monthly Operating Report October 1999
2. BSEP Unit No. 2 Monthly Operating Report October 1999

IE24

PD12 ADOCK

cc (with enclosures):

U. S. Nuclear Regulatory Commission, Region II
ATTN: Mr. Luis A. Reyes, Regional Administrator
Atlanta Federal Center
61 Forsyth Street, SW, Suite 23T85
Atlanta, GA 30303-3415

U. S. Nuclear Regulatory Commission
ATTN: Mr. Theodore A. Easlick, NRC Senior Resident Inspector
8470 River Road
Southport, NC 28461-8869

U. S. Nuclear Regulatory Commission
ATTN: Mr. Allen G. Hansen (Mail Stop OWFN 8G9)
11555 Rockville Pike
Rockville, MD 20852-2738

Ms. Jo A. Sanford
Chair - North Carolina Utilities Commission
P. O. Box 29510
Raleigh, NC 27626-0510

Electricities of N. C., Inc.
ATTN: Mr. Clarence C. Wells
P. O. Box 29513
Raleigh, NC 27626-0513

ENCLOSURE 1

BRUNSWICK STEAM ELECTRIC PLANT, UNIT NOS. 1 AND 2
DOCKET NOS. 50-325 AND 50-324 / LICENSE NOS. DPR-71 AND DPR-62

BRUNSWICK STEAM ELECTRIC PLANT, UNIT NO. 1
MONTHLY OPERATING REPORT
OCTOBER 1999

**APPENDIX A
OPERATING DATA REPORT**

DOCKET NO. 50-325
UNIT NAME Brunswick Steam Electric Plant, Unit No. 1
DATE November 8, 1999
COMPLETED BY Kester Thompson
TELEPHONE (910) 457-2754

REPORTING PERIOD

October 1999

(Month/Year)

	MONTH	YEAR TO DATE	CUMULATIVE
1. Design Electrical Rating: (MWe-Net)	867	N/A	N/A
2. Maximum Dependable Capacity: (MWe-Net).	820	N/A	N/A
3. Number of Hours the Reactor Was Critical:	745	7,113	134,625
4. Number of Hours the Generator Was On Line:	745	7,060	130,273
5. Unit Reserve Shutdown Hours:	0	0	0
6. Net Electrical Energy (MWH):	625,787	5,812,244	94,114,582

**APPENDIX B
UNIT SHUTDOWNS**

DOCKET NO. 50-325
 UNIT NAME Brunswick Steam Electric Plant, Unit No. 1
 DATE November 8, 1999
 COMPLETED BY Kester Thompson
 TELEPHONE (910) 457-2754

REPORTING PERIOD October 1999
(Month/Year)

NO.	DATE	TYPE F: FORCED S: SCHEDULED	DURATION (HOURS)	REASON (1)	METHOD OF SHUTTING DOWN (2)	CAUSE/CORRECTIVE ACTIONS COMMENTS
N/A						Unit No. 1 was not required to shut down during the month of October 1999.

SUMMARY:

(1) Reason

- A - Equipment Failure (Explain)
- B - Maintenance or Test
- C - Refueling
- D - Regulatory Restriction
- E - Operator Training/License Examination
- F - Administrative
- G - Operational Error (Explain)
- H - Other (Explain)

(2) Method

- 1 - Manual
- 2 - Manual Trip/Scram
- 3 - Automatic Trip/Scram
- 4 - Continuation
- 5 - Other (Explain)

ENCLOSURE 2

BRUNSWICK STEAM ELECTRIC PLANT, UNIT NOS. 1 AND 2
DOCKET NOS. 50-325 AND 50-324 / LICENSE NOS. DPR-71 AND DPR-62

BRUNSWICK STEAM ELECTRIC PLANT, UNIT NO. 2
MONTHLY OPERATING REPORT
OCTOBER 1999

**APPENDIX A
OPERATING DATA REPORT**

DOCKET NO. 50-324
UNIT NAME Brunswick Steam Electric Plant, Unit No. 2
DATE November 8, 1999
COMPLETED BY Kester Thompson
TELEPHONE (910) 457-2754

REPORTING PERIOD October 1999
(Month/Year)

	MONTH	YEAR TO DATE	CUMULATIVE
1. Design Electrical Rating: (MWe-Net)	867	N/A	N/A
2. Maximum Dependable Capacity: (MWe-Net).	811	N/A	N/A
3. Number of Hours the Reactor Was Critical:	745	6,252	143,534
4. Number of Hours the Generator Was On Line:	745	6,112	137,626
5. Unit Reserve Shutdown Hours:	0	0	0
6. Net Electrical Energy (MWH):	614,744	4,883,359	95,139,549

**APPENDIX B
UNIT SHUTDOWNS**

DOCKET NO. 50-324
 UNIT NAME Brunswick Steam Electric Plant, Unit No. 2
 DATE November 8, 1999
 COMPLETED BY Kester Thompson
 TELEPHONE (910) 457-2754

REPORTING PERIOD October 1999
(Month/Year)

NO.	DATE	TYPE F: FORCED S: SCHEDULED	DURATION (HOURS)	REASON (1)	METHOD OF SHUTTING DOWN (2)	CAUSE/CORRECTIVE ACTIONS COMMENTS
N/A						Unit No. 2 was not required to shut down during the month of October 1999.

SUMMARY:

(1) Reason

- A - Equipment Failure (Explain)
- B - Maintenance or Test
- C - Refueling
- D - Regulatory Restriction
- E - Operator Training/License Examination
- F - Administrative
- G - Operational Error (Explain)
- H - Other (Explain)

(2) Method

- 1 - Manual
- 2 - Manual Trip/Scram
- 3 - Automatic Trip/Scram
- 4 - Continuation
- 5 - Other (Explain)