

November 15, 1999

U.S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Washington, DC 20555-0001

DOCKET 50-255 - LICENSE DPR-20 - PALISADES PLANT
1999 STEAM GENERATOR TUBE SURVEILLANCE REPORT - TUBES PLUGGED


Palisades Technical Specification 6.6.9a requires that the number of tubes plugged in each steam generator shall be reported to the NRC within fifteen days following the completion of an inservice inspection of steam generator tubes. On November 10, 1999, an inservice inspection of the Palisades steam generator tubes was completed.

Five tubes were plugged in Steam Generator E-50A and twelve tubes were plugged in Steam Generator E-50B. The total number of tubes plugged in Steam Generator E-50A is 326. The total number of tubes plugged in Steam Generator E-50B is 324.

In accordance with Palisades Technical Specification 6.6.9b, a complete steam generator inservice inspection report will be submitted within 12 months.

SUMMARY OF COMMITMENTS

This letter contains no new commitments and no revisions to existing commitments.


Nathan L. Haskell
Director, Licensing

CC Administrator, Region III, USNRC
Project Manager, NRR, USNRC
NRC Resident Inspector - Palisades

AC01

PAU ADDITIONAL 0500265