

UNITED STATES NUCLEAR REGULATORY COMMISSION

WASHINGTON, D.C. 20555-0001

FLORIDA POWER AND LIGHT COMPANY

DOCKET NO. 50-250

TURKEY POINT PLANT UNIT NO. 3

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 202 License No. DPR-31

- 1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment by Florida Power and Light Company (the licensee) dated July 27, 1999, as supplemented October 4, 1999, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act) and the Commission's rules and regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.

- 2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment, and paragraph 3.B of Facility Operating License No. DPR-31 is hereby amended to read as follows:
 - (B) Technical Specifications and Environmental Protection Plan

The Technical Specifications contained in Appendix A, as revised through Amendment No. 202, are hereby incorporated in the license. The Environmental Protection Plan contained in Appendix B is hereby incorporated into the license. The licensee shall operate the facility in accordance with the Technical Specifications and the Environmental Protection Plan.

2. This license amendment is effective as of its date of issuance and shall be implemented prior to April 2000.

FOR THE NUCLEAR REGULATORY COMMISSION

Herbert N. Berkow, Director

Project Directorate II Division of Licensing Project Management Office of Nuclear Reactor Regulation

Attachment: Changes to the Technical Specifications

Date of Issuance: November 19, 1999



UNITED STATES NUCLEAR REGULATORY COMMISSION

WASHINGTON, D.C. 20555-0001

FLORIDA POWER AND LIGHT COMPANY

DOCKET NO. 50-251

TURKEY POINT PLANT UNIT NO. 4

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 196 License No. DPR-41

- 1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment by Florida Power and Light Company (the licensee) dated July 27, 1999, as supplemented October 4, 1999, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act) and the Commission's rules and regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.

- 2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment, and paragraph 3.B of Facility Operating License No. DPR-41 is hereby amended to read as follows:
 - (B) <u>Technical Specifications and Environmental Protection Plan</u>

The Technical Specifications contained in Appendix A, as revised through Amendment No. 196, are hereby incorporated in the license. The Environmental Protection Plan contained in Appendix B is hereby incorporated into the license. The licensee shall operate the facility in accordance with the Technical Specifications and the Environmental Protection Plan.

3. This license amendment is effective as of its date of issuance and shall be implemented prior to April 2000.

FOR THE NUCLEAR REGULATORY COMMISSION

Herbert N. Berkow, Director Project Directorate II Division of Licensing Project Management Office of Nuclear Reactor Regulation

Attachment: Changes to the Technical Specifications

Date of Issuance: November 19, 1999

ATTACHMENT TO LICENSE AMENDMENT

AMENDMENT NO. 202 FACILITY OPERATING LICENSE NO. DPR-31

AMENDMENT NO. 196 FACILITY OPERATING LICENSE NO. DPR-41

DOCKET NOS. 50-250 AND 50-251

Replace the following pages of the Appendix A Technical Specifications with the attached pages. The revised pages are identified by amendment number and contain marginal lines indicating the area of change.

Remove pages	Insert pages
3/4 4-9	3/4 4-9
3/4 5-4	3/4 5-4
3/4 8-2	3/4 8-2
3/4 8-4	3/4 8-4
	3/4 8-4a

REACTOR COOLANT SYSTEM

3/4.4.3 PRESSURIZER

LIMITING CONDITION FOR OPERATION

3.4.3 The pressurizer shall be OPERABLE with a water volume of less than or equal to 92% of indicated level, and at least two groups of pressurizer heaters each having a capacity of at least 125 kW and capable of being supplied by emergency power.

APPLICABILITY: MODES 1, 2, and 3.

ACTION:

With only one group of pressurizer heaters OPERABLE, restore at least a. two groups to OPERABLE status within 72 hours** or be in at least HOT STANDBY within the next 6 hours and in HOT SHUTDOWN within the following 6 hours.

1

With the pressurizer otherwise inoperable, be in at least HOT STANDBY b. with the Reactor Trip System breakers open within 6 hours and in HOT SHUTDOWN within the following 6 hours.

SURVEILLANCE REQUIREMENTS

4.4.3.1 The pressurizer water volume shall be determined to be within its limit at least once per 12 hours.

4.4.3.2 The capacity of each of the above required groups of pressurizer heaters shall be verified by energizing the heaters and measuring circuit current at least once per 92 days.

7 days if the inoperability is associated with an inoperable Unit 3 ** diesel generator removed from service for radiator replacement prior to April 2000.

TURKEY POINT - UNITS 3 & 4

EMERGENCY CORE COOLING SYSTEMS

3/4.5.2 ECCS SUBSYSTEMS - T_{avg} GREATER THAN OR EQUAL TO 350°F

LIMITING CONDITION FOR OPERATION

- d. With two of the four required Safety Injection pumps inoperable and the opposite unit in MODE 1, 2, or 3, restore one of the two inoperable pumps to OPERABLE status within 72 hours or be in at least HOT STANDBY within the next 12 hours and in HOT SHUTDOWN within the following 6 hours. This ACTION applies to both units simultaneously.
- e. With one of the three required Safety Injection pumps inoperable and the opposite unit in MODE 4, 5, or 6, restore the pump to OPERABLE status within 72 hours or be in at least HOT STANDBY within the next 6 hours and in HOT SHUTDOWN within the following 6 hours.
- f. With a required Safety Injection pump OPERABLE but not capable of being powered from its associated diesel generator, restore the capability within 72 hours** or be in at least HOT STANDBY within the next 6 hours and in HOT SHUTDOWN within the following 6 hours.

** 7 days for a Unit 3 diesel generator if the loss of capability is associated with replacement of the engine radiators prior to April 2000.

TURKEY POINT - UNITS 3 & 4

3/4 5-4

AMENDMENT NOS. 202 AND 196

ELECTRICAL POWER SYSTEMS

LIMITING CONDITION FOR OPERATION (Continued)

APPLICABILITY: MODES 1, 2, 3, and 4.

ACTION:

- With one of two startup transformers or an associated circuit inoperable. a. demonstrate the OPERABILITY of the other startup transformer and its associated circuits by performing Surveillance Requirement 4.8.1.1.1.a within 1 hour and at least once per 8 hours thereafter. If the inoperable startup transformer is the associated startup transformer and became inoperable while the unit is in MODE 1, reduce THERMAL POWER to \leq 30% RATED THERMAL POWER within 24 hours, or restore the inoperable startup transformer and associated circuits to OPERABLE status within the next 48 hours or be in at least HOT STANDBY within the next 6 hours and in COLD SHUTDOWN within the following 30 hours. If THERMAL POWER is reduced to \leq 30% RATED THERMAL POWER within 24 hours or if the inoperable startup transformer is associated with the opposite unit restore the startup transformer and its associated circuits to OPERABLE status within 30 days of the loss of OPERABILITY, or be in at least HOT STANDBY within the next 12 hours and in COLD SHUTDOWN within the following 30 hours. If the inoperable startup transformer is the associated startup transformer and became inoperable while the unit was in MODE 2, 3, or 4 restore the startup transformer and its associated circuits to OPERABLE status within 24 hours or be in at least HOT STANDBY within 6 hours and in COLD SHUTDOWN within the following 30 hours. This ACTION applies to both units simultaneously.
- b. With one of the required diesel generators inoperable, demonstrate the OPERABILITY of the above required startup transformers and their associated circuits by performing Surveillance Requirement 4.8.1.1.1.a within 1 hour and at least once per 8 hours thereafter. If the diesel generator became inoperable due to any cause other than an inoperable support system, an independently testable component, or preplanned preventative maintenance or testing, demonstrate the OPERABILITY of the remaining required diesel generators by performing Surveillance Requirement 4.8.1.1.2.a.4 within 24 hours, unless the absence of any potential common mode failure for the remaining diesel generators is determined. If testing of remaining required diesel generators is required, this testing must be performed regardless of when the inoperable diesel generator is restored to OPERABILITY. Restore the inoperable diesel generator to OPERABLE status within 72 hours** or be in at least HOT STANDBY within the next 6 hours and in COLD SHUTDOWN within the following 30 hours.
- c. With one startup transformer and one of the required diesel generators inoperable, demonstrate the OPERABILITY of the remaining A.C. sources by performing Surveillance Requirement 4.8.1.1.1.a on the remaining

** 7 days for a Unit 3 diesel generator if the inoperability is associated with replacement of the engine radiators prior to April 2000.

TURKEY POINT - UNITS 3 & 4

1

ELECTRICAL POWER SYSTEMS

LIMITING CONDITION FOR OPERATION (Continued)

ACTION (Continued)

SHUTDOWN within the following 30 hours. This ACTION applies to both units simultaneously. With only one startup transformer and associated circuits restored, perform Surveillance Requirement 4.8.1.1.1a on the OPERABLE Startup transformer at least once per 8 hours, and restore the other startup transformer and its associated circuits to OPERABLE status or shutdown in accordance with the provisions of Action Statement 3.8.1.1a with time requirements of that Action Statement based on the time of initial loss of a startup transformer. This ACTION applies to both units simultaneously.

- f. With two of the above required diesel generators inoperable, demonstrate the OPERABILITY of two startup transformers and their associated circuits by performing the requirements of Specification 4.8.1.1.1a. within 1 hour and at least once per 8 hours thereafter; restore at least one of the inoperable diesel generators to OPERABLE status within 2 hours or be in at least HOT STANDBY within the next 6 hours and in COLD SHUTDOWN within the following 30 hours. Restore all required diesel generators to OPERABLE status within 72 hours** from time of initial loss or be in at least HOT STANDBY within the next 6 hours and in COLD SHUTDOWN within the following 30 hours.
- g. Following the addition of the new fuel oil* to the Diesel Fuel Oil Storage Tanks, with one or more diesel generators with new fuel oil properties outside the required Diesel Fuel Oil Testing Program limits, restore the stored fuel oil properties to within the required limits within 30 days.
- h. With one or more diesel generators with stored fuel oil total particulates outside the required Diesel Fuel Oil Testing Program limits, restore the fuel oil total particulates to within the required limits within 7 days.

** 7 days for a Unit 3 diesel generator if the inoperability is associated with replacement of the engine radiators prior to April 2000.

TURKEY POINT - UNITS 3 & 4

3/4 8-4

^{*} The properties of API Gravity, specific gravity or an absolute specific gravity; kinematic viscosity; clear and bright appearance; and flash point shall be confirmed to be within the Diesel Fuel Oil Testing Program limits, prior to the addition of the new fuel oil to the Diesel Fuel Oil Storage Tanks.

ELECTRICAL POWER SYSTEMS

SURVEILLANCE REQUIREMENTS

4.8.1.1.1 Each of the above required startup transformers and their associated circuits shall be:

- a. Determined OPERABLE at least once per 7 days by verifying correct breaker alignments, indicated power availability, and
- b. Demonstrated OPERABLE at least once per 18 months while shutting down, by transferring manually unit power supply from the auxiliary transformer to the startup transformer.