

November 22, 1999

Mr. Robert J. Wanczyk
Acting Director of Operations
Vermont Yankee Nuclear Power Corporation
185 Old Ferry Road
Brattleboro, VT 05301

SUBJECT: VERMONT YANKEE NUCLEAR POWER STATION - ISSUANCE OF
AMENDMENT RE: DIESEL FUEL OIL STORAGE TANK MINIMUM VOLUME
(TAC NO. MA6534)

Dear Mr. Wanczyk:

The Commission has issued the enclosed Amendment No. 180 to Facility Operating License DPR-28 for the Vermont Yankee Nuclear Power Station, in response to your application dated September 21, 1999.

The amendment increases the required volume of stored fuel in the diesel fuel oil storage tank as a result of a conservative recalculation of diesel generator fuel consumption.

A copy of the related Safety Evaluation is also enclosed. Notice of Issuance will be included in the Commission's biweekly Federal Register notice.

Sincerely,

/s/
Richard P. Croteau, Project Manager, Section 2
Project Directorate I
Division of Licensing Project Management
Office of Nuclear Reactor Regulation

Docket No. 50-271

- Enclosures: 1. Amendment No.180 to License No. DPR-28
2. Safety Evaluation

cc w/ encls: See next page

DISTRIBUTION

Docket File PUBLIC PDI-2 Reading EAdensam(e-mail EGA1) J. Clifford
R. Croteau W. Beckner T. Clark R. Scholl (Email SE to RFS) OGC
G. Hill (2) G. Hubbard ACRS C. Anderson, R-I

DOCUMENT NAME: G:\PDI-2\Vermont\amda6534.wpd *see previous concurrence

To receive a copy of this document, indicate in the box: "C" = Copy without attachment/enclosure "E" = Copy with attachment/enclosure "N" = No copy

OFFICE	PDI-2/PM	<input checked="" type="checkbox"/>	PDI-2/LA	<input checked="" type="checkbox"/>		SPLB	<input checked="" type="checkbox"/>	E	OGC HLD		PDI-2/SC	
NAME	RPCroteau	<input checked="" type="checkbox"/>	TLClark	<input checked="" type="checkbox"/>		JHannon	<input checked="" type="checkbox"/>		C. Marco		JClifford	
DATE	10/17/99		10/17/99		1/199	10/17/99			10/25/99		10/30/99	

OFFICIAL RECORD COPY

PDR ADock

ARC FILE CENTER COPY

DF01



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555-0001

November 22, 1999

Mr. Robert J. Wanczyk
Acting Director of Operations
Vermont Yankee Nuclear Power Corporation
185 Old Ferry Road
Brattleboro, VT 05301

SUBJECT: VERMONT YANKEE NUCLEAR POWER STATION - ISSUANCE OF
AMENDMENT RE: DIESEL FUEL OIL STORAGE TANK MINIMUM VOLUME
(TAC NO. MA6534)

Dear Mr. Wanczyk:

The Commission has issued the enclosed Amendment No. 180 to Facility Operating License DPR-28 for the Vermont Yankee Nuclear Power Station, in response to your application dated September 21, 1999.

The amendment increases the required volume of stored fuel in the diesel fuel oil storage tank as a result of a conservative recalculation of diesel generator fuel consumption.

A copy of the related Safety Evaluation is also enclosed. Notice of Issuance will be included in the Commission's biweekly Federal Register notice.

Sincerely,

A handwritten signature in cursive script, appearing to read "R. Croteau", with a long horizontal line extending to the right.

Richard P. Croteau, Project Manager, Section 2
Project Directorate I
Division of Licensing Project Management
Office of Nuclear Reactor Regulation

Docket No. 50-271

Enclosures: 1. Amendment No. 180 to
License No. DPR-28
2. Safety Evaluation

cc w/ encls: See next page

Vermont Yankee Nuclear Power Station

cc:

Regional Administrator, Region I
U. S. Nuclear Regulatory Commission
475 Allendale Road
King of Prussia, PA 19406

Mr. David R. Lewis
Shaw, Pittman, Potts & Trowbridge
2300 N Street, N.W.
Washington, DC 20037-1128

Mr. Richard P. Sedano, Commissioner
Vermont Department of Public Service
112 State Street
Montpelier, VT 05620-2601

Mr. Michael H. Dworkin, Chairman
Public Service Board
State of Vermont
112 State Street
Montpelier, VT 05620-2701

Chairman, Board of Selectmen
Town of Vernon
P.O. Box 116
Vernon, VT 05354-0116

Mr. Richard E. McCullough
Operating Experience Coordinator
Vermont Yankee Nuclear Power Station
P.O. Box 157
Governor Hunt Road
Vernon, VT 05354

G. Dana Bisbee, Esq.
Deputy Attorney General
33 Capitol Street
Concord, NH 03301-6937

Chief, Safety Unit
Office of the Attorney General
One Ashburton Place, 19th Floor
Boston, MA 02108

Ms. Deborah B. Katz
Box 83
Shelburne Falls, MA 01370

Mr. Raymond N. McCandless
Vermont Department of Health
Division of Occupational
and Radiological Health
108 Cherry Street
Burlington, VT 05402

Mr. Gautam Sen
Licensing Manager
Vermont Yankee Nuclear Power
Corporation
185 Old Ferry Road
Brattleboro, VT 05301

Resident Inspector
Vermont Yankee Nuclear Power Station
U. S. Nuclear Regulatory Commission
P.O. Box 176
Vernon, VT 05354

Director, Massachusetts Emergency
Management Agency
ATTN: James Muckerheide
400 Worcester Rd.
P.O. Box 1496
Framingham, MA 01701-0317

Jonathan M. Block, Esq.
Main Street
P. O. Box 566
Putney, VT 05346-0566