

Dave Morey
Vice President
Farley Project

Southern Nuclear
Operating Company
P.O. Box 1295
Birmingham, Alabama 35201
Tel 205.992.5131



Energy to Serve Your WorldSM

NEL-99-0411

November 22, 1999

Docket No. 50-364

U. S. Nuclear Regulatory Commission
ATTN.: Document Control Desk
Washington, DC 20555-0001

Joseph M. Farley Nuclear Plant – Unit 2
Steam Generator Plugging 15-Day Report

Ladies and Gentlemen:

In accordance with Technical Specification 3/4.4.6 reporting requirement 4.4.6.5.a, a report documenting the number of tubes plugged, repaired or designated F* in each Steam Generator (S/G) must be submitted to the NRC within 15 days of the completion of the inspection, plugging or repair effort. The inspection and plugging effort was completed on November 13, 1999. This letter provides the plugging and F* inspection results of the S/G inservice inspection performed during the Farley Unit 2 13th Refueling Outage. No tubes were repaired by sleeving during this outage.

Tube Category	S/G A	S/G B	S/G C
Tubes Removed from Service by Plugging	100	99	126
Tubes Designated as F* Tubes	37	102	219

There are no NRC commitments associated with this letter.

If there are any questions, please advise.

Respectfully submitted,


Dave Morey

WAS/maf:sgplugging.doc

A001

PDR A0001 0500364

Page 2

U. S. Nuclear Regulatory Commission

**cc: Southern Nuclear Operating Company
Mr. L. M. Stinson, General Manager – Farley**

**U. S. Nuclear Regulatory Commission, Washington, D. C.
Mr. L. M. Padovan, Licensing Project Manager – Farley**

**U. S. Nuclear Regulatory Commission, Region II
Mr. L. A. Reyes, Regional Administrator
Mr. T. P. Johnson, Senior Resident Inspector – Farley**