



UNITED STATES  
NUCLEAR REGULATORY COMMISSION

WASHINGTON, D.C. 20555-0001

November 19, 1999

Mr. R.P. Necci - Vice President  
Nuclear Oversight and Regulatory Affairs  
Northeast Nuclear Energy Company  
c/o Mr. David A. Smith  
P.O. Box 128  
Waterford, CT 06385

SUBJECT: COMPLETION OF LICENSING ACTION FOR GENERIC LETTER 98-04,  
"POTENTIAL FOR DEGRADATION OF THE EMERGENCY CORE COOLING  
SYSTEM AND THE CONTAINMENT SPRAY SYSTEM AFTER A LOSS-OF-  
COOLANT ACCIDENT BECAUSE OF CONSTRUCTION AND PROTECTIVE  
COATING DEFICIENCIES AND FOREIGN MATERIAL IN CONTAINMENT,"  
DATED JULY 14, 1998; MILLSTONE NUCLEAR POWER STATION, UNIT 2,  
(TAC NO. MA4067)

Dear Mr. Necci:

On July 14, 1998, the U.S. Nuclear Regulatory Commission (NRC) issued Generic Letter (GL) 98-04, "Potential for Degradation of the Emergency Core Cooling System and the Containment Spray System After a Loss-of-Coolant Accident Because of Construction and Protective Coating Deficiencies and Foreign Material in Containment," to all holders of operating licenses or construction permits. The NRC issued GL 98-04 to determine the status of containment coating programs.

In GL 98-04, the NRC staff specifically requested that the licensees provide information outlined below for each of their facilities.

- (1) A summary description of the plant-specific program or programs implemented to ensure that Service Level 1 protective coatings used inside the containment are procured, applied, and maintained in compliance with applicable regulatory requirements and the plant-specific licensing basis for the facility. Include a discussion of how the plant-specific program meets the applicable criteria of 10 CFR Part 50, Appendix B, as well as information regarding any applicable standards, plant-specific procedures or other guidance used for (a) controlling the procurement of coatings and paints used at the facility; (b) the qualification testing of protective coatings; and (c) surface preparation, application, surveillance, and maintenance activities for protective coatings. Maintenance activities refer to rework of degraded coatings, removing degraded coatings to sound coatings, correctly preparing the surfaces, applying new coating, and verifying the quality of coatings.

NRC FILE CENTER COPY

DF01

PDR ADOCK

(2) Information demonstrating compliance with item (i) or item (ii).

- (i) For plants with licensing-basis requirements for tracking the amount of unqualified coatings inside the containment and for assessing the impact of potential coating debris on the operation of safety-related systems, structures, and components (SSCs) during a postulated design basis loss-of-coolant accident (DBLOCA), the following information shall be provided to demonstrate compliance:
  - (a) The date and findings of the last assessment of coatings and the planned date of the next assessment of coatings.
  - (b) The limit for the amount of unqualified protective coatings allowed in the containment and how this limit is determined. Discuss any conservatism in the method used to determine this limit.
  - (c) If a commercial-grade dedication program is being used at your facility for dedicating commercial-grade coatings for Service Level 1 applications inside the containment, discuss how the program adequately qualifies a coating for Service Level 1. Identify what standards or other guidance are currently being used to dedicate containment coatings at your facility.
- (ii) For plants without the above licensing-basis requirements, information shall be provided to demonstrate compliance with the requirements of 10 CFR 50.46b(5), "Long-term cooling" and the functional capability of the safety-related containment spray system as set forth in your licensing basis. If a licensee can demonstrate this compliance without quantifying the amount of unqualified coatings, this is acceptable. The following information shall be provided:

If a commercial-grade dedication program is not being used at your facility for qualifying and dedicating commercial-grade coatings for Service Level 1 applications, provide the regulatory and safety basis for not controlling these coatings in accordance with such a program. Additionally, explain why the facility's licensing basis does not require such a program.


In response to GL 98-04, you provided a letter dated November 12, 1998, for Millstone Nuclear Power Station, Unit 2. This submittal provided the information requested by GL 98-04. Clarification was provided during a phone call that took place on September 29, 1999. The staff has reviewed your response and has concluded that all requested information has been provided; therefore, we consider GL 98-04 to be closed for your facility. We thank you for your prompt and complete response.

Mr. R. P. Necci

- 3 -

This letter closes TAC No. MA4067. If you have any questions regarding this matter, please contact me at (301) 415-3041.

Sincerely,

A handwritten signature in black ink, appearing to read "Ronald B. Eaton", with a long horizontal stroke extending to the right.

Ronald B. Eaton, Sr. Project Manager, Section 2  
Project Directorate I  
Division of Licensing Project Management  
Office of Nuclear Reactor Regulation

Docket No. 50-336

cc: See next page

Mr. R. P. Necci

- 3 -

This letter closes TAC No. MA4067. If you have any questions regarding this matter, please contact me at (301) 415-3041.

Sincerely,

ORIGINAL SIGNED BY:

Ronald B. Eaton, Sr. Project Manager, Section 2  
Project Directorate I  
Division of Licensing Project Management  
Office of Nuclear Reactor Regulation

Docket No. 50-336

cc: See next page

DISTRIBUTION:

File Center	PUBLIC
PD1-2 Reading	DLew, RI
EAdensam (EGA1)	JClifford
TClark	REaton
RPulsifer	OGC
CLauron	ACRS
JDavis	JLinville, RI

DOCUMENT NAME: G:\PDI-2\Millstone2\LTRMA4067.wpd

To receive a copy of this document, indicate in the box: "C" = Copy without attachment/enclosure "E" = Copy with attachment/enclosure "N" = No copy

OFFICE	PM:PDI-2	LA:PDI-2	<input checked="" type="checkbox"/>	SC:EMCB	SC:PDI-2	<input checked="" type="checkbox"/>	
NAME	REaton:pmm	TClark <i>JTC</i>		ESullivan <i>ES</i>	JClifford <i>JM for</i>		
DATE	11/1/99	11/12/99		11/6/99	11/1/99		

OFFICIAL DOCUMENT COPY

Millstone Nuclear Power Station  
Unit 2

cc:

Ms. L. M. Cuoco  
Senior Nuclear Counsel  
Northeast Utilities Service Company  
P. O. Box 270  
Hartford, CT 06141-0270

Edward L. Wilds, Jr., Ph.D.  
Director, Division of Radiation  
Department of Environmental Protection  
79 Elm Street  
Hartford, CT 06106-5127

Regional Administrator, Region I  
U.S. Nuclear Regulatory Commission  
475 Allendale Road  
King of Prussia, PA 19406

First Selectmen  
Town of Waterford  
15 Rope Ferry Road  
Waterford, CT 06385

Charles Brinkman, Manager  
Washington Nuclear Operations  
ABB Combustion Engineering  
12300 Twinbrook Pkwy, Suite 330  
Rockville, MD 20852

Senior Resident Inspector  
Millstone Nuclear Power Station  
c/o U.S. Nuclear Regulatory Commission  
P.O. Box 513  
Niantic, CT 06357

Mr. F. C. Rothen  
Vice President - Nuclear Operations  
Northeast Nuclear Energy Company  
P. O. Box 128  
Waterford, CT 06385

Ernest C. Hadley, Esquire  
1040 B Main Street  
P.O. Box 549  
West Wareham, MA 02576

Mr. J. T. Carlin  
Vice President - Human Services  
Northeast Nuclear Energy Company  
P. O. Box 128  
Waterford, CT 06385

Mr. Allan Johanson, Assistant Director  
Office of Policy and Management  
Policy Development and Planning  
Division  
450 Capitol Avenue - MS# 52ERN  
P. O. Box 341441  
Hartford, CT 06134-1441

Mr. M. H. Brothers  
Vice President - Nuclear Operations  
Northeast Nuclear Energy Company  
P.O. Box 128  
Waterford, CT 06385

Mr. L. J. Olivier  
Senior Vice President and Chief  
Nuclear Officer - Millstone  
Northeast Nuclear Energy Company  
P.O. Box 128  
Waterford, CT 06385

Mr. C. J. Schwarz  
Station Director  
Northeast Nuclear Energy Company  
P.O. Box 128  
Waterford, CT 06385

Mr. B. D. Kenyon  
President and CEO - NNECO  
Northeast Nuclear Energy Company  
P.O. Box 128  
Waterford, CT 06385

Millstone Nuclear Power Station  
Unit 2

cc:

Citizens Regulatory Commission  
ATTN: Ms. Geri Winslow  
P. O. Box 199  
Waterford, CT 06385

Deborah Katz, President  
Citizens Awareness Network  
P. O. Box 83  
Shelburne Falls, MA 03170

Ms. Terry Concannon  
Co-Chair  
Nuclear Energy Advisory Council  
415 Buckboard Lane  
Marlboro, CT 06447

Mr. Evan W. Woollacott  
Co-Chair  
Nuclear Energy Advisory Council  
128 Terry's Plain Road  
Simsbury, CT 06070

Little Harbor Consultants, Inc.  
Millstone - ITPOP Project Office  
P. O. Box 0630  
Niantic, CT 06357-0630

Attorney Nicholas J. Scobbo, Jr.  
Ferriter, Scobbo, Caruso, Rodophele, PC  
75 State Street, 7th Floor  
Boston, MA 02108-1807

Mr. D. B. Amerine  
Vice President - Engineering Services  
Northeast Nuclear Energy Company  
P. O. Box 128  
Waterford, CT 06385

Mr. D. A. Smith  
Manager - Regulatory Affairs  
Northeast Nuclear Energy Company  
P. O. Box 128  
Waterford, CT 06385

Ms. Nancy Burton  
147 Cross Highway  
Redding Ridge, CT 00870

Mr. G. D. Hicks  
Director - Nuclear Training Services  
Northeast Nuclear Energy Company  
P.O. Box 128  
Waterford, CT 06385