

Mr. Harold B. Ray  
 Executive Vice President  
 Southern California Edison Company  
 San Onofre Nuclear Generating Station  
 P.O. Box 128  
 San Clemente, CA 92674-0128

November 15, 1999

SUBJECT: SAN ONOFRE NUCLEAR GENERATING STATION (SONGS), UNITS 2 AND 3 -  
 ISSUANCE OF AMENDMENTS RE: RESPONSE TIME TESTING  
 REQUIREMENT FOR THE CONTROL ROOM ISOLATION SIGNAL  
 (TAC NOS. MA4124 AND MA4125)

Dear Mr. Ray:

The Commission has issued the enclosed Amendment No. 160 to Facility Operating License No. NPF-10 and Amendment No. 151 to Facility Operating License No. NPF-15 for San Onofre Nuclear Generating Station, Units 2 and 3, respectively. These amendments are in response to your application dated October 20, 1998 (PCN 485), as supplemented August 13, 1999. These amendments add a response time testing requirement for the control room isolation signal.

A copy of our related Safety Evaluation is enclosed. The Notice of Issuance will be included in the Commission's next biweekly *Federal Register* notice.

Sincerely,

Original Signed By:  
 L. Raghavan, Senior Project Manager, Section 2  
 Project Directorate IV & Decommissioning  
 Division of Licensing Project Management  
 Office of Nuclear Reactor Regulation

Docket Nos. 50-361 and 50-362

- Enclosures: 1. Amendment No. 160 to NPF-10  
 2. Amendment No. 151 to NPF-15  
 3. Safety Evaluation

cc w/encls: See next page

DISTRIBUTION

|              |             |                               |
|--------------|-------------|-------------------------------|
| Docket File  | WBeckner    | SRichards (clo)               |
| PUBLIC       | LSmith, RIV | RScholl (email SE) PDIV-2 Rdg |
| LHurley, RIV | OGC         | JKilcrease, RIV ACRS          |
| GHill (4)    | PLoeser     |                               |

\* No significant changes to SE

19-217

| To receive a copy of this document, indicate "C" in the box |             |                                     |              |                                     |          |                                     |           |                                     |   |           |
|---|-------------|-------------------------------------|--------------|-------------------------------------|----------|-------------------------------------|-----------|-------------------------------------|---|-----------|
| OFFICE  | PDIV-2/PM   | <input checked="" type="checkbox"/> | PDIV-D/LA    | <input checked="" type="checkbox"/> | EEIB *   |                                     | SPSB      | <input checked="" type="checkbox"/> | OGC <input checked="" type="checkbox"/> | PDIV-2/SC |
| NAME  | LRaghavan   | <input checked="" type="checkbox"/> | CJamerson    | <input checked="" type="checkbox"/> | EMarinos | <input checked="" type="checkbox"/> | MReinhart | <input checked="" type="checkbox"/> | R Bachmann                              | SDembek   |
| DATE  | 11 / 1 / 99 |                                     | 10 / 15 / 99 |                                     | 09/15/99 |                                     | 10/25/99  |                                     | 10/28/99                                | 11/2/99   |

DOCUMENT NAME: G:\PDIV-2\SONGS\amd4124.wpd

OFFICIAL RECORD COPY

10/15

PDR A D O C K

DFol



UNITED STATES  
NUCLEAR REGULATORY COMMISSION

WASHINGTON, D.C. 20555-0001

November 15, 1999

Mr. Harold B. Ray  
Executive Vice President  
Southern California Edison Company  
San Onofre Nuclear Generating Station  
P.O. Box 128  
San Clemente, CA 92674-0128

SUBJECT: SAN ONOFRE NUCLEAR GENERATING STATION (SONGS), UNITS 2 AND 3 -  
ISSUANCE OF AMENDMENTS RE: RESPONSE TIME TESTING  
REQUIREMENT FOR THE CONTROL ROOM ISOLATION SIGNAL  
(TAC NOS. MA4124 AND MA4125)

Dear Mr. Ray:

The Commission has issued the enclosed Amendment No. 160 to Facility Operating License No. NPF-10 and Amendment No. 151 to Facility Operating License No. NPF-15 for San Onofre Nuclear Generating Station, Units 2 and 3, respectively. These amendments are in response to your application dated October 20, 1998 (PCN 485), as supplemented August 13, 1999. These amendments add a response time testing requirement for the control room isolation signal.

A copy of our related Safety Evaluation is enclosed. The Notice of Issuance will be included in the Commission's next biweekly *Federal Register* notice.

Sincerely,

A handwritten signature in black ink, appearing to read "L. Raghavan", with a long horizontal line extending to the right.

L. Raghavan, Senior Project Manager, Section 2  
Project Directorate IV & Decommissioning  
Division of Licensing Project Management  
Office of Nuclear Reactor Regulation

Docket Nos. 50-361 and 50-362

Enclosures: 1. Amendment No. 160 to NPF-10  
2. Amendment No. 151 to NPF-15  
3. Safety Evaluation

cc w/encls: See next page

San Onofre Nuclear Generating Station, Units 2 and 3

cc:

Mr. R. W. Krieger, Vice President  
Southern California Edison Company  
San Onofre Nuclear Generating Station  
P. O. Box 128  
San Clemente, CA 92674-0128

Chairman, Board of Supervisors  
County of San Diego  
1600 Pacific Highway, Room 335  
San Diego, CA 92101

Alan R. Watts, Esq.  
Woodruff, Spradlin & Smart  
701 S. Parker St. No. 7000  
Orange, CA 92668-4720

Mr. Sherwin Harris  
Resource Project Manager  
Public Utilities Department  
City of Riverside  
3900 Main Street  
Riverside, CA 92522

Regional Administrator, Region IV  
U.S. Nuclear Regulatory Commission  
Harris Tower & Pavilion  
611 Ryan Plaza Drive, Suite 400  
Arlington, TX 76011-8064

Mr. Michael Olson  
San Onofre Liaison  
San Diego Gas & Electric Company  
P.O. Box 1831  
San Diego, CA 92112-4150

Mr. Steve Hsu  
Radiologic Health Branch  
State Department of Health Services  
Post Office Box 942732  
Sacramento, CA 94234

Resident Inspector/San Onofre NPS  
c/o U.S. Nuclear Regulatory Commission  
Post Office Box 4329  
San Clemente, CA 92674

Mayor  
City of San Clemente  
100 Avenida Presidio  
San Clemente, CA 92672

Mr. Dwight E. Nunn, Vice President  
Southern California Edison Company  
San Onofre Nuclear Generating Station  
P.O. Box 128  
San Clemente, CA 92674-0128