



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D.C. 20555-0001

SOUTHERN CALIFORNIA EDISON COMPANY

SAN DIEGO GAS AND ELECTRIC COMPANY

THE CITY OF RIVERSIDE, CALIFORNIA

THE CITY OF ANAHEIM, CALIFORNIA

DOCKET NO. 50-361

SAN ONOFRE NUCLEAR GENERATING STATION, UNIT 2

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 160  
License No. NPF-10

1. The Nuclear Regulatory Commission (the Commission) has found that:
  - A. The application for amendment by Southern California Edison Company, et al. (SCE or the licensee), dated October 20, 1998, as supplemented August 13, 1999, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's regulations set forth in 10 CFR Chapter I;
  - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
  - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
  - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
  - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.

2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment, and paragraph 2.C(2) of Facility Operating License No. NPF-10 is hereby amended to read as follows:

- (2) Technical Specifications

The Technical Specifications contained in Appendix A and the Environmental Protection Plan contained in Appendix B, as revised through Amendment No. 160 , are hereby incorporated in the license. Southern California Edison Company shall operate the facility in accordance with the Technical Specifications and the Environmental Protection Plan.

3. This license amendment is effective as of the date of its issuance and shall be implemented within 30 days of its issuance.

FOR THE NUCLEAR REGULATORY COMMISSION



Stephen Dembek, Chief, Section 2  
Project Directorate IV & Decommissioning  
Division of Licensing Project Management  
Office of Nuclear Reactor Regulation

Attachment: Changes to the Technical  
Specifications

Date of Issuance: November 15, 1999

ATTACHMENT TO LICENSE AMENDMENT NO. 160

FACILITY OPERATING LICENSE NO. NPF-10

DOCKET NO. 50-361

Replace the following pages of the Appendix A Technical Specifications with the attached revised pages. The revised pages are identified by amendment number and contain marginal lines indicating the areas of change.

REMOVE

3.3-41

INSERT

3.3-41

SURVEILLANCE REQUIREMENTS (continued)

SURVEILLANCE	FREQUENCY
SR 3.3.9.2 Perform a CHANNEL FUNCTIONAL TEST on required CRIS airborne radiation monitor channel.  Verify CRIS high radiation setpoint is $\leq 4E2$ cpm above normal background.	92 days
SR 3.3.9.3 -----NOTE----- Surveillance of Actuation Logic shall include the verification of the proper operation of each initiation relay.  ----- Perform a CHANNEL FUNCTIONAL TEST on required CRIS Actuation Logic channel.	18 months
SR 3.3.9.4 Perform a CHANNEL CALIBRATION on required CRIS airborne radiation monitor channel.	18 months
SR 3.3.9.5 Perform a CHANNEL FUNCTIONAL TEST on required CRIS Manual Trip channel.	18 months
SR 3.3.9.6 Verify that response time of required CRIS channel is within limits.	18 months



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D.C. 20555-0001

SOUTHERN CALIFORNIA EDISON COMPANY

SAN DIEGO GAS AND ELECTRIC COMPANY

THE CITY OF RIVERSIDE, CALIFORNIA

THE CITY OF ANAHEIM, CALIFORNIA

DOCKET NO. 50-362

SAN ONOFRE NUCLEAR GENERATING STATION, UNIT 3

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 151  
License No. NPF-15

1. The Nuclear Regulatory Commission (the Commission) has found that:
  - A. The application for amendment by Southern California Edison Company, et al. (SCE or the licensee), dated October 20, 1998, as supplemented August 13, 1999, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's regulations set forth in 10 CFR Chapter I;
  - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
  - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
  - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
  - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.

2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment, and paragraph 2.C(2) of Facility Operating License No. NPF-15 is hereby amended to read as follows:

(2) Technical Specifications

The Technical Specifications contained in Appendix A and the Environmental Protection Plan contained in Appendix B, as revised through Amendment No. 151 , are hereby incorporated in the license. Southern California Edison Company shall operate the facility in accordance with the Technical Specifications and the Environmental Protection Plan.

3. This license amendment is effective as of the date of its issuance and shall be implemented within 30 days of its issuance.

FOR THE NUCLEAR REGULATORY COMMISSION



Stephen Dembek, Chief, Section 2  
Project Directorate IV & Decommissioning  
Division of Licensing Project Management  
Office of Nuclear Reactor Regulation

Attachment: Changes to the Technical  
Specifications

Date of Issuance: November 15, 1999

ATTACHMENT TO LICENSE AMENDMENT NO. 151

FACILITY OPERATING LICENSE NO. NPF-15

DOCKET NO. 50-362

Replace the following pages of the Appendix A Technical Specifications with the attached revised pages. The revised pages are identified by amendment number and contain marginal lines indicating the areas of change.

REMOVE

3.3-41

INSERT

3.3-41

SURVEILLANCE REQUIREMENTS (continued)

SURVEILLANCE		FREQUENCY
SR 3.3.9.2	<p>Perform a CHANNEL FUNCTIONAL TEST on required CRIS airborne radiation monitor channel.</p> <p>Verify CRIS high radiation setpoint is <math>\leq 4E2</math> cpm above normal background.</p>	92 days
SR 3.3.9.3	<p>-----NOTE----- Surveillance of Actuation Logic shall include the verification of the proper operation of each initiation relay. -----</p> <p>Perform a CHANNEL FUNCTIONAL TEST on required CRIS Actuation Logic channel.</p>	18 months
SR 3.3.9.4	<p>Perform a CHANNEL CALIBRATION on required CRIS airborne radiation monitor channel.</p>	18 months
SR 3.3.9.5	<p>Perform a CHANNEL FUNCTIONAL TEST on required CRIS Manual Trip channel.</p>	18 months
SR 3.3.9.6	<p>Verify that response time of required CRIS channel is within limits.</p>	18 months