



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555-0001

November 24, 1999

Mr. J. A. Scalice
Chief Nuclear Officer
and Executive Vice President
Tennessee Valley Authority
6A Lookout Place
1101 Market Street
Chattanooga, Tennessee 37402-2801

SUBJECT: COMPLETION OF LICENSING ACTIONS FOR GENERIC LETTER 98-04, "POTENTIAL FOR DEGRADATION OF THE EMERGENCY CORE COOLING SYSTEM AND THE CONTAINMENT SPRAY SYSTEM AFTER A LOSS-OF-COOLANT ACCIDENT BECAUSE OF CONSTRUCTION AND PROTECTIVE COATING DEFICIENCIES AND FOREIGN MATERIAL IN CONTAINMENT" - SEQUOYAH NUCLEAR PLANT, BROWNS FERRY NUCLEAR PLANT AND WATTS BAR NUCLEAR PLANT (TAC NOS. MA4021, MA4022, MA4023, MA4099, MA4100, MA4101)

Dear Mr. Scalice:

On July 14, 1998, the U.S. Nuclear Regulatory Commission (NRC) issued Generic Letter (GL) 98-04, "Potential for Degradation of the Emergency Core Cooling System and the Containment Spray System After a Loss-of-Coolant Accident Because of Construction and Protective Coating Deficiencies and Foreign Material in Containment," to all holders of operating licenses or construction permits. The NRC issued GL 98-04 to determine the status of containment coating programs. This generic activity was tracked as Multi-Plant Action L-804.

In GL 98-04, the NRC staff specifically requested that licensees provide information outlined below for each of their facilities.

- (1) A summary description of the plant-specific program or programs implemented to ensure that Service Level 1 protective coatings used inside the containment are procured, applied, and maintained in compliance with applicable regulatory requirements and the plant-specific licensing basis for the facility. Include a discussion of how the plant-specific program meets the applicable criteria of Title 10, Code of Federal Regulations, Part 50, Appendix B, as well as information regarding any applicable standards, plant-specific procedures or other guidance used for (a) controlling the procurement of coatings and paints used at the facility; (b) the qualification testing of protective coatings; and (c) surface preparation, application, surveillance, and maintenance activities for protective coatings. Maintenance activities refer to rework of degraded coatings, removing degraded coatings to sound coatings, correctly preparing the surfaces, applying new coating, and verifying the quality of coatings.

NRC FILE CENTER

PDR ADOCK

DF01

(2) Information demonstrating compliance with item (i) or item (ii).

- (i) For plants with licensing-basis requirements for tracking the amount of unqualified coatings inside the containment and for assessing the impact of potential coating debris on the operation of safety-related systems, structures, and components (SSCs) during a postulated design basis loss-of-coolant accident (DB LOCA), the following information shall be provided to demonstrate compliance:
- (a) The date and findings of the last assessment of coatings and the planned date of the next assessment of coatings.
 - (b) The limit for the amount of unqualified protective coatings allowed in the containment and how this limit is determined. Discuss any conservatism in the method used to determine this limit.
 - (c) If a commercial-grade dedication program is being used at your facility for dedicating commercial-grade coatings for Service Level 1 applications inside the containment, discuss how the program adequately qualifies a coating for Service Level 1. Identify what standards or other guidance are currently being used to dedicate containment coatings at your facility.
- (ii) For plants without the above licensing-basis requirements, information shall be provided to demonstrate compliance with the requirements of 10 CFR 50.46b(5), "Long-term cooling" and the functional capability of the safety-related containment spray system (CSS) as set forth in your licensing basis. If a licensee can demonstrate this compliance without quantifying the amount of unqualified coatings, this is acceptable. The following information shall be provided:

If a commercial-grade dedication program is not being used at your facility for qualifying and dedicating commercial-grade coatings for Service Level 1 applications, provide the regulatory and safety basis for not controlling these coatings in accordance with such a program. Additionally, explain why the facility's licensing basis does not require such a program.

In response to GL 98-04, you provided a letter dated November 10, 1998, for Sequoyah Nuclear Plant, Browns Ferry Nuclear Plant and Watts Bar Nuclear Plant. This submittal provided the information requested by GL 98-04. Clarification was provided regarding Sequoyah during a phone call that took place on June 21, 1999. The staff has reviewed your response and has concluded that all requested information has been provided; therefore, we consider GL 98-04 to be closed for your facilities. We thank you for your prompt and complete response. We also acknowledge your commitment to address GL 98-04 for Browns Ferry Unit 1 (which has not had the strainer upgrade), prior to restart of that unit.

November 24, 1999

If you have any questions regarding this matter, please contact Bill Long at 301-415-3026.

Sincerely,

Original signed by:

William O. Long, Senior Project Manager, Section 2
Project Directorate II
Division of Licensing Project Management
Office of Nuclear Reactor Regulation

Docket Nos. 50-259, 50-260, 50-296, 50-390, 50-327, and 50-358

cc: See next page

DISTRIBUTION:

- File Center
- PUBLIC
- PDII-2\SC (A)
- BFN R/F
- WLong
- RMartin
- RHeman
- BClayton
- RPulsifer
- CLauron
- JDavis
- OGC
- ACRS
- PFredrickson, RII

DOCUMENT NAME: G:\PDII-2\BFNL804_TVA.WPD

OFFICE	PDII-2:PM	PDII-2:LA	PDII-2:PM	PDII:PM
NAME	WLong	BClayton	RMartin	RHeman
DATE	11/10/99	11/18/99	11/15/99	11/22/99
OFFICE	EMCB:SC	PDII-2\SC (A)		
NAME	ESullivan	R. Corriea		
DATE	11/9/99	11/10/99	1/ /99	1/ /99


OFFICIAL RECORD COPY

J.A. Scalice

- 3 -

If you have any questions regarding this matter, please contact Bill Long at 301-415-3026.

Sincerely,



**William O. Long, Senior Project Manager, Section 2
Project Directorate II
Division of Licensing Project Management
Office of Nuclear Reactor Regulation**

Docket Nos. 50-259, 50-260, 50-296, 50-390, 50-327, and 50-328

cc: See next page

Mr. J. A. Scalice
Tennessee Valley Authority

BROWNS FERRY NUCLEAR PLANT

cc:

Mr. Karl W. Singer, Senior Vice President
Nuclear Operations
Tennessee Valley Authority
6A Lookout Place
1101 Market Street
Chattanooga, TN 37402-2801

Mr. Mark J. Burzynski, Manager
Nuclear Licensing
Tennessee Valley Authority
4X Blue Ridge
1101 Market Street
Chattanooga, TN 37402-2801

Mr. Jack A. Bailey, Vice President
Engineering & Technical Services
Tennessee Valley Authority
6A Lookout Place
1101 Market Street
Chattanooga, TN 37402-2801

Mr. Timothy E. Abney, Manager
Licensing and Industry Affairs
Browns Ferry Nuclear Plant
Tennessee Valley Authority
P.O. Box 2000
Decatur, AL 35609

Mr. John T. Herron, Site Vice President
Browns Ferry Nuclear Plant
Tennessee Valley Authority
P.O. Box 2000
Decatur, AL 35609

Senior Resident Inspector
U.S. Nuclear Regulatory Commission
Browns Ferry Nuclear Plant
10833 Shaw Road
Athens, AL 35611

General Counsel
Tennessee Valley Authority
ET 10H
400 West Summit Hill Drive
Knoxville, TN 37902

State Health Officer
Alabama Dept. of Public Health
RSA Tower - Administration
Suite 1552
P.O. Box 303017
Montgomery, AL 36130-3017

Mr. N. C. Kazanas, General Manager
Nuclear Assurance
Tennessee Valley Authority
5M Lookout Place
1101 Market Street
Chattanooga, TN 37402-2801

Chairman
Limestone County Commission
310 West Washington Street
Athens, AL 35611

Mr. Robert G. Jones, Plant Manager
Browns Ferry Nuclear Plant
Tennessee Valley Authority
P.O. Box 2000
Decatur, AL 35609