



**Carolina Power & Light Company**

Robinson Nuclear Plant  
3581 West Entrance Road  
Hartsville SC 29550

Serial: RNP-RA/99-0238

**NOV 24 1999**

United States Nuclear Regulatory Commission  
ATTN: Document Control Desk  
Washington, D.C. 20555

H. B. ROBINSON STEAM ELECTRIC PLANT, UNIT NO. 2  
DOCKET NO. 50-261/LICENSE NO. DPR-23

CORRECTION TO REVISED COMMITMENT TO NRC  
REPLACEMENT OF CONTAINMENT PURGE VALVE SEALS

Ladies and Gentlemen:

By letter dated October 12, 1999, Carolina Power & Light (CP&L) Company revised its commitment regarding the replacement of resilient seals on the containment purge and vent isolation valves for the H. B. Robinson Steam Electric Plant (HBRSEP), Unit No. 2. The letter stated, "The increased frequency for replacement of the resilient seals for the containment purge and vent valves is justifiable based on the suitability of the seal material for the application and the service life of the seals."

This statement is corrected to say, "The decreased frequency for replacement of the resilient seals for the containment purge and vent valves is justifiable based on the suitability of the seal material for the application and the service life of the seals."

If you have any questions on this subject, please contact Mr. H. K. Chernoff.

Sincerely,

R. L. Warden  
Manager - Regulatory Affairs

ALG/alg

c: L. A. Reyes, NRC, Region II  
R. Subbaratnam, NRC, NRR  
NRC Resident Inspector, HBRSEP

A034