

File Center



UNITED STATES  
NUCLEAR REGULATORY COMMISSION

WASHINGTON, D.C. 20555-0001

November 22, 1999

Mr. C. Lance Terry  
Senior Vice President  
& Principal Nuclear Officer  
TXU Electric  
Attn: Regulatory Affairs Department  
P. O. Box 1002  
Glen Rose, TX 76043

**SUBJECT: COMANCHE PEAK STEAM ELECTRIC STATION, UNITS 1 AND 2  
RE: GENERIC LETTER 97-01, "DEGRADATION OF CRDM/CEDM NOZZLE  
AND OTHER VESSEL CLOSURE HEAD PENETRATIONS"  
(TAC NOS. M98556 AND M98557)**

Dear Mr. Terry:

Enclosed is the U. S. Nuclear Regulatory Commission (NRC) staff's assessment of your letters dated May 1 and July 29, 1997, which provided your 30-day and 120-day responses to Generic Letter (GL) 97-01, and your letter dated February 11, 1999, which provided your response to the NRC staff's request for additional information (RAI) dated December 8, 1998, relative to the issuance of the GL. Your responses provided your proposed program and efforts to address the potential for primary water stress corrosion cracking (PWSCC) to occur in the control rod drive mechanism (CRDM) nozzles at the Comanche Peak Steam Electric Station (CPSES), Units 1 and 2.

On April 1, 1997, the staff issued GL 97-01 to the industry, requesting that addressees provide a description of their plans to inspect the vessel head penetrations (VHPs) at their respective pressurized water reactor (PWR)-designed plants. In the discussion section of the GL, the NRC staff indicated that it did not object to individual PWR licensees basing their inspection activities on an integrated, industry-wide inspection program.

The Westinghouse Owners Group (WOG), in coordination with the efforts of the Nuclear Energy Institute (NEI) and the other PWR Owners Groups (the Babcock and Wilcox (B&W) Owners Group and Combustion Engineering (CE) Owners Group), determined that it was appropriate for its members to develop a cooperative integrated inspection program in response to GL 97-01. Therefore, on July 25, 1997, the WOG submitted two Topical Reports, WCAP-14901, Revision 0, "Background and Methodology for Evaluation of Reactor Vessel Closure Head Penetration Integrity for the Westinghouse Owners Group" and WCAP-14902, Revision 0, "Background Material for Response to NRC Generic Letter 97-01: Reactor Vessel Closure Head Penetration Integrity for the Westinghouse Owners Group" on behalf of the member utilities in the WOG. In these reports, the WOG provided descriptions of the two models, the Electric Power Research Institute (EPRI)/Dominion Engineering crack initiation and growth susceptibility model and the Westinghouse Model, that were being used to rank the VHPs at the participating plants in the owners group. You provided your 30-day and 120-day responses for CPSES, Units 1 and 2 on May 1 and July 29, 1997. In these responses, you indicated that you were a participant in the WOG's integrated program for evaluating the potential for PWSCC to occur in the VHPs of Westinghouse-designed PWRs, and that you

NRC FILE CENTER COP

DFOL

PDR ADOCK

were endorsing the probabilistic susceptibility model in Westinghouse Topical Report WCAP-14901, Revision 0, as being applicable to the assessment of VHPs at CPSES, Units 1 and 2.

The NRC staff performed a review of your responses of May 1 and July 29, 1997, and the applicable topical report for your facility and determined that some additional information was needed for completion of the review. Therefore, on December 8, 1998, the NRC staff issued an RAI requesting: (1) a description of the probabilistic susceptibility ranking for a plant's VHPs to undergo PWSCC relative to the rankings for the rest of the industry; (2) a description of how the respective susceptibility models were benchmarked; (3) a description of how the variability in the product forms, material specifications, and heat treatments used to fabricate a plant's VHPs were addressed in the susceptibility models; and (4) a description of how the models would be refined in the future to include plant-specific inspection results. As was the case for the earlier responses to the GL, the NRC staff encouraged a coordinated, generic response to the requests in the RAI.

On December 11, 1998, NEI submitted a generic, integrated response to the RAIs on GL 97-01 on behalf of the PWR industry and the utility members in the owners groups. In the generic submittal, NEI informed the NRC staff that it normalized the susceptibility rankings for the industry. The generic response to the RAIs also provided sufficient information to answer the information requests in the RAIs, and emphasized that the integrated program is an ongoing program that will be implemented in conjunction with the EPRI, the PWR Owners Groups, the participating utilities, and the Material Reliability Projects' Subcommittee on Alloy 600. By letter dated March 21, 1999, the NRC staff informed NEI that the integrated program was an acceptable approach for addressing the potential for PWSCC to occur in the VHPs of PWR-designed nuclear plants, and that licensees responding to the GL could refer to the integrated program as a basis for assessing the postulated occurrence of PWSCC in PWR-designed VHPs.

To date, all utilities have implemented VT-2 type visual examinations of their VHPs in compliance with the American Society of Mechanical Engineers requirements specified in Table IWB-2500 for Category B-P components. Most utilities, if not all, have also performed visual examinations as part of plant-specific boric acid wastage surveillance programs. In addition, the following plants have completed voluntary, comprehensive augmented volumetric inspections (eddy current examinations or ultrasonic testing examinations) of their CRDM nozzles:

- 1994 - Point Beach, Unit 1 (Westinghouse design)
- 1994 - Oconee, Unit 2 (B&W design)
- 1994 - D. C. Cook, Unit 2 (Westinghouse design)
- 1996 - North Anna, Unit 1 (Westinghouse design)
- 1998 - Millstone, Unit 2 (CE design)
- 1999 - Ginna (Westinghouse design)

In addition, the following plants have completed voluntary, limited augmented volumetric inspections of their VHPs as well:

- o 1995 - Palisades - eight instrument nozzles (CE design)
- o 1996 - Oconee, Unit 2 - reinspection of two CRDM nozzles (B&W design)
- o 1997 - Calvert Cliffs, Unit 2 - vessel head vent pipe (CE design)

The majority of these plants have been ranked as having the more susceptible VHPs in the industry. Of these inspections, only the inspections at D. C. Cook, Unit 2, have resulted in the identification of any domestic PWSCC type flaw indications. The current program includes additional commitments to perform further volumetric inspections of the CRDM nozzles at Oconee, Unit 2 (a reinspection of 2-12 nozzles in 1999), Crystal River, Unit 3 (in 2001, a B&W design), Diablo Canyon, Unit 2 (in 1999, a Westinghouse design), Farley, Unit 2 (in 2001, a Westinghouse design), and San Onofre, Unit 3 (in 2002-2008, a CE design). These plants are currently ranked in either the high or moderate susceptibility categories.

On February 11, 1999, you provided your response to the NRC staff's RAI of December 8, 1998. In your letter of February 11, 1999, you endorsed the NEI submittal of December 11, 1998, and indicated that you were a participant in the NEI/WOG integrated program. Since the additional voluntary volumetric inspections performed to date have confirmed that PWSCC is not an immediate safety concern with respect to the structural integrity of VHPs in domestic PWRs, and since we have approved the integrated program for implementation, we conclude that the integrated program provides an acceptable basis for evaluating your VHPs. You may refer to the integrated program when submitting VHPs-related licensing action submittals for the remainder of the current 40-year licensing period. However, if you are considering applying for license renewal of your facilities, your application will need to address the following items: (1) an assessment of the susceptibility of your VHPs to develop PWSCC during the extended license terms for the facilities; (2) a confirmation that the VHPs at your facilities are included under the scope of your boric acid corrosion inspection program, and (3) a summary of the results of any inspections that have been completed on your VHPs prior to the license renewal application, as appropriate.

This completes the staff's efforts relative to your responses to GL 97-01. Thank you for your consideration and efforts in addressing this issue.

Sincerely,

**ORIGINAL SIGNED BY:**  
 David H. Jaffe, Senior Project Manager, Section 1  
 Project Directorate IV & Decommissioning  
 Division of Licensing Project Management  
 Office of Nuclear Reactor Regulation

Docket Nos. 50-445 and 50-446

cc: See next page

**DISTRIBUTION:**

File Center                      OGC  
 PUBLIC                              ACRS  
 PD# IV-1Reading                J.Tapia, RIV

To receive a copy of this document, indicate "C" in the box							
OFFICE	PDIV-1/PM	PDIV-1/LA	C	PDI	C	PDIV-1/SC	F
NAME	D.Jaffe:db	D.Johnson	dlj	JHarold	JH	R.Gramm	rb
DATE	11 / 18 / 99	11 / 18 / 99		11 / 19 / 99		11 / 22 / 99	

**Comanche Peak Steam Electric Station**

cc:

Senior Resident Inspector  
U.S. Nuclear Regulatory Commission  
P. O. Box 2159  
Glen Rose, TX 76403-2159

Regional Administrator, Region IV  
U.S. Nuclear Regulatory Commission  
611 Ryan Plaza Drive, Suite 400  
Arlington, TX 76011

Mrs. Juanita Ellis, President  
Citizens Association for Sound Energy  
1426 South Polk  
Dallas, TX 75224

Mr. Roger D. Walker  
Regulatory Affairs Manager  
TXU Electric  
P. O. Box 1002  
Glen Rose, TX 76043

George L. Edgar, Esq.  
Morgan, Lewis & Bockius  
1800 M Street, N.W.  
Washington, DC 20036-5869

Honorable Dale McPherson  
County Judge  
P. O. Box 851  
Glen Rose, TX 76043

Office of the Governor  
ATTN: John Howard, Director  
Environmental and Natural  
Resources Policy  
P. O. Box 12428  
Austin, TX 78711

Arthur C. Tate, Director  
Division of Compliance & Inspection  
Bureau of Radiation Control  
Texas Department of Health  
1100 West 49th Street  
Austin, TX 78756-3189

Jim Calloway  
Public Utility Commission of Texas  
Electric Industry Analysis  
P. O. Box 13326  
Austin, TX 78711-3326