

UNITED STATES NUCLEAR REGULATORY COMMISSION

NORTHEAST NUCLEAR ENERGY COMPANY, ET AL.

MILLSTONE NUCLEAR POWER STATION, UNIT NO. 3

DOCKET NO. 50-423

NOTICE OF WITHDRAWAL OF APPLICATION FOR

AMENDMENT TO FACILITY OPERATING LICENSE

The U.S. Nuclear Regulatory Commission (the Commission) has granted the request of Northeast Nuclear Energy Company (the licensee) to withdraw its May 1, 1995, application, as supplemented October 20, 1995, and March 11, 1999, for proposed amendment to Facility Operating License No. NPF-49 for the Millstone Nuclear Power Station, Unit No. 3, located in New London County, Connecticut.

The proposed amendment would have revised the facility technical specifications pertaining to the steam generator tube inspection surveillance interval, extending the interval from the current 18-month to a 24-month fuel cycle.

The Commission had previously issued a Notice of Consideration of Issuance of Amendment published in the FEDERAL REGISTER on November 27, 1995 (60 FR 58402). However, by letter dated October 5, 1999, as supplemented November 9, 1999, the licensee withdrew the proposed change.

For further details with respect to this action, see the application for amendment dated May 1, 1995, as supplemented October 20, 1995, and March 11, 1999, and the licensee's letters dated October 5 and November 9, 1999, that withdrew the application for license amendment.

Dated at Rockville, Maryland, this 29th day of November 1999.

FOR THE NUCLEAR REGULATORY COMMISSION



John A. Nakoski, Senior Project Manager, Section 2
Project Directorate I
Division of Licensing Project Management
Office of Nuclear Reactor Regulation