



**FPL**

**NOV 30 1999**

L-99-176  
10 CFR §50.90

U. S. Nuclear Regulatory Commission  
Attn: Document Control Desk  
Washington, D. C. 20555

Re: Turkey Point Units 3 and 4  
Docket Nos. 50-250 and 50-251  
Proposed License Amendments  
Soluble Boron Credit for Spent Fuel Pool and Fresh Fuel Rack  
Criticality Analyses

In accordance with 10 CFR §50.90, Florida Power and Light Company (FPL) requests that Appendix A of Facility Operating Licenses DPR-31 and DPR-41 be amended to modify Technical Specifications (TS) Table 3.9-1 and 5.6.1.

These proposed changes increase the subcritical margin in the Spent Fuel Pool (SFP) in order to accommodate degradation of the Boraflex panels in the fuel storage racks by permitting credit for soluble Boron. The generic methodology for crediting soluble boron in spent fuel rack criticality analysis, Westinghouse Spent Fuel Rack Criticality Analysis methodology WCAP-14416-NP-A, Revision 1, was approved by the Nuclear Regulatory Commission on October 25, 1996. The Turkey Point Units 3 and 4 specific Criticality Analyses for Fresh and Spent Fuel storage racks and the SFP Dilution Analysis are submitted herein to update the licensing bases which support the proposed TS changes.

A description of the amendments request is provided in Attachment 1. FPL has determined that the proposed license amendments do not involve a significant hazards consideration pursuant to 10 CFR §50.92. The no significant hazards determination in support of the proposed TS changes is provided in Attachment 2. Attachment 3 provides the proposed revised TS pages. Attachments 4 and 5 provide the Criticality Analyses for Spent Fuel Storage for Turkey Point Units 3 and 4. Attachment 6 provides the Turkey Point Units 3 and 4 SFP Dilution Analysis. Attachment 7 provides the Fresh Fuel Storage Criticality Analysis. Attachment 8 provides the Turkey Point Units 3 and 4 SFP monthly silica concentration data.

In accordance with 10 CFR §50.91(b), a copy of the proposed license amendment is being forwarded to the State Designee for the State of Florida.

A001

FPL A001 0506 0250

an FPL Group company

L-99-176

Turkey Point Units 3 and 4  
Docket Nos. 50-250 and 50-251  
Proposed License Amendments  
Soluble Boron Credit for Spent Fuel Pool and Fresh Fuel Rack  
Criticality Analyses

The proposed license amendments have been reviewed by the Turkey Point Plant Nuclear Safety Committee and the FPL Company Nuclear Review Board.

FPL requests the review and approval of the proposed amendments by June 2000.

Should there be any questions, please contact us.

Very truly yours,

A handwritten signature in black ink, appearing to read 'R. J. Hovey', with a horizontal line extending to the right from the end of the signature.

R. J. Hovey  
Vice President  
Turkey Point Plant

SM

cc:           Regional Administrator, Region II, USNRC  
              Senior Resident Inspector, USNRC, Turkey Point Plant  
              Florida Department of Health and Rehabilitative Services

Turkey Point Units 3 and 4  
Docket Nos. 50-250 and 50-251  
Proposed License Amendments  
Soluble Boron Credit for Spent Fuel Pool and Fresh Fuel Rack  
Criticality Analyses

STATE OF FLORIDA                    )  
  ) ss.  
COUNTY OF MIAMI-DADE         )

R. J. Hovey being first duly sworn, deposes and says:


That he is Vice President, Turkey Point Plant, of Florida Power and Light Company, the Licensee herein;

That he has executed the foregoing document; that the statements made in this document are true and correct to the best of his knowledge, information and belief, and that he is authorized to execute the document on behalf of said Licensee.

  
R. J. Hovey

Subscribed and sworn to before me this  
29<sup>th</sup> day of November, 1999.

Gheryl A. Stevenson  
Name of Notary Public (Type or Print)



R. J. Hovey is personally known to me.

## ATTACHMENT 1

### DESCRIPTION OF AMENDMENTS REQUEST

#### 1.0 Purpose

Florida Power and Light Company (FPL) requests that Appendix A of Facility Operating License DPR-31 and DPR-41 be amended to modify Technical Specifications (TS) Table 3.9-1, "Spent Fuel Burnup Requirements for Storage in Region II of the Spent Fuel Pit," and 5.6.1, "Criticality." The proposed changes seek to take advantage of improvements in the NRC approved Westinghouse methodology which credits soluble boron and provides a direct method for ensuring spent fuel rack subcriticality.

The proposed changes will enhance FPL's ability to retain the use of spent fuel storage cells in the Spent Fuel Pool (SFP) in the event of further Boraflex degradation, thereby preserving the ability to store spent fuel in the SFPs without the need for out of pool storage capability.

#### 2.0 Background

The industry has experienced issues related to the degradation of Boraflex, e.g. dissolution of  $B^{10}$ , gap formation, and shrinkage. NRC had requested the licensees via Generic Letter (GL) 96-04 "Boraflex Degradation in Spent Fuel Pool Storage Racks" to (1) assess the capability of the Boraflex to maintain a 5 % subcriticality margin and (2) submit to the NRC a plan describing its proposed actions if this subcriticality margin cannot be maintained by Boraflex material because of current or projected future Boraflex degradation. In response to the request, Turkey Point had assessed Boraflex degradation by considering the integrated gamma dose to the Boraflex panels in conjunction with the Blackness Testing results and the monitoring of silica level in the SFP.

The response to the GL concluded that at Turkey Point, no further Boraflex degradation could occur due to gamma irradiation. It is known that gamma irradiation from the spent fuel results in the formation of gaps and the shrinkage of the Boraflex panels. The saturation gamma dose level for the Boraflex degradation mechanism has been reported by EPRI to be between  $9 \times 10^9$  and  $1.5 \times 10^{10}$  rads. The calculated gamma dose to irradiated Boraflex panels in Turkey Point Units 3 and 4 SFPs is beyond the saturation level for this Boraflex degradation mechanism. Therefore, no additional significant shrinkage is expected due to gamma exposure beyond the saturation level.

The GL response also outlined the long-term remedies if a subcriticality margin of 5 % could not be maintained because of Boraflex degradation. FPL had indicated that should Boraflex degradation impact the capability to maintain  $K_{eff} \leq 0.95$ , FPL would consider taking credit for soluble boron in the SFP. Furthermore, it was stated in the response that FPL would evaluate the Westinghouse soluble boron credit methodology for reanalyzing the spent fuel rack criticality for Turkey Point Units 3 & 4 for crediting soluble boron.

### **3.0 Need for the Proposed Technical Specification Change**

FPL has an on-going in-service Boraflex verification program. The goals of the program are to confirm the in-service Boraflex panel performance data in terms of gap formation, gap distribution, and gap size. The program accomplishes these goals through the performance of the Blackness Testing, and the tracking of the SFP silica levels.

Blackness Testing is performed on a test frequency of every five years on specific Boraflex panels in either SFP. Engineering evaluations are performed to evaluate the results of the Blackness Testing to demonstrate that the subcritical margin required by Technical Specifications for the storage of fuel in the Spent Fuel Pool continues to be met. The results of these tests have demonstrated that the required TS subcritical margin for the storage of fuel in the SFP has been met.

The proposed changes to Turkey Point Units 3 and 4 TS Table 3.9-1 and Section 5.6.1, seek to take advantage of the NRC approved Westinghouse methodology which provides a direct method for ensuring subcriticality by utilizing the soluble boron that is contained in the SFP.

TS Table 3.9-1 will be revised to provide less restrictive enrichment and burnup requirements for the storage of fuel assemblies and TS 5.6.1 will be revised to provide boron concentration requirements for the water contained in the SFP. Westinghouse has performed criticality analyses for the Spent Fuel Storage for Turkey Point Units 3 & 4 and submitted here as Attachments 4 and 5. The Turkey Point Units 3 & 4 Boron Dilution analysis is submitted here as Attachment 6.

The criticality analyses presented in Attachment 7 change the analytical basis for the Fresh Fuel storage without the need to change the TS 5.6.1.2.

#### **4.0 System Description and Design Basis Requirements**

The design basis of the SFP is to provide for the safe storage of irradiated fuel assemblies. The pool is filled with borated water. The water removes decay heat, provides shielding for the personnel handling the fuel, and reduces the amount of radioactive gases released during a fuel handling accident. The water volume corresponding to the TS minimum level elevation of 56'-10" is conservatively determined to be 264,000 gallons.

Turkey Point Units 3 and 4 SFPs are each divided in two regions. Region I is designed to store high reactivity fuel (fresh or low burnup fuel). Region II can store lower reactivity (lower enrichment or higher burnup), but at a higher storage density. The maximum number of fuel cell locations is 1404. The spent fuel racks are designed to support and protect the spent fuel assemblies under normal and credible accident conditions. The SFP boron concentration is typically in the range of 2000 to 2100 ppm. Existing TS 3.9.14 states that the minimum boron concentration in the Spent Fuel Pit shall be 1950 ppm at all times when fuel is stored in the Spent Fuel Pit.

Criticality of fuel assemblies in a fuel storage rack is prevented by the design of the rack, which limits fuel assembly interaction. The SFP is maintained in a subcritical configuration in unborated water by:

- Limiting the fuel enrichment to no greater than 4.5 weight percent (w/o)  $U^{235}$ ,
- Maintaining a fixed separation between individual fuel assemblies stored in cells arranged into two separate regions (Regions I and II),
- Interposition of neutron absorbing panels (Boraflex) between assemblies, and
- Specifying assignment of fuel assemblies to a physical location based on accumulated burnup criteria.

## 5.0 Technical Specification Change Request

The proposed changes are described below and a markup of the proposed changes is provided in Attachment 3:

1. TS 3/4.9.14, "Table 3.9-1 Spent Fuel Burnup Requirements for Storage in Region II of the Spent Fuel Pit": Replace existing TS Table 3.9-1 with the revised Table 3.9-1 which provides the burnup for a given enrichment up to 4.5 w/o of U<sup>235</sup> that is allowed to be stored in Region II.

**Justification:** The Turkey Point spent fuel racks have been analyzed to take credit for soluble boron including the presence of Boraflex poison panels in the spent fuel rack. The maximum enrichment limit is increased from 1.5 w/o to 1.6 w/o of U<sup>235</sup>, and the required burnups for storage of initial enrichments up to 4.5 w/o of U<sup>235</sup> are updated. Storage of fuel assemblies with initial enrichments higher than 1.6 w/o of U<sup>235</sup> in all cells of the Turkey Point Units 3 and 4 Region II fuel racks is achievable by means of burnup credit using reactivity equivalencing. The concept of equivalencing is based on reactivity decrease associated with fuel depletion. For burnup credit a series of reactivity calculations has been performed assuming conservative conditions for the fuel storage cells (Attachment 4) to generate a set of enrichment-fuel assembly discharge burnup ordered pairs which all yield an equivalent  $K_{eff}$  when stored in the spent fuel storage racks in Region II. The limit of 1950 ppm, bounds the value of 650 ppm for normal conditions, which is required to maintain the spent fuel storage rack  $K_{eff} \leq 0.95$  when fuel assemblies are stored in accordance with TS 3/4.9.14. TS Table 3.9-1 represents combinations of fuel enrichment and discharge burnup based on calculations of constant rack reactivity with a soluble boron requirement of at least 650 ppm.

2. TS 5.6.1.1 "Criticality": Renumber 5.6.1.1a to 5.6.1.1b, 5.6.1.1b to 5.6.1.1c, and 5.6.1.1c to 5.6.1.1d.

**Justification:** This is an administrative change. Renumbering of these sections is needed in order to incorporate a new TS section numbered as 5.6.1.1a.

3. TS 5.6.1.1a: Add 5.6.1.1a to read, "A  $K_{eff}$  equivalent to less than 1.0 when flooded with unborated water, which includes a conservative allowance for uncertainties."

**Justification:** TS 5.6.1.1a is added in accordance with the “Westinghouse Spent Fuel Rack Criticality Analysis Methodology” SFP criteria without the presence of soluble boron. For both Region I and Region II,  $K_{\text{eff}}$  is required to remain less than 1.0 without soluble boron present in the SFP water ensuring that the spent fuel racks will remain subcritical under conditions when all cells are loaded with fuel assemblies with permitted enrichments and fuel burnups. The analytical criterion of  $K_{\text{eff}}$  equivalent to less than 1.0 when flooded with unborated water has been specifically approved by the NRC for this application.

4. **TS 5.6.1.1b:** Revise 5.6.1.1b to read, “A  $K_{\text{eff}}$  equivalent to less than or equal to 0.95 when flooded with water borated to 650 ppm, which includes a conservative allowance for uncertainties.”

**Justification:** Delete the current reactivity limitations of flooded conditions with unborated water. In addition, the conservative allowances of 0.97%  $\Delta k/k$  for Region I and 1.96%  $\Delta k/k$  for Region II are addressed in the Turkey Point specific analyses using the approved Westinghouse methodology and are not included in the TS. These limitations are replaced with  $K_{\text{eff}}$  limits that are based on the SFP criterion for the minimum soluble boron requirements to maintain subcriticality in accordance with the “Westinghouse Spent Fuel Rack Criticality Analysis Methodology” described in WCAP-14416-NP-A, Rev 1. The minimum soluble boron of 650 ppm is the required soluble boron limit which has been calculated by Westinghouse specifically for Turkey Point Units 3 and 4 and the supporting analyses are presented in Attachment 4. The TS limit of 1950 ppm, bounds the value of 650 ppm for normal conditions, which is required to maintain the spent fuel storage rack  $K_{\text{eff}} \leq 0.95$  when fuel assemblies are stored in accordance with TS 3/4.9.14. The analysis uncertainties will be incorporated into the UFSAR consistent with NUREG 1431.

5. **TS 5.6.1.1c:** Change the Region “1” to read “I” and Region 2 to read “II”.

**Justification:** This is an administrative change to have consistent naming of SFP Regions I and II.

6. **TS 5.6.1.2:** There is no change required for the TS 5.6.1.2.

**Justification:** The criticality analyses for Fresh Fuel storage racks for Turkey Point Units 3 and 4 constitute an update to the safety analyses bases. The safety analyses supporting the current TS for Fresh Fuel Storage racks has been updated as presented in Attachment 7 and in accordance to the Westinghouse methodology described in WCAP 14416-NP-A, Revision 1. The results of the analyses in Attachment 7 meet the current TS acceptance criteria for the effective neutron multiplication factor including uncertainties for fully flooded and for optimum moderation conditions. Therefore, there is no need to change the current TS.

## **6.0 Safety Analysis**

### **6.1 Westinghouse Spent Fuel Rack Criticality Analysis Methodology**

The methodology which allows credit for soluble boron is contained in the topical report "Westinghouse Spent Fuel Rack Criticality Analysis Methodology" described in WCAP-14416-NP-A, Revision 1. This methodology was approved by a NRC Safety Evaluation dated October 25, 1996.

Criticality of fuel assemblies in a fuel storage rack is prevented by the design of the rack, which limits fuel assembly interaction. This is done by fixing the minimum separation between fuel assemblies and placing absorber panels between storage cells. The design basis for preventing criticality in the SFP or for fresh fuel storage is examined on a 95/95 basis. The 95/95 basis is defined as the upper limit, with a 95 percent probability at a 95 percent confidence level, of effective neutron multiplication factor  $K_{eff}$  of the fuel assembly array, including uncertainties and manufacturing tolerances.

For the SFP, the criteria with the credit for soluble boron are:

1. The 95/95 basis  $K_{eff}$  for the storage will be less than 1.0 without the presence of the soluble boron.
2. The 95/95 basis  $K_{eff}$  for the storage will be less than or equal to 0.95 with the presence of a defined level of soluble boron in the SFP.

These criteria are defined in the topical report in WCAP-14416-NP-A, Revision 1. The analyses require the reactivity of the racks to be below 1.0 with all manufacturing tolerances and uncertainties and without any credit for soluble boron. Credit for soluble boron is taken to provide safety margin by maintaining rack reactivity to be approximately 5% below that for the no boron case, but also less than or equal to 0.95, including uncertainties and tolerances. Credit for soluble boron is also taken under accident scenarios.

### **6.2 Turkey Point Specific Calculations**

The methodology employed in Turkey Point spent fuel rack criticality calculations is based on the NRC approved "Westinghouse Spent Fuel Rack Criticality Analysis Methodology" described in WCAP-14416-NP-A, Revision 1.

The Turkey Point Units 3 & 4 spent fuel racks have been analyzed to allow storage of Westinghouse 15x15 fuel assemblies in all cells in Regions I and in all cells in Region II of the SFP. The  $K_{eff}$  was calculated for Region I and Region II. Westinghouse analyzed two cases for each region, one case with no soluble boron, and one case with credit for soluble boron. These analyses include the presence of Boraflex poison panels in the spent fuel rack. However, the Boraflex panels are degraded by shrinkage, which creates gaps in the panels. The storage racks were analyzed assuming Boraflex degradation to account for gap formation, shrinkage, and loss of  $B^{10}$  from the Boraflex panel via dissolution.

A Boron Dilution analysis was performed by Westinghouse for crediting soluble boron in the Turkey Point Units 3 & 4 spent fuel rack criticality analysis. The boron dilution analysis was performed to ensure that sufficient time is available to detect and mitigate a dilution event before the spent fuel rack criticality analysis  $0.95 K_{eff}$  design basis is exceeded.

Attachment 4 contains the Turkey Point specific calculations "Criticality for Spent Fuel Storage for Turkey Point Units 3 & 4 (Degraded Boraflex)." Attachment 5 contains the criticality analyses results for the more limiting cases (no soluble boron for Region I and Region II) which assume loss of  $B^{10}$  from the Boraflex panels via dissolution. Attachment 6 contains the SFP Boron Dilution analysis for Turkey Point.

### 6.3 Analytical Assumptions

The design method, which insures the criticality safety of fuel assemblies in the fuel storage rack, is described in detail in the Westinghouse topical report WCAP-14416-NP-A, Revision 1. In Attachment 4, Westinghouse describes the computer codes, the benchmarking, and the methodology which are used to calculate the criticality safety limits for Turkey Point Units 3 & 4. The specific assumptions employed in the Turkey Point criticality analyses are listed in the related sections of Attachments 4 and 5. The assumptions made for the Boron Dilution calculations are listed in Attachment 6.

In addition to crediting soluble boron in the SFP criticality analysis, the following storage configurations and enrichment limits were evaluated in the spent fuel rack criticality analyses:

- Westinghouse 15X15 fuel assemblies with nominal enrichments less than or equal to 4.50 w/o U<sup>235</sup> with 6 inch long natural uranium axial blankets at the top and bottom of the fuel rods, can be stored in any cell location in Region I.
- Westinghouse 15X15 fuel assemblies with initial nominal enrichments less than or equal to 1.60 w/o U<sup>235</sup> can be stored in any cell location in Region II.
- Westinghouse 15X15 fuel assemblies with initial nominal enrichments greater than 1.60 w/o U<sup>235</sup> must satisfy a minimum burnup requirement as shown in the revised TS Table 3.9-1.
- The characteristics of the Westinghouse 15x15 Optimized Fuel Assembly (OFA) Debris Resistant Fuel Assembly (DRFA) fuel assemblies were assumed in the spent fuel rack criticality analysis, since they bound storage of the Westinghouse 15X15 OFA and Low Parasitic Absorber Rod (LOPAR) fuel assemblies.

#### 6.4 Validation of the Analytical Assumptions

Boraflex degradation is monitored by the Blackness Testing and the level of silica in the water of the SFP. The measured data is used to validate the assumptions used in the criticality analyses and to ensure that they conservatively bound the actual Boraflex conditions in the Turkey Point SFP.

The input and assumptions on uncertainties and tolerances for the storage racks criticality analyses and the input used in the boron dilution analyses have been documented and independently verified in accordance to FPL's Quality Assurance program.

##### 6.4.1 Blackness Testing Results

The Blackness Testing results for each unit and both of their respective storage regions have been consolidated for the following reasons:

- The radiation and chemical environment that cause the formation of gaps and shrinkage are similar,
- The Boraflex material in both storage regions is made from the same polymer.

Blackness Testing has been performed for a fraction of the total Boraflex panels in the SFP. However, the measured results conservatively represent the conditions of irradiated Boraflex panels in the SFP for the following reasons:

- The manufacturing process for the spent fuel storage racks was very similar,
- The thermal and chemical processes for every storage cell are very similar,
- The degradation mechanism by gamma irradiation is the same for every cell, and
- The measured cells were chosen to provide information representative of the dose at which the irradiation effects plateau.

The consolidated Blackness testing results showed the following characteristics about Boraflex gaps and shrinkage:

- Less than 60% of all panels measured had gaps.
- The number of gaps per panel ranged from 0 to 7.
- At least 95% of the panels tested showed that there were 3 gaps or less.
- The largest gap width was 2.4 inches and the smallest gap was 0.5 inches.
- At least 95% of the gap widths were 1.5 inches or less.
- The axial location of these gaps along the panel was randomly distributed and the median distance between gaps was 44 inches.
- The nominal panel length had decreased by 2 inches.

A conservative representation of the entire SFP is taken in the analysis by assuming all cells having the following characteristics for each Boraflex panel:

- Five gaps/panel are assumed, with the width of each gap being 1.5 inches, separated by 7.5 inches (center to center). This assumption is conservative because it assumes 5 gaps in every panel whereas 40% of the panels tested showed no gaps.
- The length of each Boraflex panel is assumed to shrink by approximately 4.2 inches, which is greater than the measured shrinkage of 2.0 inches.
- The measured results yield a value of 2.1% of Boraflex unavailable for neutron absorption compared to the analysis value of 8.2 %.
- The gaps in the model are at the same axial position in each panel, which significantly increases the neutronic communication between cells. This does not occur in the actual SFP since the gaps are randomly distributed along the axial length of the Boraflex panel.

#### 6.4.2 Silica Monitoring

Silica is a component of Boraflex. Dissolution of silica from the Boraflex into the main body of the water of the Spent Fuel Pool will occur until it reaches an equilibrium concentration. One way to disturb this equilibrium condition and encourage further degradation is via the Spent Fuel Purification System that removes impurities from the water via a mixed bed ion exchanger. There are three factors limiting dissolution of silica from the Boraflex:

- The free flow of Spent Fuel Pool water inside the Boraflex wrapper plate is very limited due to the construction of the Boraflex wrapper plate and its attachment to the wall of the fuel storage cell,
- There are very few exchange sites available in the ion exchange resin for the removal of silica causing the resin to saturate with silica quickly which results in only a slight decrease in silica concentration, and
- The purification system is normally lined up to the Refueling Water Storage Tank.

The most significant method of decreasing silica concentration in the SFP is via a feed and bleed operation, which is an evolution that is rarely used.

Dissolution of  $B^{10}$  out of the Boraflex as a degradation mechanism is not considered a significant problem. This is evidenced by the low concentration of silica in the SFP water as a function of time. Attachment 8 provides the surveillance results for measured levels of silica in the SFP.

The effect of loss of  $B^{10}$  from the Boraflex was evaluated in Attachment 5. The sensitivity calculations were based on the degraded Boraflex base case presented in Attachment 4. The criticality calculations were performed assuming a reduction in either the areal density of  $B^{10}$  or a reduction in the areal density of  $B^{10}$  with a corresponding reduction in thickness of the Boraflex panel. The most limiting combination that would continue to support the criteria of  $K_{eff} < 1.0$  with no soluble boron in the Spent Fuel Pool water was then determined for:

- Region I: The combination was a reduction of both areal density and thickness by a factor of slightly more than two.
- Region II: The combination was no change in thickness and reduction of the areal density by a factor of two.

The effect of silica dissolution on the thickness and areal density of Boraflex panels can be estimated by assuming that dissolution of silica into the pool water is a uniform process. From the data in Attachment 8 it appears that over a period of several years there is only a small decrease in the average panel thickness and areal density given that the average silica concentration has increased at a very slow rate over the elapsed time. Therefore, the assumptions made in the analysis in Attachment 5 are considered very conservative and the resulting  $K_{eff}$  is conservatively high.

It is apparent that the amount of Boraflex degradation assumed in the criticality analyses compared to the measured values is greater. Therefore, the calculated  $K_{eff}$  would be considered bounding for the present conditions in the SFP.

## 6.5 Analysis Results

The criticality analyses performed for the Turkey Point spent fuel storage racks show that the acceptance criteria for criticality are met for the storage of Westinghouse 15X15 fuel assemblies under both normal and accident conditions with soluble boron credit, partial credit for the spent fuel rack Boraflex neutron absorber, credit for natural uranium axial blankets (Region I), and the burnup and enrichment limits described above.

The proposed TS 5.6.1.1 changes establish a boron concentration requirement for the water contained in the SFP. Since TS 3/4.9.14, already contains a limit that exceeds this requirement, and soluble boron has always been contained in the SFP water, this requirement will have no effect on normal SFP operations and maintenance. The proposed TS Table 3.9-1 changes establish less restrictive enrichment and burnup requirements for the storage of fuel assemblies. Since the TS for a given enrichment currently contain more restrictive burnup requirements for spent fuel storage, the revised limitations will have no effect on normal pool operations and maintenance.

Based on the results of the criticality analyses presented in Attachment 4, SFP boron concentration of 1100 ppm for accident conditions would maintain the spent fuel storage rack  $K_{eff} \leq 0.95$ , while compensating for the increased reactivity which could result from a misplaced fuel assembly. The misplaced fuel assembly event bounds a loss of SFP cooling event. The current TS SFP boron concentration limit of 1950 ppm is consistent with the boron concentration normally maintained in the SFP. Since soluble boron has always been contained in the SFP, this requirement will have no effect on normal pool operations and maintenance. The limit of 1950 ppm, bounds the value of 650 ppm for normal conditions, which is required to maintain the spent fuel storage rack  $K_{eff} \leq 0.95$  when fuel assemblies are stored in accordance with TS 3/4.9.14.

The 30 day frequency for sampling the boron concentration in the SFP in current TS 3/4.9.14 is adequate because significant reductions in SFP boron concentration result from significant increases in pool volume or significant changes in the sources of non-borated water to the pool. Significant changes in the boron concentration are difficult to produce without detection, since the pool contains such a large volume of water. Soluble boron concentration reduction requires the inflow and outflow of large volumes of water, which are readily detected. Pool inventory changes provide a good indication of potential boron concentration changes. The pool water inventory is monitored by level indication and alarms and by periodic operator rounds of the SFP. Sampling and verification of the SFP boron concentration on a 30-day frequency provides adequate assurance that smaller and less readily identifiable boron concentration reductions are not taking place.

SFP systems, instrumentation, and supporting systems are not modified as a result of the proposed license amendments. Operations involving SFP water cooling and cleanup do not change.

The Turkey Point spent fuel rack criticality analysis also addressed postulated accidents in the SFP. The accidents that can occur in the SFP and their consequences are not significantly affected by taking credit for the soluble boron present in the pool water as a major subcriticality control element.

The criticality analyses confirmed that most SFP accident conditions would not result in an increase in  $K_{eff}$  of the spent fuel racks. Examples of such accidents are the drop of a fuel assembly on top of a rack, and the drop or placement of a fuel assembly into the cask loading area. At Turkey Point, the spent fuel assembly rack configuration is such that it precludes the insertion of a fuel assembly in between rack modules. A dropped fuel assembly can only land on the top of the racks.

From a criticality standpoint, the dropped fuel assembly accident assumes a fuel assembly in its most reactive condition is dropped on to the spent fuel racks. The rack structure pertinent for criticality is not excessively deformed. Previous accident analysis with unborated water showed that a dropped fuel assembly which comes to rest horizontally on top of the spent fuel rack has sufficient water separating it from the active fuel height of stored fuel assemblies to preclude neutronic interaction. For the borated water condition, the interaction is even less since the water contains boron, an additional thermal neutron absorber.

However, two accidents can be postulated which could result in an increase in reactivity. The first postulated accident would be a loss of the SFP cooling system. The second would be the misloading of a fuel assembly into a cell for which the restrictions on enrichment and burnup are not satisfied, which can occur in Region II (which bounds all other fuel misloading accidents).

The loss of normal cooling to the SFP water causes an increase in the temperature of the water passing through the stored fuel assemblies. This causes a decrease in water density, which would result in a net increase in reactivity when soluble boron is present in the water and Boraflex neutron absorber panels are present in the racks. A fuel assembly misload accident relates to the use of restricted storage locations based on fuel assembly initial enrichment and burnup. Administrative controls are placed on the loading of assemblies into these locations (Region II). The misloading of a fuel assembly constitutes not meeting the enrichment and burnup requirements of that location. The result of the misloading is to add positive reactivity, increasing  $K_{eff}$  toward 0.95.

The amount of soluble boron required to offset each of these postulated accidents was evaluated for all of the storage configurations in the criticality analysis described above. The evaluation established the amount of soluble boron necessary to ensure that the spent fuel rack  $K_{eff}$  will be maintained less than or equal to 0.95 should a loss of SFP cooling or a fuel assembly misload accident occur.

The amount of soluble boron necessary to mitigate either of these events, 1100 ppm, is bounded by the SFP boron concentration limit contained in TS 3/4.9.14. Based on the double contingency principle, the boron concentration limit for accident conditions contained in the TS does not have to account for both a loss of cooling event and a misload event occurring at the same time.

The radiological consequences of a dropped assembly accident in the SFP do not change because of the presence of soluble boron in the SFP water. The current Updated Final Safety Analysis Report (UFSAR) accident analysis (Section 14.2.1) assumes that a high burnup fuel assembly is dropped, and the outer row of fuel rods (15) in the dropped assembly ruptures releasing the gap radioactive gases. A large fraction of the halogen gases is entrained in the pool water limiting the off-site exposures.

A boron dilution analysis was performed to ensure that sufficient time is available to detect and mitigate dilution of the SFP before the 0.95  $K_{eff}$  design basis is exceeded. The results of the SFP boron dilution analysis are summarized in Attachment 6. Calculations were performed to define the dilution times and volumes for the SFP. The dilution sources available were compiled and evaluated against the calculated dilution volumes, to determine the potential for a SFP boron dilution event.

The analysis shows that a large volume of water (approximately 290,000 gallons) is necessary to dilute the SFP from the TS limit of 1950 ppm to a soluble boron concentration where a  $K_{eff}$  of 0.95 would be approached in the SFP. A dilution event large enough to result in a significant reduction in the SFP boron concentration would involve the transfer of a large quantity of water from a dilution source and a significant increase in SFP level which would ultimately overflow the pool. In addition, because of the dilution flow rates available at Turkey Point during normal plant operations (Attachment 6), and the large quantities of water required, any significant dilution of the SFP would only occur over a long period of time (hours to days). Detection of a SFP dilution via level alarms and/or visual inspections would be expected long before a significant dilution would occur. Therefore, it is highly unlikely that any dilution event in the SFP could result in the reduction of the SFP boron concentration to less than the 650 ppm design basis limit.

The proposed TS 5.6.1.1b requires that the spent fuel rack  $K_{eff}$  be less than or equal to 0.95 when flooded with water borated to 650 ppm. The dilution analysis (Attachment 6) concluded that large volumes of water are necessary to dilute the SFP water from the 1950 ppm Technical Specification limit to less than the boron concentration limit of 650 ppm. The availability of such large water supplies on site is limited. In addition, the transferability of the available water supplies to the pool is very low due to the small number of possible flow paths, and in many cases impossible due to the physical arrangement of the SFP relative to the supplies.

The SFP dilution analysis assumes thorough mixing of all the nonborated water added to the SFP. It is unlikely, with cooling flow and convection from the spent fuel decay heat, that thorough mixing would not occur. However, if mixing were not adequate, it would be conceivable that a localized pocket of non-borated water could form somewhere in the SFP. This possibility is addressed by the calculation in Attachment 4, which shows that the spent fuel rack  $K_{eff}$  will be less than 1.0 on a 95/95 basis with the SFP filled with non-borated water. Thus, even if a pocket of non-borated water formed in the SFP,  $K_{eff}$  would not be expected to exceed 1.0 anywhere in the pool.

The Fresh Fuel racks were analyzed (Attachment 7) for the full density water flooding and for introduction of water at optimum density. (Optimum density is defined as the low density of water, which would lead to the highest reactivity of the storage array). Under normal conditions, the fresh fuel racks are maintained in a dry environment. The introduction of water into the fresh fuel rack area is the worst case accident scenario. The water flooding cases analyzed in Attachment 7 are bounding accident situations, which result in the most conservative fuel rack  $K_{eff}$ . Since  $K_{eff}$  was calculated to be less than 0.95 for the full density analysis and less than 0.98 for the optimum water density moderation analysis, including uncertainties at a 95/95 probability/confidence level, the respective acceptance criteria for criticality are met for storage of the 15x15 fuel assemblies with maximum allowed enrichment.

## 7.0 Conclusion

The safety analyses in Attachments 4, 5, 6 and 7 demonstrate that the required margin for subcriticality in the SFP and the New Fuel storage racks will not be exceeded.

The combination of the following provides a level of safety:

1. The 95/95  $K_{eff}$  calculation, which shows that the spent fuel rack  $K_{eff}$  will remain less than 1.0 when flooded with unborated water.
2. The proposed TS which will ensure that the SFP boron concentration and fuel assembly storage will be maintained consistent with the assumptions in the criticality analysis, thus maintaining the required margin to criticality.
3. The criticality analysis for the Turkey Point spent fuel racks which was performed utilizing the NRC approved Westinghouse Spent Fuel Rack Criticality Analysis Methodology described in WCAP-14416-NP-A, Revision 1, October 25, 1996.
4. The 95/95  $K_{eff}$  calculation, which shows that the New Fuel storage rack  $K_{eff}$  will remain less than 0.95 when flooded with unborated water and less than 0.98 for low-density optimum moderation conditions.

In conclusion, the proposed TS amendments provide reasonable assurance of continued protection of the public health and safety.

## ATTACHMENT 2

### NO SIGNIFICANT HAZARDS CONSIDERATION DETERMINATION

#### Introduction

The Nuclear Regulatory Commission has provided standards for determining whether a significant safety hazards consideration exists [10 CFR §50.92(c)]. A proposed amendment to an operating license for a facility involves no significant hazards consideration, if operation of the facility in accordance with the proposed amendment would not (1) involve a significant increase in the probability or consequences of an accident previously evaluated; or (2) create the possibility of a new or different kind of accident from any accident previously evaluated; or (3) involve a significant reduction in a margin of safety. Each standard is discussed below for the proposed amendments.

#### Discussion

- (1) Operation of the facility in accordance with the proposed amendments would not involve a significant increase in the probability or consequences of an accident previously evaluated.**

There is no increase in the probability of a fuel assembly drop accident in the Spent Fuel Pool (SFP) when considering the presence of soluble boron in the SFP water for criticality control. The handling of the fuel assemblies in the SFP has always been performed in borated water. The consequences of a fuel assembly drop accident in the SFP are not affected when considering the presence of soluble boron.

There is no increase in the probability of the accidental misloading of spent fuel assemblies into the SFP racks when considering the presence of soluble boron in the pool water for criticality control. Fuel assembly placement will continue to be controlled pursuant to approved fuel handling procedures and will be in accordance with the Technical Specification (TS) spent fuel rack storage limitations. There is no increase in the consequences of the accidental misloading of spent fuel assemblies into the SFP racks because criticality analyses demonstrate that the pool will remain subcritical following an accidental misloading if the pool contains an adequate boron concentration. The proposed TS ensure that an adequate SFP boron concentration will be maintained. There is no increase in the probability of the loss of normal cooling to the SFP water when considering the presence of soluble boron in the pool water for subcriticality control since a high concentration of soluble boron has always been maintained in the SFP water.

A loss of normal cooling to the SFP water causes an increase in the temperature of the water passing through the stored fuel assemblies. This causes a decrease in water density, which would result in a net increase in reactivity when soluble boron is present in the water and Boraflex neutron absorber panels are present in the racks. However, the additional negative reactivity provided by the 1950 ppm boron concentration limit, above that provided by the concentration required (650 ppm) to maintain  $K_{eff}$  less than or equal to 0.95, will compensate for the increased reactivity which could result from a loss of SFP cooling event. Because adequate soluble boron will be maintained in the SFP water, the consequences of a loss of normal cooling to the SFP will not be increased.

The Fresh Fuel racks are analyzed by employing the "Westinghouse Spent Fuel Rack Criticality Analysis Methodology" approved by the NRC and described in WCAP-14416, NP-A, Revision 1. Only the method for Fresh Fuel storage racks criticality calculations has changed. The method of handling fuel, the maximum fuel enrichment, and the limiting values for criticality have not changed. Therefore, there is no change in the margin of safety for the Fresh Fuel storage racks.

Therefore, based on the conclusions of the above analysis, the proposed changes will not involve a significant increase in the probability or consequences of an accident previously evaluated.

- (2) Operation of the facility in accordance with the proposed amendments would not create the possibility of a new or different kind of accident from any previously evaluated.**

Spent fuel handling accidents are not new or different types of accidents, they have been analyzed in Section 14.2.1 of the Updated Final Safety Analysis Report (UFSAR). Criticality accidents in the SFP are not new or different types of accidents, they have been analyzed in the UFSAR and in the spent fuel storage criticality analysis.

Current TS 3/4.9.14 already contains a limit on the SFP boron concentration. The boron concentration in the SFP has always been maintained near the limit of the RWST boron concentration for refueling purposes. The current TS boron concentration requirement for the SFP water conservatively bounds the boration assumptions of the revised criticality analyses. Since soluble boron has always been maintained in the SFP water, the implementation of this requirement for criticality purposes will have no effect on normal pool operations and maintenance.

Since soluble boron has always been present in the SFP, a dilution of the SFP soluble boron has always been a possibility. However, it was shown in the SFP dilution analysis that a dilution of the Turkey Point SFP which could increase the spent fuel storage rack  $K_{eff}$  to greater than 0.95 is not a credible event. Therefore, the implementation of limitations on the SFP boron concentration for criticality purposes will not result in the possibility of a new or different kind of accident.

Proposed TS 3/4.9.14 Table 3.9-1 specifies the requirements for the spent fuel rack storage, which is currently contained in the TS. These proposed new SFP storage limitations are consistent with the assumptions made in the spent fuel rack criticality analysis, and will not have any significant effect on normal SFP operations and maintenance, and will not create any possibility of a new or different kind of accident. Verifications will continue to be performed to ensure that the SFP loading configuration meets specified requirements.

The Fresh Fuel racks are analyzed by employing the "Westinghouse Spent Fuel Rack Criticality Analysis Methodology" approved by the NRC and described in WCAP-14416, NP-A, Revision 1. Only the method for Fresh Fuel storage racks criticality calculations has changed. The method of handling fuel, the maximum fuel enrichment, and the limiting values for criticality have not changed. Therefore, there is no change in the margin of safety for the Fresh Fuel storage racks.

As discussed above, the proposed changes will not create the possibility of a new or different kind of accident from any previously evaluated. There is no significant change in plant configuration, equipment design or equipment.

**(3) Operation of the facility in accordance with the proposed amendments would not involve a significant reduction in a margin of safety.**

The proposed TS changes will provide adequate safety margin to ensure that the stored fuel assembly array will always remain subcritical. Those limits are based on a plant specific criticality analyses performed in accordance with the NRC approved Westinghouse Spent Fuel Rack criticality analysis methodology.

The criticality analysis takes credit for soluble boron to ensure that  $K_{eff}$  will be less than or equal to 0.95 under normal circumstances. Storage configurations have been defined using a 95/95  $K_{eff}$  calculation to ensure that the spent fuel rack  $K_{eff}$  will be less than 1.0 with no soluble boron. Soluble boron credit is used to provide safety margin by maintaining  $K_{eff}$  less than or equal to 0.95, including uncertainties, tolerances, and accident conditions in the presence of SFP soluble boron.

The loss of substantial amounts of soluble boron from the SFP that could lead to exceeding a  $K_{eff}$  of 0.95 has been evaluated in the SFP Dilution analysis and shown to be not credible.

The analysis shows that the dilution of the SFP boron concentration from 1950 ppm to 650 ppm is not credible. When this result is combined with the results from the 95/95 criticality analyses, which show that the spent fuel rack  $K_{eff}$  will remain less than 1.0 when flooded with unborated water, it provides a level of safety comparable to the conservative criticality analysis methodology required by ANSI 57.2-1983, NUREG-0800, and Regulatory Guide 1.13.

The Fresh Fuel racks are analyzed by employing the "Westinghouse Spent Fuel Rack Criticality Analysis Methodology" approved by the NRC and described in WCAP-14416, NP-A, Revision 1. Only the method for Fresh Fuel storage racks criticality calculations has changed. The method of handling fuel, the maximum fuel enrichment, and the limiting values for criticality have not changed. Therefore, there is no change in the margin of safety for the Fresh Fuel storage racks.

Therefore, the proposed changes in these license amendments will not result in a significant reduction in the plant's margin of safety.

### Summary

Based on the reasoning presented above, FPL has determined that the proposed amendments request does not (1) involve a significant increase in the probability or consequences of an accident previously evaluated, (2) create the possibility of a new or different kind of accident from any accident previously evaluated, or (3) involve a significant reduction in a margin of safety; therefore the proposed changes do not involve a significant hazards consideration

L-99-176  
Attachment 3

**ATTACHMENT 3**

**PROPOSED TECHNICAL SPECIFICATION PAGES**

3/4 9-16  
5-5

TABLE 3.9-1

SPENT FUEL BURNUP REQUIREMENTS FOR STORAGE  
IN REGION II OF THE SPENT FUEL PIT

<u>Initial w/o</u>	<u>Discharge Burnup GWD/MT</u>
1.5	0.
1.75	5.0
2.0	9.0
2.2	12.0
2.4	14.8
2.6	17.6
2.8	20.1
3.0	22.6
3.2	25.0
3.4	27.4
3.6	29.6
3.8	31.8
4.0	34.0
4.2	36.1
4.5	39.0

Linear interpolation between two consecutive points will yield conservative results.

Replace  
with attached

Add

TABLE 3.9-1

SPENT FUEL BURNUP REQUIREMENTS FOR STORAGE  
IN REGION II OF THE SPENT FUEL PIT

<u>Initial w/o</u>	<u>Discharge Burnup MWD/MTU</u>
1.6	0.0
1.80	3706
2.00	7459
2.20	9724
2.40	12582
2.60	15338
2.63	15914
2.80	17994
3.00	20548
3.25	23312
3.40	25354
3.60	27605
3.88	30256
4.00	31804
4.20	33752
4.40	35599
4.50	36746

Linear interpolation between values may  
be used for intermediate points.

DESIGN FEATURES

5.6 FUEL STORAGE

5.6.1 CRITICALITY

a.  $k_{eff}$  equivalent to less than 1.0 when flooded with unborated water, which includes a conservative allowance for uncertainties

5.6.1.1 The spent fuel storage racks are designed to provide safe subcritical storage of fuel assemblies by providing sufficient center-to-center spacing or a combination of spacing and poison and shall be maintained with:

borated to 650 ppm

Delete

b. ~~A  $k_{eff}$  equivalent to less than or equal to 0.95 when flooded with unborated water, which includes a conservative allowance in region 1 of 0.97%  $\Delta k/k$  and in region 2 of 1.96%  $\Delta k/k$  for uncertainties for two-region fuel storage racks.~~

delete

c. ~~b.~~ A nominal 10.6 inch center-to-center distance for Region 1 and 9.0 inch center-to-center distance for Region 2 for two region fuel storage racks.

II

d. ~~c.~~ The maximum enrichment loading for fuel assemblies is 4.5 weight percent of U-235.

5.6.1.2 The racks for new fuel storage are designed to store fuel in a safe subcritical array and shall be maintained with:

a. A nominal 21 inch center-to-center spacing to assure  $k_{eff}$  equal to or less than 0.98 for optimum moderation conditions and equal to or less than 0.95 for fully flooded conditions.

b. Fuel assemblies placed in the New Fuel Storage Area shall contain no more than 4.5 weight percent of U-235.

L-99-176  
Attachment 4

**ATTACHMENT 4**

**Criticality Analyses for Fresh and Spent Fuel  
Storage for Turkey Point Unit 3 and 4  
(Degraded Boraflex)**

**Criticality for Spent Fuel Storage for  
Turkey Point Units 3 & 4  
(Degraded Boraflex)**

July 1999

H. C. Huria  
M. A. Kotun  
M. Ouisloumen  
S. Srinilta  
S. Kapil

Prepared:

*S. Kapil*  
S. Kapil  
Criticality Services Team

*7/6/99*

Verified:

*S. Srinilta*  
S. Srinilta  
Criticality Services Team

*7/6/99*

Approved:

*S. Ray*  
S. Ray, Manager  
Core Analysis B

*7/6/99*



**Westinghouse  
Commercial Nuclear Fuel Division**

# Table of Contents

<b>1.0</b>	<b>Introduction.....</b>	<b>1</b>
1.1	Design Description.....	1
1.2	Design Criteria .....	2
<b>2.0</b>	<b>Analytical Methods .....</b>	<b>3</b>
<b>3.0</b>	<b>Criticality Analysis of Region 1 All Cell Spent Fuel Storage.....</b>	<b>4</b>
3.1	No Soluble Boron $K_{eff}$ Calculation.....	4
3.2	Soluble Boron Credit $K_{eff}$ Calculations.....	7
<b>4.0</b>	<b>Criticality Analysis of Region 2 All Cell Spent Fuel Storage.....</b>	<b>8</b>
4.1	No Soluble Boron $K_{eff}$ Calculation.....	8
4.2	Soluble Boron Credit $K_{eff}$ Calculations.....	11
4.3	Burnup Credit Reactivity Equivalencing.....	11
<b>5.0</b>	<b>Discussion of Postulated Accidents in the Spent Fuel Pool .....</b>	<b>13</b>
<b>6.0</b>	<b>Soluble Boron Credit Summary .....</b>	<b>15</b>
<b>7.0</b>	<b>Summary of Criticality Results .....</b>	<b>16</b>
	<b>Bibliography .....</b>	<b>30</b>

## List of Tables

Table 1.	Nominal Fuel Parameters Employed in the Criticality Analysis .....	17
Table 2.	Turkey Point 3 and 4 Region 1 Spent Fuel Storage Cell and Fuel Nominal Parameters .....	18
Table 3.	Region 1 - No Soluble Boron .....	19
Table 4.	Region 1 - With Soluble Boron (450 ppm) .....	20
Table 5.	Turkey Point 3 and 4 Region 2 Spent Fuel Storage Cell Nominal Parameters. ....	21
Table 6.	Region 2 - No Soluble Boron.....	22
Table 7.	Region 2 - With Soluble Boron (250 ppm) .....	23
Table 8.	Spent Fuel Pool Soluble Boron Requirements . ....	24
Table 9.	Burnup Needed for Fuel Storage in Region 2 of the Spent Fuel Pool .....	25

## List of Figures

Figure 1.	Turkey Point Units 3 and 4 Region 1 Spent Fuel Pool Storage Cell Nominal Dimensions .....	26
Figure 2.	Turkey Point Units 3 and 4 High Density Spent Fuel Pool Storage Cell (Region 2) Nominal Dimensions .....	27
Figure 3.	Degraded Boraflex Panel (Not to Scale).....	28
Figure 4.	Turkey Point Units 3 and 4 High Density All Cell Configuration Burnup Credit Requirements (Region 2).....	29

# 1.0 Introduction

This report presents the results of criticality analyses of the Florida Power & Light Turkey Point Units 3 and 4 spent fuel storage racks with credit for spent fuel pool soluble boron.

Turkey Point Units 3 and 4 spent fuel pool is divided into two regions. Region 1 is designed to store high reactivity fuel (fresh or low burnup fuel). Region 2 can store lower reactivity (lower enrichment or higher burnup) fuel, but at a higher storage density.

The methodology employed here is contained in the topical report, "Westinghouse Spent Fuel Rack Criticality Analysis Methodology"<sup>(1)</sup>.

The Turkey Point Units 3 and 4 spent fuel racks have been analyzed to allow storage of Westinghouse 15x15 fuel assemblies with nominal enrichments up to 4.5 w/o <sup>235</sup>U (with 6 inches long natural uranium axial blanket at top and bottom of the fuel rods) in Region 1 storage cell locations and fuel with an equivalent enrichment up to 1.60 w/o <sup>235</sup>U (with no axial blankets) in Region 2. Both analyses take credit for soluble boron in the pool. These analyses include the presence of the Boraflex poison panels in the spent fuel rack. However, the boraflex panels are degraded by shrinkage which creates gaps in the panels.

The analyses require the reactivity of the racks to be below 1.0 with all manufacturing tolerances and uncertainties and without any credit for soluble boron. Credit for soluble boron is taken to provide safety margin by maintaining rack reactivity to be approximately 5% below that for the no boron case, but also less than or equal to 0.95, including uncertainties and tolerances. Credit for soluble boron is also taken under accident conditions.

The following storage configurations and enrichment limits were considered in these analyses:

**All Cell Storage  
in Region 1**

Storage of 15x15 fuel assemblies in any cell location. Fuel assemblies must have an initial nominal enrichment no greater than 4.50 w/o <sup>235</sup>U with 6 inches long natural uranium axial blanket at top and bottom of the fuel rods. The soluble boron credit required for this storage configuration is 450 ppm.

**All Cell Storage  
in Region 2**

Storage of 15x15 fuel assemblies in any cell location. Fuel assemblies must have an initial nominal enrichment no greater than 1.60 w/o <sup>235</sup>U or satisfy a minimum burnup requirement for higher initial enrichments. The soluble boron credit required for this storage configuration is 650 ppm.

## 1.1 Design Description

The Turkey Point Unit 3 spent fuel storage cells for Regions 1 and 2 are shown in Figure 1 on page 26 and Figure 2 on page 27, respectively. These are also used to represent the Turkey Point Unit 4 pool, as they are the same or more limiting. The degraded boraflex panel is shown in Figure 3 on page 28.

The fuel parameters relevant to this analysis are given in Table 1 on page 17. The Table 1 fuel parameters bound the previous fuel designs used in Turkey Point Units 3 & 4. The fuel rod and guide thimble and instrumentation thimble tube cladding are modeled as zircaloy in this analysis. This is conservative with respect to the Westinghouse ZIRLO™ product which is a zirconium alloy containing additional elements including niobium. Niobium has a small absorption cross section which causes more neutron capture in the cladding resulting in a lower reactivity. Therefore, this analysis is conservative with respect to fuel assemblies containing ZIRLO™ cladding in fuel rods and guide thimble and instrumentation thimble tubes.

## 1.2 Design Criteria

Criticality of fuel assemblies in a fuel storage rack is prevented by the design of the rack which limits fuel assembly interaction. This is done by fixing the minimum separation between fuel assembly and/or placing absorber panels between storage cells.

The design basis for preventing criticality in the spent fuel pool (SFP) or for fresh fuel storage, is examined on the 95/95 basis. The 95/95 basis is defined as the upper limit, with a 95 percent probability at a 95 percent confidence level, of the effective neutron multiplication factor  $K_{eff}$  of the fuel assembly array, including uncertainties and manufacturing tolerances.

For the spent fuel pool, the criteria with the credit for soluble boron are:

1. The 95/95 basis  $K_{eff}$  for the storage will be less than 1.0, without the presence of soluble boron.
2. The 95/95 basis  $K_{eff}$  for the storage will be less than or equal to 0.95 with the presence of a defined level of soluble boron in the pool.

These criteria are defined in the topical report, "Westinghouse Spent Fuel Rack Criticality Analysis Methodology"<sup>(1)</sup>.

The design criteria are consistent with ANSI 57.2-1983<sup>(2)</sup>, NRC guidance<sup>(3)</sup>, NUREG-0800<sup>(4)</sup> and the NRC approved Westinghouse criticality topical report "Westinghouse Spent Fuel Rack Criticality Analysis Methodology"<sup>(1)</sup>.

## 2.0 Analytical Methods

The criticality calculation method and cross-section values are verified by comparison with critical experiment data for fuel assemblies similar to those for which the racks are designed. This benchmarking data is sufficiently diverse to establish that the method bias and uncertainty will apply to rack conditions which include strong neutron absorbers, large water gaps, low moderator densities and spent fuel pool soluble boron.

The design method which insures the criticality safety of fuel assemblies in the fuel storage rack is described in detail in the Westinghouse Spent Fuel Rack Criticality Analysis Methodology topical report<sup>(1)</sup>. This report describes the computer codes, benchmarking, and methodology which are used to calculate the criticality safety limits presented in this report for Turkey Point Units 3 and 4.

As determined in the benchmarking in the topical report, the method bias using the described methodology of NITAWL-II, XSDRNPM-S and KENO-Va is  $0.00770 \Delta K$  with a 95 percent probability at a 95 percent confidence level uncertainty on the bias of  $0.00300 \Delta K$ . These values will be used in this report.

### 3.0 Criticality Analysis of Region 1 All Cell Spent Fuel Storage

This section describes the analytical techniques and models employed to perform the criticality analysis for the storage of fuel in all cells of the Turkey Point Units 3 and 4 Region 1 spent fuel storage racks with credit for soluble boron.

Section 3.1 describes the no soluble boron  $K_{eff}$  calculations. Section 3.2 discusses the results of the spent fuel rack  $K_{eff}$  soluble boron credit calculations.

Region 1 fuel storage rack configuration is shown in Figure 1 on page 26 and the rack parameters are shown in Table 2 on page 18.

#### 3.1 No Soluble Boron $K_{eff}$ Calculation

For the no soluble boron conditions the 95/95 basis  $K_{eff}$  should be less than 1.0. KENO-Va is used to establish a nominal reference reactivity and PHOENIX-P is used to assess the temperature bias of a normal pool temperature range and the effects of material and construction tolerance variations. A final 95/95  $K_{eff}$  is developed by statistically combining the individual tolerance impacts with the calculational and methodology uncertainties and summing this term with the temperature and method biases and the nominal KENO-Va reference reactivity. The equation for determining the final 95/95  $K_{eff}$  is defined in Reference 1 and is shown below:

$$K_{eff} = K_{nominal} + B_{method} + B_{temp} + B_{self} + B_{uncert}$$

where:

- $K_{nominal}$  = nominal conditions KENO-Va  $K_{eff}$
- $B_{method}$  = method bias determined from benchmark critical comparisons
- $B_{temp}$  = temperature bias
- $B_{self}$  =  $^{10}\text{B}$  self shielding bias, if applicable.
- $B_{uncert}$  = statistical summation of uncertainty components  
=  $[\text{Sum}\{\text{tolerance}(i)^2 \dots \text{or} \dots \text{uncertainty}(i)\}^2]^{**1/2}$

Following assumptions were used to develop the nominal KENO-Va model for storage of fuel assemblies in all cells of the Turkey Point Units 3 and 4 spent fuel storage rack:

1. The fuel assembly parameters relevant to the criticality analysis were based on the Westinghouse 15x15 DRFA fuel design with nominal enrichment of 4.5 w/o and with 6 inch natural uranium axial blanket at top and bottom (see Tables 1 and 2 for fuel parameters).
2. The fuel pellets were modeled assuming nominal values for pellet density and dish-fraction.
3. No credit was taken for any  $^{234}\text{U}$  or  $^{236}\text{U}$  in the fuel, nor was any credit taken for the buildup of fission product poison material.
4. No credit was taken for any grids in the assembly.
5. No credit was taken for any burnable absorber in the fuel rods.
6. Credit was taken for the presence of spent fuel rack Boraflex poison panels.  $^{10}\text{B}$  areal density of  $0.020 \text{ gm/cm}^2$  was used.
7. The moderator was water with 0 ppm soluble boron at a temperature of  $68^\circ\text{F}$ . A water density of  $1.0 \text{ gm/cm}^3$  was used.
8. The array was infinite in lateral (x and y) extent and finite in axial (vertical) extent.
9. All available storage cells were loaded with fuel assemblies.

Fuel assembly data is shown in Table 1 on page 17. Dimensions for the Region 1 fuel racks are shown in Table 2 on page 18 and the cell arrangement is shown in Figure 1 on page 26.

With the above assumptions, the nominal KENO-Va calculation resulted in a  $K_{\text{eff}}$  of  $0.93970 \pm 0.00081$  under normal conditions.

Following biases are included:

**Methodology:** The benchmarking bias as determined for the Westinghouse KENO-Va methodology was considered.

**Water Temperature:** A reactivity bias determined in PHOENIX-P was applied to account for the effect of the normal range of spent fuel pool water temperatures ( $50^\circ\text{F}$  to  $185^\circ\text{F}$ ).

**Particle Size Effect in Boraflex:** A bias on reactivity resulting from the finite particle size of the boron bearing compound in Boraflex panels.

All biases are shown in Table 3 on page 19. To evaluate the reactivity effects of possible variations in material characteristics and mechanical/construction dimensions, PHOENIX-P perturbation calculations were performed. For the Turkey Point Units 3 and 4 spent fuel rack all cell storage configuration,  $\text{H}_2\text{O}$  material tolerances were considered along with construction tolerances. Uncertainties associated with calculation and methodology accuracy were also included in the statistical summation of uncertainty components. Nominal values are shown in Table 2 on page 18 and manufacturing tolerances and uncertainties are shown in Table 3 on page 19.

Following tolerance and uncertainty components were considered in the total uncertainty statistical summation:

**<sup>235</sup>U Enrichment:** The standard DOE enrichment tolerance of  $\pm 0.05$  w/o <sup>235</sup>U about the nominal reference enrichment of 4.50 w/o <sup>235</sup>U was considered.

**UO<sub>2</sub> Density:** A  $\pm 2.0\%$  variation about the nominal reference theoretical density was considered.

**Fuel Pellet Dishing:** A variation in fuel pellet dishing fraction from 0.0% to the nominal dishing was considered.

**Storage Cell I.D.:** The  $+0.050/-0.025$  inch tolerance about the nominal 8.75 inch reference cell I.D. was considered.

**Storage Cell Pitch:** The  $+0.12/-0.12$  inch tolerance about the nominal 10.60 inch reference cell pitch was considered.

**Stainless Steel Wall Thickness:** The  $+0.007/ -0.007$  inch tolerance about the nominal 0.075 inch reference stainless steel wall thickness was considered.

**Boraflex Thickness:** A tolerance of  $+0.007/-0.007$  inch about the reference 0.078 inch thickness of Boraflex is included.

**Boraflex Width:** A manufacturing tolerance of  $+0.075/-0.075$  inch around the nominal Boraflex width of 7.5 inches is included.

**Boraflex Length:** Nominal Boraflex length is 139.4 inches with a manufacturing uncertainty of  $+0.25/-0.25$  inch. Based on a previous study, the reactivity variation due to this small tolerance is negligible. No calculation was performed here for this tolerance.

**Wrapper Thickness:** A manufacturing tolerance of  $+0.002/-0.002$  inch around the nominal stainless steel wrapper thickness of 0.02 inch is included.

**Poison Cavity:** The  $+0.010/-0.010$  inch tolerance around the nominal poison cavity thickness of 0.090 inch is included.

**Assembly Position:** The KENO-Va reference reactivity calculation assumed fuel assemblies were symmetrically positioned (centered) within the storage cells. Potentially an increase in reactivity can occur if the corners of the four fuel assemblies were positioned together.

**Calculation Uncertainty:** The 95 percent probability/95 percent confidence level uncertainty on the KENO-Va nominal reference  $K_{eff}$  was considered.

**Methodology Uncertainty:** The 95 percent probability/95 percent confidence uncertainty in the benchmarking bias as determined for the Westinghouse KENO-Va methodology was included ( $0.00300 \Delta K$ ).

These manufacturing tolerances and uncertainties are convoluted and added to the nominal  $K_{eff}$  to arrive at the final  $K_{eff}$  on a 95/95 basis.

This summation is shown in Table 3 on page 19 and results in a 95/95 basis  $K_{eff}$  of 0.96150.

Since  $K_{eff}$  is less than 1.0, the Turkey Point Units 3 and 4 spent fuel racks will remain subcritical under conditions when all cells are loaded with 4.50 w/o  $^{235}\text{U}$  15x15 fuel assemblies with natural uranium axial blankets and no soluble boron is present in the spent fuel pool water. This meets the design basis.

### 3.2 Soluble Boron Credit $K_{eff}$ Calculations

The criterion for defining the boron level, used here is that the  $K_{eff}$  of the racks should be approximately 5% below the value of  $K_{eff}$  for no boron and also below or equal to 0.95. Based on the results of Section 3.1, the target 95/95  $K_{eff}$  is approximately 0.912.

To determine the amount of soluble boron required to maintain the target  $K_{eff}$ , KENO-Va was used to establish a nominal reference reactivity and PHOENIX-P was used to assess the pool temperature bias, the effects of material and construction tolerances, as described in Section 3.1.

The assumptions used to develop the nominal KENO-Va model for soluble boron credit for all cell storage in the Turkey Point Units 3 and 4 spent fuel racks were similar to those in Section 3.1 except for assumption 7 regarding the moderator soluble boron concentration. The moderator was replaced with water containing 450 ppm soluble boron.

With the above assumptions, the KENO-Va calculation for the nominal case with 450 ppm soluble boron in the moderator resulted in a  $K_{eff}$  of  $0.86326 \pm 0.00076$ .

All biases and tolerances are shown in Table 4 on page 20. A final 95/95  $K_{eff}$  was developed by statistical convolution of the individual tolerance impacts and the calculational and methodology uncertainties and then summing this term with the biases and the nominal KENO-Va reference reactivity. The same equation as defined in Section 3.1 is used for the final 95/95  $K_{eff}$ . Summation shown in Table 4 on page 20, results in a 95/95 basis  $K_{eff}$  of 0.90391.

Since  $K_{eff}$  is less than or equal to 0.95 including soluble boron credit and uncertainties at a 95/95 probability/confidence level, the acceptance criteria for criticality is met for all cell storage of 15x15 fuel assemblies in the Turkey Point Units 3 and 4 spent fuel racks. Storage of fuel assemblies with nominal enrichments no greater than 4.50 w/o  $^{235}\text{U}$  with natural uranium axial blankets is acceptable for storage in all cells with the presence of 450 ppm soluble boron.

## 4.0 Criticality Analysis of Region 2 All Cell Spent Fuel Storage

This section describes the analytical techniques and models employed to perform the criticality analysis and reactivity equivalencing evaluations for the storage of fuel in all cells of the Turkey Point Units 3 and 4 Region 2 spent fuel storage racks with credit for soluble boron.

Section 4.1 describes the no soluble boron  $K_{eff}$  calculations. Section 4.2 discusses the results of the spent fuel rack  $K_{eff}$  soluble boron credit calculations. Finally, Section 4.3 presents the results of calculations performed to show the minimum burnup requirements for assemblies with initial enrichments above those determined in Section 4.1.

### 4.1 No Soluble Boron $K_{eff}$ Calculation

For the no soluble boron conditions the 95/95 basis  $K_{eff}$  should be less than 1.0. KENO-Va is used to establish a nominal reference reactivity and PHOENIX-P is used to assess the temperature bias of a normal pool temperature range and the effects of material and construction tolerance variations. A final 95/95  $K_{eff}$  is developed by statistically combining the individual tolerance impacts with the calculational and methodology uncertainties and summing this term with the temperature and method biases and the nominal KENO-Va reference reactivity. The equation for determining the final 95/95  $K_{eff}$  is defined in Reference 1 and is shown below:

$$K_{eff} = K_{nominal} + B_{method} + B_{temp} + B_{self} + B_{uncert}$$

where:

- $K_{nominal}$  = nominal conditions KENO-Va  $K_{eff}$
- $B_{method}$  = method bias determined from benchmark critical comparisons
- $B_{temp}$  = temperature bias
- $B_{self}$  =  $^{10}\text{B}$  self shielding bias, if applicable.
- $B_{uncert}$  = statistical summation of uncertainty components  
=  $[\text{Sum}\{\text{tolerance}(i)^2 \dots \text{or} \dots \text{uncertainty}(i)\}^2]^{**1/2}$

Following assumptions were used to develop the no soluble boron nominal KENO-Va model for storage of fuel assemblies in all cells of the Turkey Point Units 3 and 4 spent fuel storage racks:

1. The fuel assembly parameters relevant to the criticality analysis were based on the Westinghouse 15x15 DRFA fuel design (see Table 1 on page 17 for fuel parameters).
2. Fuel assemblies contain uranium dioxide at a nominal enrichment of 1.60 w/o  $^{235}\text{U}$  over the entire length of each rod.
3. The fuel pellets were modeled assuming nominal values for theoretical density and dishing fraction.
4. No credit was taken for any natural or reduced enrichment axial blankets.
5. No credit was taken for any  $^{234}\text{U}$  or  $^{236}\text{U}$  in the fuel, nor was any credit taken for the buildup of fission product poison material.
6. No credit was taken for any grids in the assembly.
7. No credit was taken for any burnable absorber in the fuel rods.
8. Credit was taken for the presence of spent fuel rack Boraflex poison panels.  $^{10}\text{B}$  areal density of  $0.012 \text{ gm/cm}^2$  was used.
9. The moderator was water with 0 ppm soluble boron at a temperature of  $68^\circ\text{F}$ . A water density of  $1.0 \text{ gm/cm}^3$  was used.
10. The array was infinite in lateral (x and y) extent and finite in axial (vertical) extent.
11. Fuel storage cells were loaded with fuel assemblies in all cell arrangement.

Fuel assembly data is shown in Table 1 on page 17. Dimensions for the Region 2 fuel racks are shown in Table 5 on page 21 and the cell arrangement is shown in Figure 2 on page 27.

With the above assumptions, the nominal KENO-Va calculation resulted in a  $K_{\text{eff}}$  of  $0.94785 \pm 0.00042$  under normal conditions.

Following biases were included:

**Methodology:** The benchmarking bias as determined for the Westinghouse KENO-Va methodology was considered.

**Water Temperature:** A reactivity bias determined in PHOENIX-P was applied to account for the effect of the normal range of spent fuel pool water temperatures ( $50^\circ\text{F}$  to  $185^\circ\text{F}$ ).

**Particle Size Effect in Boraflex:** A bias on reactivity resulting from the finite particle size of the boron bearing compound in Boraflex panels.

All biases are shown in Table 6 on page 22. To evaluate the reactivity effects of possible variations in material characteristics and mechanical/construction dimensions, PHOENIX-P perturbation calculations were performed. For the Turkey Point Units 3 and 4 spent fuel rack all configuration,  $\text{UO}_2$  material tolerances were considered along with construction tolerances. Uncertainties associated with calculation and methodology accuracy were also considered in the statistical summation of uncertainty components. Nominal values are shown in Table 5 on page 21 and manufacturing tolerances and uncertainties are shown in Table 6 on page 22.

The following tolerance and uncertainty components were considered in the total uncertainty statistical summation:

**$^{235}\text{U}$  Enrichment:** The standard DOE enrichment tolerance of  $\pm 0.05$  w/o  $^{235}\text{U}$  about the nominal reference enrichment of 1.60 w/o  $^{235}\text{U}$  was considered.

**$\text{UO}_2$  Density:** A  $\pm 2.0\%$  variation about the nominal reference theoretical density was considered.

**Fuel Pellet Dishing:** A variation in fuel pellet dishing fraction from 0.0% to the nominal dishing.

**Storage Cell I.D.:** The  $+0.025/-0.025$  inch tolerance about the nominal 8.80 inch reference cell I.D. was considered.

**Storage Cell Pitch:** The  $+0.07/-0.03$  inch tolerance about the nominal 9.0 inch reference cell pitch was considered.

**Stainless Steel Wall Thickness:** The  $+0.007/-0.007$  inch tolerance about the nominal 0.075 inch reference stainless steel wall thickness was considered.

**Boraflex Thickness:** A tolerance of  $+0.007/-0.007$  inch about the reference 0.051 inch thickness of Boraflex is included.

**Boraflex Width:** A manufacturing tolerance of  $+0.075/-0.075$  inch around the nominal Boraflex width of 7.5 inches is included.

**Boraflex Length:** Nominal Boraflex length is 139.4 inches with a manufacturing uncertainty of  $+0.25/-0.25$  inch. Based on a previous study, the reactivity variation due to this small tolerance is negligible. No calculation was performed here for this tolerance.

**Wrapper Thickness:** A manufacturing tolerance of  $+0.002/-0.002$  inch around the nominal stainless steel wrapper thickness of 0.02 inch is included.

**Assembly Position:** The KENO-Va reference reactivity calculation assumed fuel assemblies were symmetrically positioned (centered) within the storage cells. Potentially an increase in reactivity can occur if the corners of the four fuel assemblies were positioned together.

**Calculation Uncertainty:** The 95 percent probability/95 percent confidence level uncertainty on the KENO-Va nominal reference  $K_{\text{eff}}$  was considered.

**Methodology Uncertainty:** The 95 percent probability/95 percent confidence uncertainty in the benchmarking bias as determined for the Westinghouse KENO-Va methodology was considered.

These manufacturing tolerances and uncertainties are convoluted and added to the nominal  $K_{\text{eff}}$  to arrive at the final  $K_{\text{eff}}$  on a 95/95 basis.

This summation is shown in Table 6 on page 22 and results in a 95/95 basis  $K_{\text{eff}}$  of 0.97217.

Since  $K_{\text{eff}}$  is less than 1.0, the Turkey Point Units 3 and 4 spent fuel racks will remain subcritical when all cells are loaded with nominal 1.60 w/o  $^{235}\text{U}$  15x15 fuel assemblies and no soluble boron is present in the spent fuel pool water. This meets the design basis.

## 4.2 Soluble Boron Credit $K_{eff}$ Calculations

The criterion for defining the boron level, used here is that the  $K_{eff}$  of the racks should be approximately 5% below the value of  $K_{eff}$  for no boron and also below or equal to 0.95. Based on the results of Section 4.1, the target  $K_{eff}$  is approximately 0.922.

To determine the amount of soluble boron required to maintain the target  $K_{eff}$ , KENO-Va was used to establish a nominal reference reactivity and PHOENIX-P was used to assess the pool temperature bias, the effects of material and construction tolerances, as described in Section 4.1.

The assumptions used to develop the nominal KENO-Va model for soluble boron credit for all cell storage in the Turkey Point Units 3 and 4 spent fuel racks were similar to those in Section 4.1 except for assumption 9 regarding the moderator soluble boron concentration. The moderator was replaced with water containing 250 ppm soluble boron.

With the above assumptions, the KENO-Va calculation for the nominal case with 250 ppm soluble boron in the moderator resulted in a  $K_{eff}$  of  $0.89088 \pm 0.00040$ .

All biases and tolerances are shown in Table 7 on page 23. A final 95/95  $K_{eff}$  was developed by statistical convolution of the individual tolerance impacts and the calculational and methodology uncertainties and then summing this term with the biases and the nominal KENO-Va reference reactivity. The same equation as defined in Section 4.1 is used for the final 95/95  $K_{eff}$ . The summation is shown in Table 7 on page 23 and results in a 95/95 basis  $K_{eff}$  of 0.91663.

Since  $K_{eff}$  is less than or equal to 0.95 including soluble boron credit and uncertainties at a 95/95 probability/confidence level, the acceptance criteria for criticality is met for all cell storage of 15x15 fuel assemblies with nominal enrichments no greater than 1.60 w/o  $^{235}\text{U}$  in the Turkey Point Units 3 and 4 spent fuel racks with the presence of 250 ppm soluble boron.

## 4.3 Burnup Credit Reactivity Equivalencing

Storage of fuel assemblies with initial enrichments higher than 1.60 w/o  $^{235}\text{U}$  in all cells of the Turkey Point Units 3 and 4 spent fuel racks is achievable by means of burnup credit using reactivity equivalencing. The concept of reactivity equivalencing is based on the reactivity decrease associated with fuel depletion. For burnup credit, a series of reactivity calculations is performed to generate a set of enrichment-fuel assembly discharge burnup ordered pairs which all yield an equivalent  $K_{eff}$  when stored in the spent fuel storage racks.

Figure 4 on page 29 shows the constant  $K_{eff}$  contours generated for all cell storage in the Turkey Point Units 3 and 4 spent fuel racks. This curve represents combinations of fuel enrichment and discharge burnup which yield the same rack multiplication factor ( $K_{eff}$ ) as the rack loaded with 1.60 w/o  $^{235}\text{U}$  fuel assemblies at zero burnup in all cell locations.

Uncertainties associated with burnup credit include a reactivity uncertainty of  $0.01 \Delta K$  at 30,000 MWD/MTU applied linearly to the burnup credit requirement to account for calculation and depletion uncertainties and 5% on the calculated burnup to account for burnup measurement

uncertainty. The amount of additional soluble boron needed to account for these uncertainties in the burnup requirement of Figure 4 on page 29 was 400 ppm. This is additional boron above the 250 ppm required in Section 4.2. This results in a total soluble boron requirement of 650 ppm.

It is important to recognize that the curve in Figure 4 on page 29 is based on calculations of constant rack reactivity. In this way, the environment of the storage rack and its influence on assembly reactivity is implicitly considered. For convenience, the data from Figure 4 on page 29 are also provided in Table 9 on page 25. Use of linear interpolation between the tabulated values is acceptable since the curve shown in Figure 4 on page 29 is linear in between the tabulated points.

The effect of axial burnup distribution on assembly reactivity has been considered in the development of the Turkey Point Units 3 and 4 all cell storage burnup credit limit. Previous evaluations have been performed to quantify axial burnup reactivity effects and to confirm that the reactivity equivalencing methodology described in Reference 1 results in calculations of conservative burnup credit limits. The evaluations show that axial burnup effects only become important at burnup-enrichment combinations which are above those calculated for the Turkey Point Units 3 and 4 all cell storage burnup credit limit. Therefore, additional accounting of axial burnup distribution effects in the Turkey Point Units 3 and 4 all cell storage burnup credit limit is not necessary.

## 5.0 Discussion of Postulated Accidents in the Spent Fuel Pool

Most accident conditions will not result in an increase in  $K_{eff}$  of the rack. Examples are:

- |   |   |
|---|---|
| <b>Fuel assembly drop on top of rack</b>  | The rack structure pertinent for criticality is not excessively deformed and the dropped assembly which comes to rest horizontally on top of the rack has sufficient water separating it from the active fuel height of stored assemblies to preclude neutronic interaction.  |
| <b>Fuel assembly drop between rack modules or between rack modules and spent fuel pool wall</b> | The design of the spent fuel racks and fuel handling equipment is such that it precludes the insertion of a fuel assembly between rack modules. However, it is possible that a fuel assembly can be positioned between the rack modules and the spent fuel pool wall. The reactivity increase caused by this incident is bounded by the misplacement of a fuel assembly inside the spent fuel racks where it does not meet the enrichment or burnup restrictions. |

However, two accidents can be postulated for each storage configuration which can increase reactivity beyond the analyzed condition. The first postulated accident would be a change in the spent fuel pool water temperature and the second would be a misload of an assembly into a cell for which the restrictions on enrichment or burnup are not satisfied.

### Loss of Cooling Accident

For the change in spent fuel pool water temperature accident (due to loss of cooling), a temperature range of 32°F to 240°F is considered. Calculations were performed for all Turkey Point Units 3 and 4 storage configurations to determine the reactivity change caused by a change in the spent fuel pool water temperature outside the normal range (50°F to 185°F). The results of these calculations are tabulated in Table 8 on page 24 for both Regions 1 and 2.

### Assembly Misloaded Accident

The misloaded assembly accident addresses the largest reactivity increase caused by a 4.50 w/o enriched 15x15 unirradiated fuel assembly misplaced into a storage cell for which the restrictions on enrichment or burnup are not satisfied. For Region 1, there are no restrictions on assembly burnup for placing the assemblies in an all cell configuration. Consequently, this accident is not relevant to Region 1. For Region 2, the accidental placement of a high reactivity assembly (4.5% enrichment and no burnup) in the all cell configuration can lead to a reactivity increase. The results of these calculations are also tabulated in Table 8. It shows the increase in the soluble boron level required to assure that with this accidental misload, the target reactivity with boron is still met.

## Boron Dilution

Further it has been shown in a companion report that the time and quantities of water to dilute the boron in the pool to the normal boron levels meet the design criterion.

For an occurrence of the above postulated accident conditions, the double contingency principle of ANSI/ANS-8.1-1983<sup>(5)</sup> can be applied. It specifies that assumption of two unlikely, independent, concurrent events need not be considered to ensure protection against a criticality accident. Dilution of boron in water and misload of an assembly are two independent accidents. Thus, for these postulated accident conditions, the presence of additional soluble boron in the storage pool water (above the concentration required for normal conditions and reactivity equivalencing) can be assumed as a realistic initial condition.

Based on the above discussion, should a loss of spent fuel pool cooling accident or a fuel assembly misload occur in the Turkey Point Units 3 and 4 spent fuel racks,  $K_{eff}$  will be maintained below the target level as well as less than or equal to 0.95 with the presence of at least 1100 ppm of soluble boron in the spent fuel pool.

## **6.0 Soluble Boron Credit Summary**

Spent fuel pool soluble boron has been used in this criticality analysis to offset storage rack and fuel assembly tolerances, calculational uncertainties, uncertainty associated with reactivity equivalencing (burnup credit) and the reactivity increase caused by postulated accident conditions. The total soluble boron concentration required to be maintained in the spent fuel pool is a summation of each of these components. Table 8 on page 24 summarizes the storage configurations and corresponding soluble boron credit requirements.

## 7.0 Summary of Criticality Results

For the storage of Westinghouse 15x15 fuel assemblies in the Turkey Point Units 3 and 4 spent fuel storage racks, the acceptance criteria for criticality requires the effective neutron multiplication factor,  $K_{eff}$ , to be  $< 1.0$  with all tolerances and uncertainties with no soluble boron, and  $\leq 0.95$  including uncertainties, tolerances and accident conditions in the presence of spent fuel pool soluble boron.

This report shows that the acceptance criteria for criticality is met for the Turkey Point Units 3 and 4 spent fuel racks for the storage of Westinghouse 15x15 fuel assemblies under both normal and accident conditions with enrichment limits tabulated below.

### Enrichment Limits

#### **All Cell Storage in Spent Fuel Pool in Region 1**

Storage of 15x15 fuel assemblies in any cell location. Fuel assemblies must have an initial nominal enrichment no greater than 4.50 w/o  $^{235}\text{U}$  and have 6 inches of natural uranium blanket at top and bottom. The soluble boron credit required for this storage configuration is 450 ppm.

#### **All Cell Storage in Spent Fuel Pool in Region 2**

Storage of 15x15 fuel assemblies in any cell location. Fuel assemblies must have an initial nominal enrichment no greater than 1.6 w/o or satisfy a minimum burnup requirement for higher initial enrichments. The soluble boron credit required for this storage configuration is 650 ppm.

Soluble boron level needed in the spent fuel pool for normal and accident conditions are shown in Table 8 on page 24.

The analytical methods employed herein conform to ANSI N18.2-1973, "Nuclear Safety Criteria for the Design of Stationary Pressurized Water Reactor Plants", Section 5.7 Fuel Handling System; ANSI 57.2-1983, "American Nuclear Society, American National Standard Design Requirements for Light Water Reactor Spent Fuel Storage Facilities at Nuclear Power Plants", Section 6.4.2; ANSI 8.1-1983, "Validation of Calculational Methods for Nuclear Criticality Safety"; the NRC Standard Review Plan<sup>(4)</sup>, Section 9; and the NRC approved Westinghouse criticality topical report "Westinghouse Spent Fuel Rack Criticality Analysis Methodology"<sup>(1)</sup>.

**Table 1. Nominal Fuel Parameters Employed in the Criticality Analysis**

<b>Parameter</b>	<b>Westinghouse 15x15 DRFA</b>
Number of Fuel Rods per Assembly	204
Rod Clad O.D. (inch)	0.422
Clad Thickness (inch)	0.0243
Fuel Pellet O.D. (inch)	0.3659
Fuel Pellet Density (% of Theoretical)	96
Fuel Pellet Dishing Factor (%)	1.187
Rod Pitch (inch)	0.563
Number of Zirc Guide Tubes	20
Guide Tube O.D. (inch)	0.533
Guide Tube Thickness (inch)	0.017
Number of Instrument Tubes	1
Instrument Tube O.D. (inch)	0.533
Instrument Tube Thickness (inch)	0.017

**Table 2. Turkey Point 3 and 4 Region 1 Spent Fuel Storage Cell and Fuel Nominal Parameters**

<b>Rack Parameter</b>	<b>Unit</b>	<b>Value</b>
Rack Cell Inner Dimension	inch	8.75
Rack Cell Pitch	inch	10.60
Rack Material		SS
Rack Wall Thickness	inch	0.075
Wrapper Material		SS
Wrapper Plate Thickness	inch	0.020
Poison Panel Thickness	inch	0.078
Poison Cavity Thickness	inch	0.090
Poison Panel Width	inch	7.5
Poison Panel Length	inch	139.4
<sup>10</sup> B Loading in Boraflex	gm/cm <sup>2</sup>	0.020
Bottom of Boraflex Above Support Pad	inch	6.16
<b>Fuel Parameter</b>		
Axial Blanket at Each End of the Rods	inch	6.0
Blanket Material		Natural Uranium
Nominal Fuel Enrichment of the Central Length	%	4.5
Blanket Region Enrichment	%	0.79
Theoretical Density	%	96

**Table 3. Region 1 - No Soluble Boron**

<b>Base Keno Reference Reactivity</b>		<b>0.93970</b>
<b>Calculation and Methodology Biases</b>		
	<b>Range</b>	
Methodology (Benchmark) Bias		0.00770
Pool Temperature Bias	50 F to 185 F	0.00111
Boron Particles in Boraflex		<u>0.00140</u>
Total Bias		0.01021
<b>Tolerances and Uncertainties</b>		
	<b>Parameter Variation</b>	<b>Reactivity Variation</b>
Fuel Enrichment	+0.05/-0.05 %	0.00184
Fuel Density	+2/-2 %	0.00255
Fuel Pellet Dishing	-1.187 %	0.00148
Rack Cell Inner Dimension	+0.05/-0.025 inch	0.00204
Rack Cell Pitch	+0.12/-0.12 inch	0.00950
Rack Wall Thickness	+0.007/-0.007 inch	0.00031
Wrapper Plate Thickness	+0.002/-0.002 inch	0.00000
Poison Panel Thickness	+0.007/-0.007 inch	0.00251
Poison Cavity Thickness —	+0.010/-0.010 inch	0.00001
Poison Panel Width	+0.075/-0.075 inch	0.00020
Asymmetric Assembly Position		0.00325
Calculation Uncertainty		0.00134
Benchmark Bias Uncertainty		<u>0.00300</u>
Total Uncertainty (convoluted)		0.01159
<b>Final <math>K_{eff}</math> on 95/95 Basis</b>		<b>0.96150</b>

**Table 4. Region 1 - With Soluble Boron (450 ppm)**

<b>Base Keno Reference Reactivity</b>		<b>0.88326</b>
<b>Calculation and Methodology Biases</b>	<b>Range</b>	
Methodology (Benchmark) Bias		0.00770
Pool Temperature Bias	50 F to 185 F	0.00084
Boron Particles in Boraflex		<u>0.00140</u>
Total Bias		0.00994
<b>Tolerances and Uncertainties</b>	<b>Parameter Variation</b>	<b>Reactivity Variation</b>
Fuel Enrichment	+0.05/-0.05 %	0.00206
Fuel Density	+2/-2 %	0.00312
Fuel Pellet Dishing	-1.187 %	0.00181
Rack Cell Inner Dimension	+0.05/-0.025 inch	0.00169
Rack Cell Pitch	-0.12 inch	0.00886
Rack Wall Thickness	+0.007/-0.007 inch	0.00014
Wrapper Plate Thickness	+0.002/-0.002 inch	0.00000
Poison Panel Thickness	+0.007/-0.007 inch	0.00228
Poison Cavity Thickness	+0.010/-0.010 inch	0.00001
Poison Panel Width	+0.075/-0.075 inch	0.00018
Asymmetric Assembly Position		0.00045
Calculation Uncertainty		0.00125
Benchmark Bias Uncertainty		<u>0.00300</u>
Total Uncertainty (convoluted)		0.01071
<b>Final <math>K_{eff}</math> on 95/95 Basis</b>		<b>0.90391</b>

**Table 5. Turkey Point 3 and 4 Region 2 Spent Fuel Storage Cell Nominal Parameters**

<b>Parameter</b>	<b>Unit</b>	<b>Value</b>
Rack Cell Inner Dimension	inch	8.80
Rack Cell Pitch	inch	9.0
Rack Material		SS
Rack Wall Thickness	inch	0.075
Wrapper Material		SS
Wrapper Plate Thickness	inch	0.020
Poison Panel Thickness	inch	0.051
Poison Cavity Thickness	inch	0.090
Poison Panel Width	inch	7.5
Poison Panel Length	inch	139.4
<sup>10</sup> B Loading in Boraflex	gm/cm <sup>2</sup>	0.012
Bottom of Boraflex Above Support Pad	inch	6.16

**Table 6. Region 2 - No Soluble Boron**

<b>Base Keno Reference Reactivity</b>		<b>0.94785</b>
<b>Calculation and Methodology Biases</b>	<b>Range</b>	
Methodology (Benchmark) Bias		0.00770
Pool Temperature Bias	50 F to 185 F	0.00140
Boron Particles in Boraflex		<u>0.00317</u>
Total Bias		0.01227
<b>Tolerances and Uncertainties</b>	<b>Parameter Variation</b>	<b>Reactivity Variation</b>
Fuel Enrichment	+0.05/-0.05 %	0.00959
Fuel Density	+2/-2 %	0.00272
Fuel Pellet Dishing	-1.187 %	0.00134
Rack Cell Inner Dimension	+0.025/-0.025 inch	0.00000
Rack Cell Pitch	+0.07/-0.03 inch	0.00092
Rack Wall Thickness	+0.007/-0.007 inch	0.00000
Wrapper Plate Thickness	+0.002/-0.002 inch	0.00000
Poison Panel Thickness	+0.007/-0.007 inch	0.00579
Poison Cavity Thickness	+0.010/-0.010 inch	0.00000
Poison Panel Width	+0.075/-0.075 inch	0.00055
Asymmetric Assembly Position -	-	0.00000
Calculation Uncertainty		0.00069
Benchmark Bias Uncertainty		<u>0.00300</u>
Total Uncertainty (convoluted)		0.01205
<b>Final <math>K_{eff}</math> on 95/95 Basis</b>		<b>0.97217</b>

**Table 7. Region 2 - With Soluble Boron (250 ppm)**

<b>Base Keno Reference Reactivity</b>		<b>0.89088</b>
<b>Calculation and Methodology Biases</b>	<b>Range</b>	
Methodology (Benchmark) Bias		0.00770
Pool Temperature Bias	50 F to 185 F	0.00164
Boron Particles in Boraflex		<u>0.00317</u>
Total Bias		0.01251
<b>Tolerances and Uncertainties</b>	<b>Parameter Variation</b>	<b>Reactivity Variation</b>
Fuel Enrichment	+0.05/-0.05 %	0.01037
Fuel Density	+2/-2 %	0.00383
Fuel Pellet Dishing	-1.187 %	0.00223
Rack Cell Inner Dimension	+0.025/-0.025 inch	0.00015
Rack Cell Pitch	+0.07/-0.03 inch	0.00158
Rack Wall Thickness	+0.007/-0.007 inch	0.00020
Wrapper Plate Thickness	+0.002/-0.002 inch	0.00001
Poison Panel Thickness	+0.007/-0.007 inch	0.00592
Poison Cavity Thickness	+0.010/-0.010 inch	0.00004
Poison Panel Width	+0.075/-0.075 inch	0.00102
Asymmetric Assembly Position	+0.07/-0.03 inch	0.00000
Calculation Uncertainty		0.00066
Benchmark Bias Uncertainty		<u>0.00300</u>
Total Uncertainty (convoluted)		0.01324
<b>Final <math>K_{eff}</math> on 95/95 Basis</b>		<b>0.91663</b>


**Table 8. Spent Fuel Pool Soluble Boron Requirements**

<b>Region</b>	<b>Normal (ppm)</b>	<b>For Loss of Cooling (ppm)</b>	<b>For Misloaded Assembly (ppm)</b>	<b>Soluble Boron for Accidents (ppm)</b>
1	450	50	0	500
2	650	< 450	450	1100
Pool	650			1100

**Table 9. Burnup Needed for Fuel Storage in Region 2 of the Spent Fuel Pool**

<b>Enrichment (%)</b>	<b>Burnup (MWD/MTU)</b>
1.60	0.0
1.80	3706
2.00	7459
2.20	9724
2.40	12582
2.60	15338
2.63	15914
2.80	17994
3.00	20548
3.25	23312
3.40	25354
3.60	27605
3.88	30256
4.00	31804
4.20	33752
4.40	35599
4.50	36746

Figure 1. Turkey Point Units 3 and 4 Region 1 Spent Fuel Pool Storage Cell  
Nominal Dimensions



**Figure 2. Turkey Point Units 3 and 4 High Density Spent Fuel Pool Storage Cell (Region 2)  
Nominal Dimensions**




Figure 3. Degraded Boraflex Panel  
(Not to Scale)





Figure 4. Turkey Point Units 3 and 4 High Density All Cell Configuration Burnup Credit Requirements (Region 2)



# Bibliography

1. Newmyer, W.D., *Westinghouse Spent Fuel Rack Criticality Analysis Methodology*, WCAP-14416, -NP-A, Revision 1, November 1996.
2. American Nuclear Society, *American National Standard Design Requirements for Light Water Reactor Spent Fuel Storage Facilities at Nuclear Power Plants*, ANSI/ANS-57.2-1983, October 7, 1983.
3. Nuclear Regulatory Commission, Letter to All Power Reactor Licensees from B. K. Grimes, *OT Position for Review and Acceptance of Spent Fuel Storage and Handling Applications*, April 14, 1978.
4. U.S. Nuclear Regulatory Commission, Standard Review Plan, NUREG-0800, July 1981.
5. American Nuclear Society, *American National Standard for Nuclear Criticality Safety in Operation with Fissionable Materials Outside Reactors*, ANSI/ANS-8.1-1983, October 7, 1983.

L-99-176  
Attachment 5

**ATTACHMENT 5**

**Criticality Analysis with Reduced B<sup>10</sup> Loading in the Degraded Boraflex  
For Regions I and II Spent Fuel Storage**

**Criticality Analysis With a Reduced B<sup>10</sup> Loading in the Degraded Boraflex  
for Turkey Point Units 3 & 4 Region 1 and Region 2 Spent Fuel All Cell Storage  
(No Soluble Boron)**

October , 1999



S. Srinilta (ND)

Core Analysis B

Date: 10/5/99

Verified:



J. Secker (ND)

Core Analysis C

Date: 10/5/99

**Criticality Analysis With a Reduced B<sup>10</sup> Loading in the Degraded Boraflex  
for Turkey Point Units 3 & 4 Region 1 and Region 2 Spent Fuel All Cell Storage  
(No Soluble Boron)**

A criticality analysis was performed with a reduced B<sup>10</sup> loading in the degraded boraflex for Turkey Point Units 3 & 4 Region 1 and Region 2 spent fuel all cell storage (No Soluble Boron). The methodology and assumptions used in the analysis are the same as in Reference 1 except that the absorber B<sup>10</sup> loading and its thickness are reduced to 0.009 g/cm<sup>2</sup> and 0.0351 inch for Region 1 and 0.0006 g/cm<sup>2</sup> and 0.051 inch (remain unchanged) for Region 2. For Region 1, the reduction of both the B<sup>10</sup> loading and the corresponding thickness is slightly more limiting than the reduction of the B<sup>10</sup> loading only. For Region 2, the reduction of the B<sup>10</sup> loading only is slightly more limiting than the reduction of the B<sup>10</sup> loading and the corresponding thickness. The final 95/95 Keff is shown in the attached Table 1 and Table 2 for spent fuel rack Region 1 and Region 2, respectively. Since both Keff's are still less than 1.0, the Turkey Point Units 3 and 4 spent fuel racks will remain subcritical when all cells are loaded 15x15 fresh fuel assemblies with nominal enrichments no greater than 4.50 w/o U<sup>235</sup> with natural uranium axial blankets in Region 1, and with nominal enrichments no greater than 1.60 w/o in Region 2. This meets the design basis for no soluble boron water in the pool.

Reference: 1) 99FP-G-0071 Criticality for Spent Fuel Storage for Turkey Point Units 3 & 4  
(Degraded Boraflex)

**Table 1. Region 1 - No Soluble Boron**

<b>Base Keno Reference Reactivity</b>		<b>0.97155</b>
<b>Calculation and Methodology Biases</b>	<b>Range</b>	
Methodology (Benchmark) Bias		0.00770
Pool Temperature Bias	50 F to 185 F	0.00077
Boron Particles in Boraflex		<u>0.00384</u>
Total Bias		0.01231
<b>Tolerances and Uncertainties</b>	<b>Parameter Variation</b>	<b>Reactivity Variation</b>
Fuel Enrichment	+0.05/-0.05 %	0.00191
Fuel Density	+2/-2 %	0.00250
Fuel Pellet Dishing	-1.187 %	0.00145
Rack Cell Inner Dimension	+0.05/-0.025 inch	0.00153
Rack Cell Pitch	+0.12/-0.12 inch	0.01022
Rack Wall Thickness	+0.007/-0.007 inch	0.00024
Wrapper Plate Thickness	+0.002/-0.002 inch	0.00000
Poison Panel Thickness	+0.007/-0.007 inch	0.00973
Poison Cavity Thickness	+0.010/-0.010 inch	0.00004
Poison Panel Width	+0.075/-0.075 inch	0.00047
Asymmetric Assembly Position		0.00534
Calculation Uncertainty		0.00129
Benchmark Bias Uncertainty		<u>0.00300</u>
Total Uncertainty (convoluted)		0.01590
<b>Final <math>K_{eff}</math> on 95/95 Basis</b>		<b>0.99976</b>

**Table 2. Region 2 - No Soluble Boron**

<b>Base Keno Reference Reactivity</b>		<b>0.97383</b>
<b>Calculation and Methodology Biases</b>	<b>Range</b>	
Methodology (Benchmark) Bias		0.00770
Pool Temperature Bias	50 F to 185 F	0.00103
Boron Particles in Boraflex		<u>0.00450</u>
Total Bias		0.01323
<b>Tolerances and Uncertainties</b>	<b>Parameter Variation</b>	<b>Reactivity Variation</b>
Fuel Enrichment	+0.05/-0.05 %	0.00972
Fuel Density	+2/-2 %	0.00254
Fuel Pellet Dishing	-1.187 %	0.00116
Rack Cell Inner Dimension	+0.025/-0.025 inch	0.00000
Rack Cell Pitch	+0.07/-0.03 inch	0.00116
Rack Wall Thickness	+0.007/-0.007 inch	0.00000
Wrapper Plate Thickness	+0.002/-0.002 inch	0.00000
Poison Panel Thickness	+0.007/-0.007 inch	0.00582
Poison Cavity Thickness	+0.010/-0.010 inch	0.00000
Poison Panel Width	+0.075/-0.075 inch	0.00026
Asymmetric Assembly Position		0.00000
Calculation Uncertainty		0.00041
Benchmark Bias Uncertainty		<u>0.00300</u>
Total Uncertainty (convoluted)		0.01213
<b>Final <math>K_{eff}</math> on 95/95 Basis</b>		<b>0.99919</b>

L-99-176  
Attachment 6

**ATTACHMENT 6**

**Turkey Point Units 3 and 4  
Spent Fuel Pool Dilution Analysis**

**TURKEY POINT UNITS 3 AND 4  
SPENT FUEL POOL DILUTION ANALYSIS**

Prepared By: Gary J. Corpora 11/17/99  
Gary J. Corpora, Fluid Systems Engineering

Verified By: Kenneth P. Slaby 11/17/99  
Kenneth P. Slaby, Fluid Systems Engineering

**Rev. 0**

**November 17, 1999**

## Table of Contents

Section	Page
1.0 INTRODUCTION	1
2.0 SPENT FUEL POOL AND RELATED SYSTEM FEATURES	2
2.1 Spent Fuel Pool	2
2.2 Spent Fuel Storage Racks	3
2.3 Spent Fuel Pool Cooling System	3
2.4 Spent Fuel Pool Cleanup System	4
2.5 Dilution Sources	4
2.6 Boration Sources	8
2.7 Spent Fuel Pool Instrumentation	9
2.8 Administrative Controls	9
2.9 Piping	10
2.10 Loss of Offsite Power Impact	10
3.0 SPENT FUEL POOL DILUTION EVALUATION	11
3.1 Calculation of Boron Dilution Times and Volumes	11
3.2 Evaluation of Boron Dilution Events	12
3.3 Summary of Dilution Events	15
4.0 CONCLUSIONS	17
5.0 REFERENCES	19
FIGURES	
FIGURE 1 - Spent Fuel Pool and Related Systems	20
FIGURE 2 - Spent Fuel Pit Plan View	21
FIGURE 3 - Spent Fuel Pool Fluid Mixing	21

## **1.0 INTRODUCTION**

A boron dilution analysis has been completed for crediting boron in the Turkey Point Units 3 and 4 spent fuel rack criticality analysis. The boron dilution analysis includes an evaluation of the following plant specific features:

- Dilution Sources
- Boration Sources
- Instrumentation
- Administrative Procedures
- Piping
- Loss of Offsite Power Impact
- Boron Dilution Initiating Events
- Boron Dilution Times and Volumes

The boron dilution analysis was completed to ensure that sufficient time is available to detect and mitigate the dilution before the spent fuel rack criticality analysis  $0.95 k_{eff}$  design basis is exceeded.

## **2.0 SPENT FUEL POOL AND RELATED SYSTEM FEATURES**

This section provides background information on the spent fuel pool and its related systems and features. A one-line diagram of the spent fuel pool related systems is provided as Figure 1. For the purposes of this evaluation, the spent fuel pool and its related systems are sufficiently similar between the two Units that they will be treated as identical. Any significant differences will be identified, so that this report will be bounding for both Units.

### **2.1 Spent Fuel Pool**

The design purpose of the spent fuel pool is to provide for the safe storage of irradiated fuel assemblies. The pool is filled with borated water. The water removes decay heat, provides shielding for personnel handling the fuel, and reduces the amount of radioactive gases released during a fuel handling accident. Pool water evaporation takes place on a continuous basis, requiring periodic makeup. The makeup source can be unborated water, since the evaporation process does not carry off the boron. Evaporation actually increases the boron concentration in the pool.

The spent fuel pool is a reinforced concrete structure with a minimum ¼" inch welded steel liner. The water-tight liner has dedicated drain lines to collect and detect liner leakage. The pool structure is designed to meet seismic requirements. The pool is approximately 38 feet deep. The top of the pit is located on the 58' elevation of the fuel handling building. The bottom of the pit is approximately at the 18' elevation.

In the event of excessive makeup flow into the pool, the pool would overflow onto the floor. There are no floor drains. Water would slowly drain into the transfer canal through metal covers which are not water-tight. The transfer canal is normally isolated from the SFP and empty. If the makeup rates exceeds the drain rate into the canal, the water level would rise approximately 3" to the bottom of the room door. Water would seep through the normally closed door to the outside roof of the fuel building. The open transfer canal and leakage through the room door minimize the effect of pool dilution sources, if any, from the floor elevation level.

As shown in Figure 2, the transfer canal lies adjacent to the pool and connects to the reactor refueling water cavity during refueling operations. The gates between the pool and the transfer canal are

normally closed. The volume of the pit is approximately 39,946 ft<sup>3</sup> to the Tech Spec minimum level elevation of 56'-10" less instrument accuracy. The majority of the water volume displaced by objects in the pit is by the spent fuel assemblies. The maximum number of assembly locations is 1404. The volume of all 1404 assemblies (3707 ft<sup>3</sup>) is subtracted from the total pit volume. The racks themselves occupy a relatively small volume(403 ft<sup>3</sup>), but they are subtracted as well. Finally, it is assumed that a spent fuel cask is loaded into the pit, which displaces a small volume(429 ft<sup>3</sup>). When the above volumes are subtracted from the pit volume, the remaining water volume (35,407 ft<sup>3</sup> = 264,845 gal.) is conservatively rounded down to 264,000 gallons.

## **2.2 Spent Fuel Storage Racks**

The spent fuel racks are designed to support and protect the spent fuel assemblies under normal and credible accident conditions. Their design ensures the ability to withstand combinations of dead loads, live loads (fuel assemblies), and seismic loads.

## **2.3 Spent Fuel Pool Cooling System**

The spent fuel pool cooling system is designed to remove the heat generated by stored spent fuel elements from the spent fuel pool. The system design incorporates redundancy for the only active component, the spent fuel pool cooling pump. System piping is configured so that failure of any pipeline in the cooling system does not drain the spent fuel pool below the top of the stored spent fuel assemblies.

The portion of the spent fuel pool cooling system which, if it failed, could result in a significant release of pool water is seismically designed.

The cooling system train consists of redundant pumps, a heat exchanger, valves, piping and instrumentation. The pump takes suction from the fuel pool at an inlet located below the pool water level, transfers the pool water through a heat exchanger and returns it back into the pool through an outlet located below and a large distance away from the cooling system inlet. The return line is designed to prevent siphoning. The heat exchangers are cooled by component cooling water.

## **2.4 Spent Fuel Pool Cleanup System**

The spent fuel pool cleanup system is designed to maintain water clarity and to control borated water chemistry. The cleanup system is connected to the spent fuel pool cooling system. About 100 gpm of the spent fuel pool cooling pump(s) discharge flow can be diverted to the cleanup loop, which includes the spent fuel pool demineralizer and filters. The filters remove particulates from the spent fuel pool water and the spent fuel pool demineralizer removes ionic impurities.

The refueling water purification loop also uses the spent fuel pool demineralizer and filters to clean up the refueling water storage tank after refueling operations. The design flow rate in the loop is limited to 100 gpm to accommodate the design flow of the spent fuel pool demineralizer.

The spent fuel pool has a surface skimmer system designed to provide optical clarity by removing surface debris. The system consists of two surface skimmers, a single strainer, a single pump and three filters. The skimmer pump is a centrifugal pump with a 100 gpm capacity. The pump discharge flow passes through the filter to remove particulates. It returns to the spent fuel pool.

## **2.5 Dilution Sources**

### **2.5.1 Chemical and Volume Control System (CVCS)**

The CVCS connects to the spent fuel pool via a 2" line from the discharge of the outlet of the holdup tanks recirculation pump to the refueling water purification pump bypass line to the spent fuel pool demineralizer inlet and into the cooling loop return header. This connection is normally isolated and is used to transfer water from the holdup tanks to the spent fuel pool. The isolation is by three manual valves.

Since there is also a check valve at the recirculation pump discharge, water will not flow from the spent fuel pool to the holdup tanks. Also, holdup tank water will not gravity-drain to the spent fuel pool because the holdup tank recirculation pump is normally isolated, and the maximum tank water level is below the minimum SFP level.

The recirculation pump can take suction from either of the three holdup tanks. However, by procedure, the only one pump is aligned to one holdup tank at a time. Manual valve manipulations are required to switch the pump suction to another tank. Each holdup tank has a total volume of approximately 97,000 gallons and can be at a boron concentration from 0 ppm up to 2000 ppm. The flow from this source is estimated to be 90 gpm.

### **2.5.2 Primary Water Makeup System**

The primary water makeup system consists of one primary water storage tank and two primary water pumps per Unit. During normal operation, one primary water pump is running on recirculation to provide primary water on demand to multiple users. Each primary water storage tank contains approximately 150,000 gallons of non-borated, demineralized water.

The primary water makeup system connects to the spent fuel pool directly via the cooling loop return line, and indirectly through the spent fuel pool demineralizer outlet and the local station in the spent fuel pit area. Using the direct connection, the contents of the primary water storage tank can be transferred directly to the spent fuel pool cooling system via the primary water pumps. The direct connection is normally isolated from the primary water system by three locked-closed manual valves. The preferred method of makeup is from the refueling water storage tank which is borated. The second preferred makeup method is from the direct connection to the spent fuel pool cooling loop return header. The flow rate through this path is estimated to be 415 gpm.

When primary water is used to flush spent resin, the spent fuel pool demineralizer is isolated from the cleanup loop by one manual valve. If this valve were left open, primary water could be transferred into the spent fuel pool. The flow from this pathway is estimated to be 240 gpm.

Finally, the 2" primary water station in the spent fuel pit area is isolated by a normally closed valve and a capped connection. The flow from this pathway is estimated to be 500 gpm.

### **2.5.3 Demineralized Water System**

The demineralized water system is supplied from a water treatment plant. This source of makeup is utilized only when the treatment plant supply pressure is at least 50 psig. Demineralized water is

provided through the same connection to the spent fuel pool cooling loop return piping as the primary water source. The demineralized water supply is isolated by one normally closed and one locked closed valve. The flow from this source is estimated to be 174 gpm.

#### **2.5.4 Component Cooling Water System**

Component cooling water is the cooling medium for the spent fuel pool cooling system heat exchanger. There is no direct connection between the component cooling system and the spent fuel pool cooling system. If, however, a leak were to develop in a heat exchanger that is in service, the connection would be made. Since the component cooling system normally operates at a slightly higher pressure than the spent fuel pool cooling system, it is expected that a breach in a spent fuel pool cooling system heat exchanger tube would result in non-borated component cooling water entering the spent fuel pool cooling system.

It would be expected that the flow rate of any leakage of component cooling water into the spent fuel pool cooling system would be very low due to the small difference in operating pressures between the two systems. Even if there was significant leakage from the component cooling water system to the spent fuel pool, the impact on the spent fuel pool boron concentration would be minimal because a loss of water from the component cooling water surge tank would initiate an alarm and control room indication to alert the control room operators.

If the alarms which would alert the control room operators of a component cooling water system leak were to fail and leakage from the component cooling water system to the spent fuel pool cooling system were to continue undetected, the component cooling water surge tank would be administratively refilled with primary water. Until makeup is initiated, the volume added to the spent fuel pool would be limited by the component cooling water surge tank volume of 2000 gallons.

Because of the limited dilution volume from this source relative to the spent fuel pool volume, it is not considered further in this analysis.

#### **2.5.5 Drain Systems**

The equipment drain system connects directly to the spent fuel pool cooling system and skimmer system at the drain connections for the spent fuel pit pumps, heat exchangers (tube side), filters, demineralizer, the skimmer pump, and skimmer filter. Each connection has a normally closed valve to isolate it. Backflow through these paths is not considered credible, because if the drain valves were left open, the pressurized spent fuel pool cooling system would flow into the drain system, not vice versa.

#### **2.5.6 Fire Protection System**

In an emergency loss of spent fuel pool inventory, a fire hose station is available outside the spent fuel pool area door. This station is capable of providing 100 gpm of non-borated water. Although an available source, the fire hose is not specifically addressed by an approved procedure for makeup.

#### **2.5.7 Spent Fuel Pit Demineralizer**

The spent fuel pit demineralizer has a capacity of 30 ft<sup>3</sup> of 1:1 equivalent mixed bed resin. This implies a volume ratio of 60%/40% anion to cation resin. If we assume the bed was loaded with 100% anion, it would bound the capacity to remove boron when it is first aligned to the system. The demineralizer would be operated at a nominal 100 gpm flow rate. Dilution of the spent fuel pool resulting from operation of the demineralizer will not result in an increase in the spent fuel pool level.

#### **2.5.8 Rainwater Collection System**

The room housing the spent fuel pool includes 4-6" piping along the walls to carry rainwater from the roof to a drain system. The piping is not seismically designed and could therefore be postulated to break during an earthquake.

#### **2.5.9 Dilution Source and Flow Rate Summary**

Based on the evaluation of potential spent fuel pool dilution sources summarized above, the following dilution sources were determined to be capable of providing a significant amount of non-borated water to the spent fuel pool. The potential for these sources to dilute the spent fuel pool boron concentration to the design basis boron concentration (650 ppm) will be evaluated in Section 3.0.

SOURCE	APPROXIMATE FLOW RATE (GPM)
CVCS	
- Holdup Tank to Cleanup Loop	90
Primary Water System	
- To SFP via valve 821	415
- To SFP via demineralizer sluice line	240
- 2" PW station near SFP	500
Demineralized Water System	
- To SFP via valve 821	174
Fire Protection System	
- Fire hose station outside SFP room	100
SFP Demineralizer	100

## 2.6 Boration Sources

The normal source of borated water to the spent fuel pool is from the refueling water storage tank. It is also possible to borate the spent fuel pool by the addition of dry boric acid directly to the spent fuel pool water.

### 2.6.1 Refueling Water Storage Tank

The refueling water storage tank (RWST) connects to the spent fuel pool through the purification loop via the refueling water purification pump. This connection is used to purify the RWST water when the purification loop is isolated from the spent fuel pool cooling system. Normally, this connection can supply borated water to the spent fuel pool via the refueling water purification pump to the inlet to the spent fuel pit cooling system purification loop. The refueling water purification pump is powered from a non-vital bus power supply. The RWST is required by Technical Specifications to be kept at a minimum boron concentration of 1950 ppm.

### 2.6.2 Direct Addition of Boric Acid

If necessary, the boron concentration of the spent fuel pool can be increased by emptying bags of dry boric acid directly into the spent fuel pool. However, boric acid dissolves very slowly at room temperature and requires that the spent fuel pool cooling pumps be available for mixing the spent fuel pool water (see section 3.1 for further discussion on spent fuel pool mixing.) Furthermore, there is no procedure currently in place to provide operator guidance for this method. Therefore, this method would be used only in an emergency.

## **2.7 Spent Fuel Pool Instrumentation**

Instrumentation is available to monitor spent fuel pool water level and temperature. Additional instrumentation is provided to monitor the pressure and flow of the spent fuel pool cleanup system, and pressure, flow, and temperature of the spent fuel pool cooling system.

The instrumentation provided to monitor the temperature of the water in the spent fuel pool is indicated locally and annunciated in the control room. The water level instrumentation alarms, high and low level, are annunciated in the control room. Two area radiation monitors are available in the spent fuel pool room.

A change of one foot in spent fuel pool level with the transfer canal isolated requires approximately 7816 gallons of water. If the pool level was raised from the low level alarm point to the high level alarm (6" including instrument error), a dilution of approximately 3908 gallons could occur before an alarm would be received in the control room. If the spent fuel pool boron concentration were at 1950 ppm initially, such a dilution would only result in a reduction of the pool boron concentration of approximately 28 ppm.

## **2.8 Administrative Controls**

The following administrative controls are in place to control the spent fuel pool boron concentration and water inventory:

1. Procedures are available to aid in the identification and termination of dilution events.
2. The procedures for loss of inventory (other than evaporation) specify that a borated makeup

source (RWST) be used as the preferred makeup source. The procedures specify non-borated sources as secondary preferences.

3. In accordance with procedures, plant personnel perform rounds in the spent fuel pool room once every 12 hours. The personnel making rounds to the spent fuel pool are trained to be aware of the change in the status of the spent fuel pool. They are instructed to check the temperature and level in the pool and conditions around the pool during plant rounds.
4. Administrative controls (locked closed valves on primary water and demineralized water flow paths to the spent fuel pool cooling system) are placed on some of the potential dilution paths.
5. Procedures require that the chemistry department verify the pool boron-concentration will not be diluted below 1950 ppm when makeup is added.

## **2.9 Piping**

There are no systems (other than those listed in section 2.5.1 to 2.5.8) identified which have piping in the vicinity of the spent fuel pool which could result in a dilution of the spent fuel pool if they were to fail.

## **2.10 Loss of Offsite Power Impact**

Of the dilution sources listed in Section 2.5.9, only the fire protection system is capable of providing non-borated water to the spent fuel pool during a loss of offsite power.

The loss of offsite power would affect the ability to respond to a dilution event. The spent fuel pool level instrumentation is not powered from vital power supplies.

The refueling water purification pump is not powered from a safeguards supply and would not be available to deliver borated water from the RWST. However, at maximum water level, the RWST can be gravity-drained to the spent fuel pool through the refueling water purification pumps, if necessary, to provide a borated water source. Finally, manual addition of dry boric acid to the pool could be used if it became necessary to increase the spent fuel pool boron concentration during a loss of offsite power.

### 3.0 SPENT FUEL POOL DILUTION EVALUATION

#### 3.1 Calculation of Boron Dilution Times and Volumes

For the purposes of evaluating spent fuel pool dilution times and volumes, the total pool volume available for dilution, as described in section 2.1, is conservatively assumed to be 264,000 gallons.

Based on the criticality analyses (Reference 1), the soluble boron concentration required to maintain the spent fuel pool boron concentration at  $k_{eff} < 0.95$ , including uncertainties and burnup, with a 95% probability at a 95% confidence level (95/95) is 650 ppm.

The spent fuel pool boron concentration is typically in the range of 2000 and 2100 ppm. If the concentration falls below 1950 ppm, Turkey Point enters a Limiting Condition of Operation Action Requirement procedure and uses administrative procedures to restore and monitor the concentration. However, for the purposes of evaluating the dilution times and volumes, the initial spent fuel pool boron concentration is assumed to be at the current Technical Specification minimum limit of 1950 ppm. The evaluations are based on the spent fuel pool boron concentration being diluted from 1950 ppm to 650 ppm. To dilute the combined pool volume of 264,000 gallons from 1950 ppm to 650 ppm would conservatively require 290,000 gallons of non-borated water, based on a feed-and-bleed operation (constant volume).

This analysis assumes thorough mixing of all the non-borated water added to the spent fuel pool with the contents of the spent fuel pool. Refer to Figure 3. Based on the design flow of 2300 gpm per spent fuel pit pump, the 264,000 gallon system volume is turned over approximately every two hours with one pump running, which is the normal alignment. It is unlikely, with cooling flow and convection from the spent fuel decay heat, that thorough mixing would not occur. However, if mixing was not adequate, it would be conceivable that a localized pocket of non-borated water could form somewhere in the spent fuel pool. This possibility is addressed by the calculation in Reference 1 which shows that the spent fuel rack  $K_{eff}$  will be less than 1.0 on a 95/95 basis with the spent fuel pool filled with non-borated water. Thus, even if a pocket of non-borated water formed in the spent fuel pool,  $K_{eff}$  would not exceed 1.0 anywhere in the pool.

The time to dilute the spent fuel pool depends on the initial volume of the pool and the postulated rate of dilution. The dilution volumes and times for the dilution scenarios discussed in Sections 3.2 and 3.3 are calculated based on the following equation:

$$t_{\text{end}} = \ln (C_o / C_{\text{end}}) V / Q \quad \text{(Equation 1)}$$

Where:

$C_o$  = the boron concentration of the pool volume at the beginning of the event (1950 ppm)

$C_{\text{end}}$  = the boron endpoint concentration (650 ppm)

$Q$  = dilution rate (gallons/minute)

$V$  = volume (gallons) of spent fuel pool (264,000)

$t_{\text{end}}$  = time to reach  $C_{\text{end}}$  (minutes)

### 3.2 Evaluation of Boron Dilution Events

The potential spent fuel pool dilution events that could occur are evaluated below:

#### 3.2.1 Dilution From CVCS Holdup Tanks

The contents of a CVCS holdup tank can be transferred via the recirculation pump to the spent fuel pool via the cleanup loop. The flow path to the transfer canal is through a line that is isolated by one normally closed valve. This connection is a designated source of makeup water in a loss of spent fuel pool inventory event. Each of the three CVCS recycle holdup tanks has a total volume of approximately 97,000 gallons. The water in the tanks can have a boron concentration from 0 ppm to approximately 2000 ppm. Any amount of boron in the CVCS holdup tank water would reduce the dilution of the spent fuel pool resulting from the transfer of CVCS holdup tank water to the spent fuel pool. To dilute the spent fuel pool volume from 1950 ppm to 650 ppm would require 290,000 gallons of unborated water. The combined contents of the three CVCS holdup tanks (approximately 300,000 gallons) is slightly more than the required dilution volume. The path from the recirculation pump to the spent fuel pool via the connection to the spent fuel pool purification loop can provide approximately 90 gpm. If the manual isolation valve were left unattended, it would take 43 minutes to increase the spent fuel pool level from the low to high alarm setpoints, and 54 hours to provide the 290,000 gallons required to dilute the pool from 1950 to 650 ppm boron, assuming 0 ppm boron in the holdup tanks.

The CVCS recirculation pump can take suction from either of the three CVCS holdup tanks. Administrative procedures specify that the pumps are aligned to one holdup tank at a time. Manual valve manipulations are required to switch the pump suction to another tank. Thus, it is assumed for the purposes of this evaluation that only the contents of one CVCS holdup tank is available for a spent fuel pool dilution event. The 97,000 gallons of water contained in one CVCS holdup tank is less than the 290,000 gallons necessary to dilute the spent fuel pool/transfer canal from 1950 ppm to 650 ppm. Because of these factors, the CVCS holdup tanks are not considered a credible dilution source for the purposes of this analysis.

### **3.2.2 Dilution From Primary Water Storage Tanks**

The contents of the primary water storage tank can be transferred via the primary water pumps directly or indirectly to the spent fuel pool.

The primary water system consists of a primary water storage tank and two primary water pumps per Unit. Primary water can be supplied to the spent fuel pool cooling system from the tank and pumps associated with either Unit. The two primary water storage tanks each contain approximately 150,000 gallons of non-borated reactor grade water. The tanks are normally not cross-connected. Thus, the contents of one tank is not sufficient to dilute the spent fuel pool from 1950 to 650 ppm.

The path from the primary water pumps to the spent fuel pool via the connection to the spent fuel pool cooling loop return header can provide approximately 415 gpm. If the manual isolation valve were left unattended, it would take 9 minutes to increase the spent fuel pool level from the low to high alarm setpoints, and 12 hours to provide the 290,000 gallons required to dilute the pool from 1950 to 650 ppm boron.

The path from the primary water pumps to the spent fuel pool via the spent fuel pit demineralizer resin flushing connection can provide approximately 240 gpm. If the manual isolation valve were left unattended, it would take 16 minutes to increase the spent fuel pool level from the low to high alarm setpoints, and 20 hours to provide the 290,000 gallons required to dilute the pool from 1950 to 650 ppm boron.

The path from the primary water pumps to the spent fuel pool via the 2" station in the spent fuel pit area can provide approximately 500 gpm. If the temporary hose connection were left unattended, it would take 8 minutes to increase the spent fuel pool level from the low to high alarm setpoints, and 10 hours to provide the 290,000 gallons required to dilute the pool from 1950 to 650 ppm boron.

### **3.2.3 Dilution From Demineralized Water System**

This source consists of a trailer-type portable system which is administratively controlled. Thus, its capacity and surge volume are very limited.

The path from the demineralized water connection to the spent fuel pool via the 2" connection to the spent fuel pool cooling system return header can provide approximately 174 gpm. If the path were left unattended, it would take 22 minutes to increase the spent fuel pool level from the low to high alarm setpoints, and 28 hours to provide the 290,000 gallons required to dilute the pool from 1950 to 650 ppm boron.

### **3.2.4 Dilution from Fire Protection System**

The fire protection system draws from two raw water tanks with a capacity of 500,000 and 750,000 gallons, respectively. The path from the fire water pump to the spent fuel pool via the fire hose station outside the spent fuel pit area can provide approximately 100 gpm. If the hose were left unattended, it would take 39 minutes to increase the spent fuel pool level from the low to high alarm setpoints, and 48 hours to provide the 290,000 gallons required to dilute the pool from 1950 to 650 ppm boron.

### **3.2.5 Dilution Resulting From Seismic Events or Random Pipe Breaks**

A seismic event could cause piping ruptures in the vicinity of the spent fuel pool in piping that is not seismically qualified. The only piping within the immediate vicinity of the spent fuel pool that could result in dilution of the spent fuel pool if it ruptures during a seismic event are the 4-6" rain collection piping along the walls. In order to consider this piping as a dilution source, it would be necessary to assume that a seismic event occurred coincident with a major rainstorm that would dump significant volumes of unborated rainwater into the spent fuel pool. This combination of events is considered to have a sufficiently low probability of occurrence to eliminate it from consideration for this analysis.

For a seismic event with offsite power available, rupture of the primary water station piping in the spent fuel pit area are bounded by the analyses in Sections 3.2.2. If offsite power is not available, the primary water systems would not operate, and thus, there would be no dilution source.

### **3.2.6 Dilution From Spent Fuel Pool Demineralizer**

When the spent fuel pool demineralizer is first placed in service after being recharged with fresh resin, it can initially remove boron from the water passing through it. In the worst case, assuming 30 ft<sup>3</sup> of anion resin in the demineralizer, up to 18 ppm of boron could be removed from the spent fuel pool water before the resin would become saturated. Since the demineralizer normally utilizes a mixed bed of anion and cation resin, less boron would actually be removed before saturation. Because of the small amount of boron removed by the demineralizers, it is not considered a credible dilution source for the purposes of this evaluation.

### **3.2.7 Review of Licensee Event Reports(LER)**

A review of 8 LERs related to the spent fuel pool and cooling system was conducted to identify any extraordinary mechanisms of dilution not previously addressed in the previous sections. The review resulted in no new dilution paths or mechanisms.

## **3.3 Summary of Dilution Events**

The four available water sources for spent fuel pool dilution are primary water, demineralized water, CVCS holdup tank fluid, and fire protection. Fire protection is the least likely source, since it is not controlled by procedure for use as makeup, and because the fire hose is located outside the spent fuel pool room. The CVCS holdup tank source is the next least likely because it is normally borated to some degree, and because the volume of one tank is less than that required to dilute the spent fuel pool from 1950 to 650 ppm. The demineralized water source is the next least likely source because its source is controlled administratively, and because it is third in the preferred list of normal makeup sources behind the RWST and the primary water system. Since the RWST is always borated, the key system for consideration is the primary water system.

Flow rates from the primary water system supply pump vary up to pump runout flow of 500 gpm. Even at this flow, the spent fuel pool is filled to the high alarm in only 8 minutes, assuming the pool level was initially at the Technical Specification minimum level. Assuming that the high level alarm were to fail, the pool would overflow and fill the room until water would leak into the refueling canal and out of the room door leaking to the building roof. A significant loss of primary water storage tank inventory would be detected by the operator via a low tank level alarm at 50%. Makeup to the tank is provided administratively from the deaeration system, so the tank would not be refilled continuously without operator attention. Finally, the total tank volume of 150,000 gallons is not sufficient to dilution the spent fuel pool from 1950 to 650 ppm boron.

Furthermore, for any dilution scenario to successfully add 290,000 gallons of water to the spent fuel pool, plant operators would have to fail to question or investigate the continuous makeup of water to the primary water storage tank for the required time period, and fail to recognize that the need for 290,000 gallons of makeup was unusual.

## 4.0 CONCLUSIONS

A boron dilution analysis has been completed for the spent fuel pool. As a result of this spent fuel pool boron dilution analysis, it is concluded that an unplanned or inadvertent event which would result in the dilution of the spent fuel pool boron concentration from 1950 ppm to 650 ppm is not a credible event. This conclusion is based on the following:

The preferred method of normal makeup to the pool is, by procedure, from the RWST, a borated water source. Thus, the operator would have to make a conscious decision to choose a non-borated water source for makeup over a borated water source.

If an inadvertent dilution were to be initiated, administrative procedures are in place to address a high level alarm in the spent fuel pool. Borated water from the RWST is available via the refueling water purification pump with normal power available, and by gravity feed to the pool should offsite power be lost.

In order to dilute the spent fuel pool to the design  $K_{eff}$  of 0.95, a substantial amount of water (290,000 gallons) is needed. To provide this volume, an operator would have to initiate the dilution flow, then abandon monitoring of pool level, and ignore administrative procedures, and a high level alarm for a period of at least 10 hours. The 290,000 gallon value is used for analysis. It exceeds the volume of the typical source of unborated water (primary water storage tank). There is no single credible source of unborated water of at least 290,000 gallons.

Since such a large water volume turnover is required, a spent fuel pool dilution event would be readily detected by plant personnel via alarms, flooding in the fuel handling building, or eventually by operator rounds through the spent fuel pool area.

It should be noted that this boron dilution evaluation was conducted by evaluating the time and water volumes required to dilute the spent fuel pool from 1950 ppm to 650 ppm. The 650 ppm endpoint was utilized to ensure that  $K_{eff}$  for the spent fuel racks would remain less than or equal to 0.95. As part of the criticality analysis for the spent fuel racks (Reference 1), a calculation has been performed on a 95/95 basis to show that the spent fuel rack  $K_{eff}$  remains less than 1.0 with non-borated water in the pool. Thus, even if the spent fuel pool were diluted to zero ppm, which would take significantly more

water than evaluated above, the spent fuel would be expected to remain subcritical and the health and safety of the public would be assured.

**5.0****REFERENCES**

1. CAB-99-214, "Criticality for Fresh and Spent Fuel Storage for Turkey Point Units 3 and 4 (Full Boraflex)," June, 1999.




Figure 1 - Spent Fuel Pool and Related Systems




Figure 2 - SFP Plan View 1




Figure 3 - SFP Mixing 1

L-99-176  
Attachment 7

**ATTACHMENT 7**

**Criticality for Fresh Fuel Storage for  
Turkey Point Units 3 & 4**

## Criticality for Fresh Fuel Storage for Turkey Point Units 3 & 4

October 1999

H. C. Huria  
M. A. Kotun  
S. Srinilta  
S. Kapil

Prepared: *Sushil Kapil*  
S. Kapil  
Criticality Services Team

Verified: *S. Srinilta*  
S. Srinilta  
Criticality Services Team

Approved: *B. Beebe*  
B. Beebe, Acting Manager  
Core Analysis B



Westinghouse  
Nuclear Fuel Business Unit

## Table of Contents

<b>1.0</b>	<b>Introduction.....</b>	<b>1</b>
<b>1.1</b>	<b>Design Description.....</b>	<b>1</b>
<b>1.2</b>	<b>Design Criteria.....</b>	<b>1</b>
<b>2.0</b>	<b>Analytical Methods.....</b>	<b>3</b>
<b>3.0</b>	<b>Criticality Analysis of the Fresh Fuel Racks.....</b>	<b>4</b>
<b>3.1</b>	<b>Full Density Moderation Analysis.....</b>	<b>4</b>
<b>3.2</b>	<b>Low Density Optimum Moderation Analysis.....</b>	<b>6</b>
<b>4.0</b>	<b>Discussion of Postulated Accidents in the Fresh Fuel Storage.....</b>	<b>9</b>
<b>5.0</b>	<b>Summary of Criticality Results.....</b>	<b>10</b>
	<b>Bibliography.....</b>	<b>15</b>

## List of Tables

Table 1. Nominal Fuel Parameters Employed in the Criticality Analysis .....	11
Table 2. Fresh Fuel Storage Cell and Fuel Parameters .....	12

## List of Figures

- Figure 1. Turkey Point Unit 4 Fresh Fuel Storage Cell Layout .....13  
Figure 2. Turkey Point Units 3 and 4 Fresh Fuel Rack  $K_{eff}$  as a Function of Water Density 14

# 1.0 Introduction

This report presents the results of criticality analyses of the Florida Power & Light Turkey Point Units 3 and 4 fresh fuel storage vault.

The following storage configuration and enrichment limit were considered in the analyses:

<b>Fresh Fuel</b>	Storage of 15x15 fuel assemblies in the fresh fuel vault. Fuel assemblies must have a nominal enrichment no greater than 4.5 w/o <sup>235</sup> U with no axial blankets.
-------------------	---

Under full density water flooding accident, the storage is shown to meet the limit of  $K_{eff} \leq 0.95$  and for the optimum moderation accident the limit of  $K_{eff} \leq 0.98$  is met.

## 1.1 Design Description

The cross-sectional view of the Turkey Point Unit 4 fresh fuel rack layout is depicted in Figure 1 on page 13. Fresh fuel storage cell layout for Turkey Point Unit 3 is a mirror image of Turkey Point Unit 4.

The fuel parameters relevant to this analysis are given in Table 1 on page 11 and Table 2 on page 12. The Table 1 fuel parameters bound the previous fuel designs used in Turkey Point Units 3 & 4. The fuel rod and guide thimble and instrumentation thimble tube cladding are modeled as zircaloy in this analysis. This is conservative with respect to the Westinghouse ZIRLO™ product which is a zirconium alloy containing additional elements including niobium. Niobium has a small absorption cross section which causes more neutron capture in the cladding resulting in a lower reactivity. Therefore, this analysis is conservative with respect to fuel assemblies containing ZIRLO™ cladding in fuel rods and guide thimble and instrumentation thimble tubes.

Table 2 on page 12 also shows the rack dimensions with the manufacturing tolerances.

The analyses are performed for full density water flooding and with a low density water presence in the fuel storage area which maximizes the storage reactivity.

The analyses conform to the requirements of NUREG-0800, Section 9.

## 1.2 Design Criteria

Criticality of fuel assemblies in a fuel storage rack is prevented by the design of the rack which limits fuel assembly interaction. This is done by fixing the minimum separation between fuel assembly and/or placing absorber panels between storage cells.

The design basis for preventing criticality for fresh fuel storage, is examined on the 95/95 basis. The 95/95 basis is defined as the upper limit, with a 95 percent probability at a 95 percent confidence level, of the effective neutron multiplication factor  $K_{\text{eff}}$  of the fuel assembly array, including uncertainties and manufacturing tolerances.

Fresh fuel is normally stored in dry conditions. However, the accidental introduction of water in the storage area is considered. For the full density water flooding in the fresh fuel storage area, the criterion of 95/95 basis  $K_{\text{eff}} \leq 0.95$  must be met. For optimum moderation (water content which gives the highest reactivity) in the storage area the criterion of 95/95 basis  $K_{\text{eff}} \leq 0.98$  must be met.

The design criteria are consistent with ANSI 57.2-1983<sup>(2)</sup>, ANSI 57.3-1983<sup>(3)</sup>, and NUREG-0800<sup>(4)</sup>.

## 2.0 Analytical Methods

The criticality calculation method and cross-section values are verified by comparison with critical experiment data for fuel assemblies similar to those for which the racks are designed. This benchmarking data is sufficiently diverse to establish that the method bias and uncertainty will apply to rack conditions which include strong neutron absorbers, large water gaps, low moderator densities and spent fuel pool soluble boron.

The design method which insures the criticality safety of fuel assemblies in the fuel storage rack is described in detail in the Westinghouse Spent Fuel Rack Criticality Analysis Methodology topical report<sup>(1)</sup>. This report describes the computer codes, benchmarking, and methodology which are used to calculate the criticality safety limits presented in this report for Turkey Point Units 3 and 4.

As determined in the benchmarking in the topical report, the method bias using the described methodology of NITAWL-II, XSDRNPM-S and KENO-Va is 0.00770  $\Delta K$  with a 95 percent probability at a 95 percent confidence level uncertainty on the bias of 0.00300  $\Delta K$ . These values will be used in this report.

### 3.0 Criticality Analysis of the Fresh Fuel Racks

The fresh fuel is stored in the fresh fuel racks in a dry condition. The reactivity of the dry fuel is very low at enrichments up to 5 w/o. However, with any introduction of water in the storage area the reactivity of the array can rise significantly. Thus, the reactivity of the system is examined for the conditions of flooding and for introduction of water at optimum density. The optimum density is defined as the low density of water which would lead to the highest reactivity of the storage array.

This section describes the analytical techniques and models employed to perform the criticality analysis for the storage of fresh fuel in the Turkey Point Units 3 and 4 fresh fuel storage racks. The fresh fuel rack is analyzed by employing the methodology outlined in Section 2 of this report. Details of this analysis are outlined in Sections 3.1 and 3.2 for the full density water flooding condition and optimum moderation condition, respectively.

Fresh fuel is stored in racks arranged in an L-shaped configuration, consisting of two limbs of 8x3 and 3x10. Up to 54 assemblies can be stored. Figure 1 on page 13 shows the configuration.

Since the fresh fuel racks are normally maintained in a dry condition, the criticality analysis will show that the rack 95/95  $K_{eff}$  is less than or equal to 0.95 for the accidental full density water flooding scenario (ANSI/ANS-57.3) and less than or equal to 0.98 for the accidental low water density (optimum moderation) flooding scenario (NUREG-0800, Section 9).

The analyses are performed for the fresh fuel storage in the "worst case" conditions. In these conditions, the manufacturing tolerances are included in the calculation input in the limiting direction, so that the calculations are conservative.

#### 3.1 Full Density Moderation Analysis

The fresh fuel racks are analyzed for the full density water flooding condition under "worst case" scenario:

1. Maximum enrichment of 4.55 w/o  $^{235}\text{U}$
2. No pellet dishing
3. Fuel with 98% of theoretical density
4. Minimum assembly storage pitch of 20.875 inches.
5. An infinite array of assemblies (no radial leakage of neutrons) is modeled.
6. Top and bottom of the storage have 1 foot of water.

The "worst case" scenarios conservatively account for fuel parameter variability and tolerances on rack dimensions. The KENO results for the "worst case" model are then used to develop the maximum 95/95  $K_{eff}$  which is compared to the criticality safety limit of 0.95.

Therefore, following assumptions were used to develop the KENO model for the storage of fresh fuel in the Turkey Point Units 3 and 4 fresh fuel storage racks under full density water condition:

1. The fuel assembly parameters for the criticality analysis are based on the Westinghouse 15x15 DRFA design.
2. All fuel rods contain uranium dioxide at the maximum enrichment of 4.55 w/o over the entire length of each rod.
3. The fuel pellets are modeled assuming a  $UO_2$  density which is 98% of theoretical density with no dishing fraction (0%) for "worst case" conditions.
4. No credit is taken for any  $^{234}U$  or  $^{236}U$  in the fuel.
5. No credit is taken for any grids in the assembly.
6. No credit is taken for any burnable absorber in the fuel rods.
7. The flooding is by pure water (no boron) at a temperature of 68°F. A limiting value of  $1.0 \text{ gm/cm}^3$  is used for the density of water.
8. The 20.875 inch minimum center to center spacing is used for distance between all storage cells, (see Figure 1 on page 13). The actual distance between the outer assembly and the east wall is 54 inches. Only 30 inch distance between the outer assembly and the east wall is assumed in the analysis and this is conservative.
9. There are no absorber panels between the assemblies. Rack structure is only the L shaped inserts described in Table 2 on page 12.
10. All available storage cells are loaded with fuel assemblies.

A KENO model was set up using the above limiting fuel and rack parameters and resulted in a  $K_{eff}$  of 0.91295 with a 95 percent probability/95 percent confidence level uncertainty of  $+0.00130 \Delta K$ .

Based on the analysis described above, the following equation is used to develop the maximum 95/95  $K_{eff}$ :

$$K_{eff} = K_{worst} + B_{method} + \sqrt{ks_{worst}^2 + ks_{method}^2}$$

where:

- |               |   |  |
|---------------|---|--|
| $K_{worst}$   | = | worst case KENO $K_{eff}$                                  |
| $B_{method}$  | = | method bias determined from benchmark critical comparisons |
| $ks_{worst}$  | = | 95/95 uncertainty in the worst case KENO $K_{eff}$         |
| $ks_{method}$ | = | 95/95 uncertainty in the method bias                       |

Substituting calculated values in the order listed above, the result is:

$$K_{eff} = (0.91295) + (0.0077) + \sqrt{0.00130^2 + 0.0030^2} = 0.92392$$

Since  $K_{eff}$  is less than 0.95 including uncertainties at a 95/95 probability/confidence level, the acceptance criterion for criticality is met for the Turkey Point Units 3 and 4 fresh fuel storage racks under full density water flooding conditions for storage of Westinghouse 15x15 fuel assemblies with maximum enrichments up to 4.55 w/o  $^{235}\text{U}$ .

### 3.2 Low Density Optimum Moderation Analysis

The fresh fuel rack is analyzed for the low density optimum moderation condition under "worst case" scenario:

1. Maximum enrichment of 4.55 w/o  $^{235}\text{U}$
2. No pellet dishing
3. Fuel with 98% of theoretical density
4. Minimum assembly storage pitch of 20.875 inches.
5. Six feet thick concrete wall is assumed to surround the storage area on all sides which is conservative.
6. Top and bottom of the storage have 1 foot of water (at low density) followed by 6 feet of concrete.

The "worst case" scenarios conservatively account for fuel parameter variability and tolerances on rack dimensions (Table 2 on page 12). The KENO results for the "worst case" model are then used to develop the maximum 95/95  $K_{eff}$  which is compared to the criticality safety limit of 0.98.

The following assumptions were used to develop the KENO model for the storage of fresh fuel in the Turkey Point Units 3 and 4 fresh fuel storage racks under low density optimum moderation condition:

1. The fuel assembly parameters relevant to the criticality analysis are based on the Westinghouse 15x15 DRFA design.
2. All fuel rods contain uranium dioxide at a maximum enrichment of 4.55 w/o in the entire length of the rod.
3. The fuel pellets are modeled assuming a  $\text{UO}_2$  density which is 98% of theoretical density with no dishing fraction (0%) for the "worst case" conditions.
4. No credit is taken for any  $^{234}\text{U}$  or  $^{236}\text{U}$  in the fuel.
5. No credit is taken for any fuel grids.
6. No credit is taken for any burnable absorber in the fuel rods.
7. The moderator is low density water (no boron) at a temperature of 68°F. The optimum moderation typically occurs around 0.07 to 0.10 gm/cm<sup>3</sup> water density. Opti-

imum water density was determined and used in the analysis (See Figure 2 on page 14).

8. A minimum center to center spacing of 20.875 inches. See Figure 1 on page 13 and Table 2 on page 12 for details.
9. The entire rack is modeled and is assumed to be surrounded by concrete walls in all directions. For simplicity, the concrete wall thickness is assumed to be 72 inches. All available storage cells are loaded with fuel assemblies.

A KENO model was set up using the above limiting fuel and rack parameters. Water density of approximately  $0.095 \text{ gm/cm}^3$  was found to lead to the highest reactivity (See Figure 2 on page 14). This density was used for the limiting calculation. This resulted in a  $K_{\text{eff}}$  of 0.83095 with a 95 percent probability/95 percent confidence level uncertainty of  $+0.00119 \Delta K$ .

Based on the analysis described above, the following equation is used to develop the maximum 95/95  $K_{\text{eff}}$ :

$$K_{\text{eff}} = K_{\text{worst}} + B_{\text{method}} + \sqrt{ks_{\text{worst}}^2 + ks_{\text{method}}^2}$$

where:

$K_{\text{worst}}$	=	worst case KENO $K_{\text{eff}}$
$B_{\text{method}}$	=	method bias determined from benchmark critical comparisons
$ks_{\text{worst}}$	=	95/95 uncertainty in the worst case KENO $K_{\text{eff}}$
$ks_{\text{method}}$	=	95/95 uncertainty in the method bias

Substituting calculated values in the order listed above, the result is:

$$K_{\text{eff}} = 0.83095 + (0.0077) + \sqrt{0.00119^2 + 0.0030^2} = 0.84188$$

This KENO model resulted in a  $K_{\text{eff}}$  of 0.84188 with a 95 percent probability/95 percent confidence level.

Since  $K_{\text{eff}}$  is less than 0.98 including uncertainties at a 95/95 probability/confidence level, the acceptance criteria for criticality is met for the Turkey Point Units 3 and 4 fresh fuel storage racks under optimum moderation condition.

Thus, for both full density water moderation and the optimum water density moderation the respective reactivity criteria are met. Westinghouse 15x15 fuel assemblies with maximum enrichments up to 4.55 w/o  $^{235}\text{U}$  (with no axial blankets) meet the reactivity limits.

## 4.0 Discussion of Postulated Accidents in the Fresh Fuel Storage

Under normal conditions, the fresh fuel racks are maintained in a dry environment. The introduction of water into the fresh fuel rack area is the worst case accident scenario. The water flooding cases analyzed in this report are bounding accident situations which result in the most conservative fuel rack  $K_{eff}$ .

Other accidents can be postulated which could cause a reactivity increase in the fresh fuel racks and these are a fuel assembly drop on top of the rack and a fuel assembly drop between the rack and the wall. The fuel assembly drop between the rack and the wall is not possible for the Turkey Point Units 3 and 4 fresh fuel racks due to the construction configuration which precludes the drop of an assembly into any position other than a storage cell. For the fuel assembly drop on top of the rack, the double contingency principle<sup>(5)</sup> is applied. This states that assumption of two unlikely, independent, concurrent events is not required to ensure protection against a criticality accident. Thus, for the case of the fuel assembly drop on top of the rack, the absence of a moderator in the fresh fuel storage racks can be assumed as a realistic initial condition since assuming the presence of moderator would be a second unlikely, independent event.

Experience has shown that the maximum reactivity increase associated with a fuel assembly drop on top of the rack is less than 10 percent  $\Delta K$  under the full density water condition.

Therefore, since the normal, dry fresh fuel rack reactivity for Turkey Point Units 3 and 4 is relatively low, less than 0.65, and the maximum reactivity increase for the fuel assembly drop on top of the rack for the dry condition would be much less than 10 percent  $\Delta K$ , the maximum rack  $K_{eff}$  for the fuel assembly drop on top of the rack will meet the licensing bases.

## 5.0 Summary of Criticality Results

For the storage of Westinghouse 15x15 fuel assemblies in the Turkey Point Units 3 and 4 fresh fuel storage racks, the acceptance criteria requires the effective neutron multiplication factor to be  $\leq 0.95$ , including uncertainties, for the fully flooded conditions and  $\leq 0.98$ , including uncertainties, for the optimum moderation conditions.

This report shows that the acceptance criteria for criticality is met for the Turkey Point Units 3 and 4 fresh fuel racks for the storage of Westinghouse 15x15 fuel assemblies under both normal and accident conditions with enrichment limits tabulated below.

<b>Fresh Fuel Storage</b>	Storage of 15x15 fuel assemblies in all cells. Fuel assemblies must have a maximum enrichment no greater than 4.55 w/o in the entire length of the fuel rod.
---------------------------	--

The analytical methods employed herein conform to ANSI N18.2-1973, "Nuclear Safety Criteria for the Design of Stationary Pressurized Water Reactor Plants", Section 5.7 Fuel Handling System; ANSI 57.2-1983, "American Nuclear Society, American National Standard Design Requirements for Light Water Reactor Spent Fuel Storage Facilities at Nuclear Power Plants", Section 6.4.2; ANSI/ANS-57.3-1983, "American Nuclear Society, American National Standard Design Requirements for New Fuel Storage Facilities at Light Water Reactor Plants"; ANSI 8.1-1983, "Validation of Calculational Methods for Nuclear Criticality Safety"; the NRC Standard Review Plan<sup>(4)</sup>, Section 9.

**Table 1. Nominal Fuel Parameters Employed in the Criticality Analysis**

<b>Parameter</b>	<b>Westinghouse 15x15 DRFA</b>
Number of Fuel Rods per Assembly	204
Rod Clad O.D. (inch)	0.422
Clad Thickness (inch)	0.0243
Fuel Pellet O.D. (inch)	0.3659
Fuel Pellet Density (% of Theoretical)	96
Fuel Pellet Dishing Factor (%)	1.187
Rod Pitch (inch)	0.563
Number of Guide Tubes	20
Guide Tube O.D. (inch)	0.533
Guide Tube Thickness (inch)	0.017
Number of Instrument Tubes	1
Instrument Tube O.D. (inch)	0.533
Instrument Tube Thickness (inch)	0.017

**Table 2. Fresh Fuel Storage Cell and Fuel Parameters**

<b>Parameter</b>		<b>Dimension</b>	<b>Tolerance</b>	<b>Value Used</b>
Pitch	inch	21.0	+0.125/-0.125	20.875
Sourrounding Concrete	inch			72
L-angle Width	inch	2.5x2.5		2.5x2.5
L-angle Thickness	inch	0.25		0.25
L-angle ID	inch	9.0	+0.05/-0.075	9.0
Distance of wall from the Center of the Outer Assembly	inch			
West	inch			42
North	inch			30
East	inch			54
South	inch			73
Fuel Density	%	96	+2/-2	98
Dishing	%	1.187		0
Enrichment	%	4.50	+0.05/-0.05	4.55

Figure 1. Turkey Point Unit 4 Fresh Fuel Storage Cell Layout





Figure 2. Turkey Point Units 3 and 4 Fresh Fuel Rack  $K_{eff}$  as a Function of Water Density



## Bibliography

1. Newmyer, W.D., *Westinghouse Spent Fuel Rack Criticality Analysis Methodology*, WCAP-14416, -NP-A, Revision 1, November 1996.
2. American Nuclear Society, *American National Standard Design Requirements for Light Water Reactor Spent Fuel Storage Facilities at Nuclear Power Plants*, ANSI/ANS-57.2-1983, October 7, 1983.
3. American Nuclear Society, *American National Standard Design Requirements for New Fuel Storage Facilities at Light Water Reactor Plants*, ANSI/ANS-57.3-1983, January 13, 1983.
4. U.S. Nuclear Regulatory Commission, Standard Review Plan, NUREG-0800, July 1981.
5. American Nuclear Society, *American National Standard for Nuclear Criticality Safety in Operation with Fissionable Materials Outside Reactors*, ANSI/ANS-8.1-1983, October 7, 1983.

L-99-176  
Attachment 8

**ATTACHMENT 8**

**Turkey Point Units 3 & 4  
Monthly Silica Concentration (ppm)**

**Table 1**  
**Turkey Point Units 3 and 4**  
**Monthly Silica Concentration (ppm)**

January 1993 - September 1999

Month/YY	Unit 3	Unit 4
Jan-93	5.66	3.40
Feb-93	4.15	3.85
Mar-93	5.27	4.63
Apr-93	6.97	4.26
May-93	7.50	4.50
Jun-93	7.80	5.40
Jul-93	8.20	4.85
Aug-93	7.45	4.30
Sep-93	7.29	3.30
Oct-93	6.65	4.85
Nov-93	7.70	1.97
Dec-93	5.68	3.80
Jan-94	8.00	4.20
Feb-94	7.40	3.71
Mar-94	7.12	4.13
Apr-94	5.10	3.80
May-94	4.95	3.95
Jun-94	2.57	5.00
Jul-94	3.25	4.70
Aug-94	5.00	4.80
Sep-94	5.50	5.00
Oct-94	5.40	5.30
Nov-94	7.00	4.20
Dec-94	7.90	4.40
Jan-95	4.95	4.60
Feb-95	5.30	4.55
Mar-95	5.80	5.23
Apr-95	8.00	4.54
May-95	7.50	4.90
Jun-95	7.80	5.40
Jul-95	8.21	4.50
Aug-95	7.97	4.85
Sep-95	7.10	5.52
Oct-95	6.40	5.70
Nov-95	7.00	4.80
Dec-95	5.00	4.80

Month/YY	Unit 3	Unit 4
Jan-96	6.40	4.70
Feb-96	5.80	4.50
Mar-96	6.80	4.70
Apr-96	8.70	5.65
May-96	8.00	6.10
Jun-96	5.50	4.20
Jul-96	9.16	6.30
Aug-96	12.00	5.30
Sep-96	11.70	5.20
Oct-96	8.00	5.90
Nov-96	10.98	* 5.50
Dec-96	* 5.36	4.10
Jan-97	** 4.75	5.40
Feb-97	4.62	4.60
Mar-97	10.70	* 5.15
Apr-97	* 10.90	* 7.50
May-97	11.00	6.10
Jun-97	6.40	7.50
Jul-97	12.21	7.40
Aug-97	12.21	6.40
Sep-97	12.21	6.14
Oct-97	12.21	6.00
Nov-97	12.60	6.20
Dec-97	* 12.10	5.90
Jan-98	11.95	6.89
Feb-98	12.21	7.30
Mar-98	11.90	3.70
Apr-98	9.40	3.40
May-98	8.00	3.60
Jun-98	6.90	4.70
Jul-98	5.80	7.80
Aug-98	2.80	7.40
Sep-98	* 24.83	8.40
Oct-98	13.70	6.10
Nov-98	* 9.70	9.80
Dec-98	11.10	10.10

Month/YY	Unit 3	Unit 4
Jan-99	13.92	* 8.81
Feb-99	* 13.89	* 8.59
Mar-99	13.70	* 8.48
Apr-99	** 13.94	7.50
May-99	14.19	7.90
Jun-99	10.20	7.00
Jul-99	15.00	7.83
Aug-99	13.00	** 8.47
Sep-99	* 15.58	8.10

Notes:

\* Average for month

\*\* Interpolated

Data Sources:

Reference 17 and PTN Chemistry Logs