

Commonwealth Edison Company
LaSalle Generating Station
2601 North 21st Road
Marseilles, IL 61341-9757
Tel 815-357-6761



December 1, 1999

United States Nuclear Regulatory Commission
Attention: Document Control Desk
Washington, D.C. 20555

LaSalle County Station, Units 1 and 2
Facility Operating License Nos. NPF-11 and NPF-18
NRC Docket Nos. 50-373 and 50-374

Subject: Licensee Event Report

In accordance with 10 CFR 50.73(a)(2)(i), Commonwealth Edison (ComEd) Company is submitting Licensee Event Report #99-004-00, Docket No. 050-373.

Attachment A provides the commitments for this submittal.

Should you have any questions concerning this letter, please contact Mr. Frank A. Spangenberg, III, Regulatory Assurance Manager, at (815) 357-6761, extension 2383.

Respectfully,

A handwritten signature in black ink, appearing to read "Jeffrey A. Benjamin", with a horizontal line extending to the right.

for
Jeffrey A. Benjamin
Site Vice President
LaSalle County Station

Attachments: Regulatory Commitment(s) - Attachment A
Licensee Event Report

cc: Regional Administrator - NRC Region III
NRC Senior Resident Inspector - LaSalle County Station

JE22

Attachment A
Regulatory Commitment(s)

ComEd is committing to the following actions. Any other actions discussed in this submittal represent intended or planned actions by ComEd. They are described to the NRC for the NRC's information and are not regulatory commitments.

<i>Regulatory Commitment(s)</i>	<i>Tracking Number</i>
A supplement to this report will be submitted detailing the results of the root cause investigation. The supplement will address whether past performances of the Rod Block Monitor surveillance procedures resulted in actual non-compliance with Technical Specification requirements. The supplement will also include the results of an extent of condition review of procedures that could impact the operability of the APRMs.	ATM# 18727-31