

PETER E. KATZ
Plant General Manager
Calvert Cliffs Nuclear Power Plant

Baltimore Gas and Electric Company
Calvert Cliffs Nuclear Power Plant
1650 Calvert Cliffs Parkway
Lusby, Maryland 20657
410 495-4101

*A Member of the
Constellation Energy Group*



December 7, 1999

U. S. Nuclear Regulatory Commission
Washington, DC 20555

ATTENTION: Document Control Desk

SUBJECT: Calvert Cliffs Nuclear Power Plant
Unit Nos. 1 & 2; Docket Nos. 50-317 & 50-318
November 1999 Operating Data Reports

The subject reports are being sent to you as required by Technical Specification 5.6.4.

Should you have any questions, please contact Mr. Bruce B. Mrowca at (410) 495-3989.

Very truly yours,

A handwritten signature in black ink, appearing to read 'P.E. Katz', is written over the typed name.

PEK/EMT/bjd

Attachments

cc: R. S. Fleishman, Esquire
J. E. Silberg, Esquire
A. W. Dromerick, NRC
S. R. Peterson, NRC
H. J. Miller, NRC

Resident Inspector, NRC
R. I. McLean, DNR
J. H. Walter, PSC
P. Lewis, INPO
K. N. Larson, ANI

JE24

PAR ADOCT 05000317

UNIT SHUTDOWNS

DOCKET NO. 50-317
 UNIT NAME Calvert Cliffs - U1
 DATE December 3, 1999
 COMPLETED BY Herman O. Olsen
 TELEPHONE (410) 495-6734

REPORTING MONTH November 1999

NO.	DATE	TYPE F: FORCED S: SCHEDULED	DURATION (HOURS)	REASON ¹	METHOD OF SHUTTING DOWN ²	CAUSE/CORRECTIVE ACTIONS COMMENTS
						There were no shutdowns this month.

¹ Reason:

- A - Equipment Failure
- B - Maintenance or Test
- C - Refueling
- D - Regulatory Restriction
- E - Operator Training & License Examination
- F - Administrative
- G - Operational Error
- H - Other

² Method:

- 1 - Manual
- 2 - Manual Scram.
- 3 - Automatic Scram.
- 4 - Continued
- 5 - Other

DOCKET NO. 50-317
CALVERT CLIFFS - UNIT 1
December 3, 1999

SUMMARY OF OPERATING EXPERIENCE

November 1999

The unit operated at 100% for the entire month.

UNIT SHUTDOWNS

DOCKET NO.	50-318
UNIT NAME	Calvert Cliffs-U2
DATE	December 3, 1999
COMPLETED BY	Herman O. Olsen
TELEPHONE	(410) 495-6734

REPORT MONTH November 1999

NO.	DATE	TYPE F: FORCED S: SCHEDULED	DURATION (HOURS)	REASON ¹	METHOD OF SHUTTING DOWN ²	CAUSE/CORRECTIVE ACTIONS COMMENTS
						There were no shutdowns this month.

- ¹ Reason:
- A - Equipment Failure
 - B - Maintenance or Test
 - C - Refueling
 - D - Regulatory Restriction
 - E - Operator Training & License Examination
 - F - Administrative
 - G - Operational Error
 - H - Other

- ² Method:
- 1 - Manual
 - 2 - Manual Scram.
 - 3 - Automatic Scram.
 - 4 - Continued
 - 5 - Other

DOCKET NO. 50-318
CALVERT CLIFFS - UNIT 2
December 3, 1999

SUMMARY OF OPERATING EXPERIENCE

October 1999

The unit began the month at 100% power.

On 11/05/99 at 2015 power was reduced to 85% to allow for Main Turbine valve testing and waterbox cleaning. Power was returned to 100% on 11/06/99 at 0616.

The unit operated at 100% power for the remainder of the month.