



FPL

DEC 08 1999

L-99-267
10 CFR 50.36

U. S. Nuclear Regulatory Commission
Attn: Document Control Desk
Washington, D. C. 20555

Re: Turkey Point Units 3 and 4
Docket Nos. 50-250 and 50-251
Monthly Operating Report - November, 1999

In accordance with the requirements of Turkey Point Units 3 and 4 Technical Specification 6.9.1.5, and the guidance of Generic Letter 97-02, attached are the November, 1999, Operating Data Report and Summary of Operating Experience for Turkey Point Units 3 and 4.

Very truly yours,

R. J. Hovey
Vice President
Turkey Point Plant

OIH

Attachments

cc: Regional Administrator, Region II, USNRC
Senior Resident Inspector, USNRC, Turkey Point Plant

IE24

AVERAGE DAILY UNIT POWER LEVEL

DOCKET NO. 50-250
UNIT: Turkey Point #3
DATE: December 3, 1999
COMPLETED BY: O.I. Hanek
TELEPHONE: (305) 246-6607

REPORT MONTH November, 1999

DAY	AVERAGE DAILY POWER LEVEL (MWe-Net)
11/1/99	710
11/2/99	709
11/3/99	716
11/4/99	724
11/5/99	726
11/6/99	724
11/7/99	718
11/8/99	722
11/9/99	722
11/10/99	722
11/11/99	720
11/12/99	720
11/13/99	721
11/14/99	720
11/15/99	692
11/16/99	317
11/17/99	0
11/18/99	348
11/19/99	720
11/20/99	723
11/21/99	722
11/22/99	720
11/23/99	717
11/24/99	717
11/25/99	716
11/26/99	714
11/27/99	716
11/28/99	722
11/29/99	725
11/30/99	726

OPERATING DATA REPORT

DOCKET NO. 50-250
UNIT NAME TURKEY POINT UNIT 3
DATE December 3, 1999
COMPLETED BY O. I. Hanek
TELEPHONE (305) 246-6607

REPORTING PERIOD November, 1999
(Month/Year)

1. Design Electrical Rating (MWe-Net)_____ 720
2. Maximum Dependable Capacity (MWe-Net)_____ 693

	<u>MONTH</u>	<u>-YTD-</u>	<u>CUMULATIVE</u>
3. Number of Hours Reactor Was Critical_____	693.8	7963.4	168873.4
4. Number of Hours Generator Was On Line_____	677.2	7940.5	166658.1
5. Unit Reserve Shutdown Hours_____	0.0	0.0	121.8
6. Net Electrical Energy (MWH)_____	481025	5575620	107396479

UNIT SHUTDOWNS

DOCKET NO. 50-250
UNIT NAME: Turkey Point #3
DATE: December 3, 1999
COMPLETED BY: O. I. Hanek
TELEPHONE: (305) 246-6607

REPORT MONTH November, 1999

No.	Date	Type ¹	Duration (Hours)	Reason ²	Method of Shutting Down Reactor ³	Cause & Corrective Action Comments
19900032	11/16/99	F	42.8	A	1	Turbine control valve inoperable, testing and repairs

1

F - Forced
S - Scheduled

2

Reason
A - Equipment Failure
B - Maintenance or Test
C - Refueling
D - Regulatory restriction
E - Operator Training &
License Examination
F - Administrative
G - Operational Error (Explain)
H - Other (Explain)

3

Method
1 - Manual
2 - Manual Scram
3 - Automatic Scram
4 - Continuation
5 - Other (Explain)

SUMMARY OF OPERATING EXPERIENCE

DOCKET NO. 50-250
UNIT: Turkey Point #3
DATE: December 3, 1999
COMPLETED BY: O. I. Hanek
TELEPHONE: (305) 246-6607

REPORT MONTH November, 1999

Unit 3 operated essentially at 100% in the beginning of the month of November, 1999. On November 15, 1999, power reduction was commenced to test the No. 2 turbine control valve. On November 16, 1999, the unit was taken offline to repair the No. 2 turbine control valve. On November 18, 1999, Unit 3 resumed 100% power operation and remained at that power level for the rest of the month.

AVERAGE DAILY UNIT POWER LEVEL

DOCKET NO. 50-251
UNIT: Turkey Point #4
DATE: December 3, 1999
COMPLETED BY: O. I. Hanek
TELEPHONE: (305) 246-6607

REPORT MONTH November, 1999

DAY	AVERAGE DAILY POWER LEVEL (MWe-Net)
11/1/99	710
11/2/99	710
11/3/99	717
11/4/99	725
11/5/99	727
11/6/99	726
11/7/99	723
11/8/99	687
11/9/99	290
11/10/99	516
11/11/99	715
11/12/99	720
11/13/99	724
11/14/99	723
11/15/99	722
11/16/99	714
11/17/99	724
11/18/99	728
11/19/99	726
11/20/99	725
11/21/99	722
11/22/99	719
11/23/99	718
11/24/99	719
11/25/99	716
11/26/99	714
11/27/99	716
11/28/99	722
11/29/99	725
11/30/99	725

OPERATING DATA REPORT

DOCKET NO. 50-251
UNIT NAME TURKEY POINT UNIT 4
DATE December 3, 1999
COMPLETED BY O. I. Hanek
TELEPHONE (305) 246-6607

REPORTING PERIOD November, 1999
(Month/Year)

1. Design Electrical Rating (MWe-Net) _____ 720
2. Maximum Dependable Capacity (MWe-Net) _____ 693

	<u>MONTH</u>	<u>-YTD-</u>	<u>CUMULATIVE</u>
3. Number of Hours Reactor Was Critical _____	720	7462.7	165530.2
4. Number of Hours Generator Was On Line _____	720	7441.8	161178.3
5. Unit Reserve Shutdown Hours _____	0.0	0.0	577.2
6. Net Electrical Energy (MWH) _____	502823	5197566	104870664

UNIT SHUTDOWNS

DOCKET NO. 50-251
 UNIT NAME: Turkey Point #4
 DATE: December 3, 1999
 COMPLETED BY: O. I. Hanek
 TELEPHONE: (305) 246-6607

REPORT MONTH November, 1999

No.	Date	Type ¹	Duration (Hours)	Reason ²	Method of Shutting Down Reactor ³	Cause & Corrective Action Comments
N/A	N/A					

1

F - Forced
 S - Scheduled

2

Reason
 A - Equipment Failure
 B - Maintenance or Test
 C - Refueling
 D - Regulatory restriction
 E - Operator Training &
 License Examination
 F - Administrative
 G - Operational Error (Explain)
 H - Other (Explain)

3

Method
 1 - Manual
 2 - Manual Scram
 3 - Automatic Scram
 4 - Continued
 5 - Other (Explain)

119

SUMMARY OF OPERATING EXPERIENCE

DOCKET NO.	<u>50-251</u>
UNIT:	<u>Turkey Point #4</u>
DATE:	<u>December 3, 1999</u>
COMPLETE BY:	<u>O. I. Hanek</u>
TELEPHONE:	<u>(305)246-6607</u>

REPORT MONTH November, 1999

Unit 4 operated at essentially 100% until November 8, 1999, when reactor power was reduced to approximately 40% for turbine valve testing. The unit returned to 100% power on November 10, 1999, and operated at that power level for the rest of the month of November, 1999.