



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D.C. 20555-0001

TXU ELECTRIC COMPANY

COMANCHE PEAK STEAM ELECTRIC STATION, UNIT NO. 1

DOCKET NO. 50-445

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 73  
License No. NPF-87


1. The Nuclear Regulatory Commission (the Commission) has found that:
  - A. The application for amendment by TXU Electric Company (TXU Electric) dated February 27, 1998, as supplemented by letters dated June 10, 1998, and October 22, 1999, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations set forth in 10 CFR Chapter I;
  - B. The facility will operate in conformity with the application, as amended, the provisions of the Act, and the rules and regulations of the Commission;
  - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
  - D. The issuance of this license amendment will not be inimical to the common defense and security or to the health and safety of the public; and
  - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.
2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment and paragraph 2.C.(2) of Facility Operating License No. NPF-87 is hereby amended to read as follows:

(2) Technical Specifications and Environmental Protection Plan

The Technical Specifications contained in Appendix A, as revised through Amendment No. 73, and the Environmental Protection Plan contained in Appendix B, are hereby incorporated into this license. TXU Electric shall operate the facility in accordance with the Technical Specifications and the Environmental Protection Plan.

3. The license amendment is effective as of its date of issuance and shall be implemented within 30 days from the date of issuance.

FOR THE NUCLEAR REGULATORY COMMISSION



Robert A. Gramm, Chief, Section 1  
Project Directorate IV & Decommissioning  
Division of Licensing Project Management  
Office of Nuclear Reactor Regulation

Attachment: Changes to the Technical  
Specifications

Date of Issuance: December 8, 1999



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D.C. 20555-0001

TXU ELECTRIC COMPANY

COMANCHE PEAK STEAM ELECTRIC STATION, UNIT NO. 2

DOCKET NO. 50-446

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 73  
License No. NPF-89

1. The Nuclear Regulatory Commission (the Commission) has found that:
  - A. The application for amendment by TXU Electric Company (TXU Electric) dated February 27, 1998, as supplemented by letters dated June 10, 1998, and October 22, 1999, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations set forth in 10 CFR Chapter I;
  - B. The facility will operate in conformity with the application, as amended, the provisions of the Act, and the rules and regulations of the Commission;
  - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
  - D. The issuance of this license amendment will not be inimical to the common defense and security or to the health and safety of the public; and
  - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.
2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment and paragraph 2.C.(2) of Facility Operating License No. NPF-89 is hereby amended to read as follows:

(2) Technical Specifications and Environmental Protection Plan

The Technical Specifications contained in Appendix A, as revised through Amendment No. 73 , and the Environmental Protection Plan contained in Appendix B, are hereby incorporated into this license. TXU Electric shall operate the facility in accordance with the Technical Specifications and the Environmental Protection Plan.

3. This license amendment is effective as of its date of issuance and shall be implemented within 30 days from the date of issuance.

FOR THE NUCLEAR REGULATORY COMMISSION



Robert A. Gramm, Chief, Section 1  
Project Directorate IV & Decommissioning  
Division of Licensing Project Management  
Office of Nuclear Reactor Regulation

Attachment: Changes to the Technical  
Specifications

Date of Issuance: December 8, 1999

ATTACHMENT TO LICENSE AMENDMENT NO. 73

TO FACILITY OPERATING LICENSE NO. NPF-87

AND AMENDMENT NO. 73

TO FACILITY OPERATING LICENSE NO. NPF-89

DOCKET NOS. 50-445 AND 50-446

Replace the following pages of the Appendix A Technical Specifications with the attached revised pages. The revised pages are identified by amendment number and contain marginal lines indicating the areas of change.

Remove

Insert

3.3-34

3.3-34

Table 3.3.2-1 (page 6 of 6)  
Engineered Safety Feature Actuation System Instrumentation

FUNCTION	APPLICABLE MODES OR OTHER SPECIFIED CONDITIONS	REQUIRED CHANNELS	CONDITIONS	SURVEILLANCE REQUIREMENTS	ALLOWABLE VALUE(a)
7. Automatic Switchover to Containment Sump					
a. Automatic Actuation Logic and Actuation Relays	1, 2, 3, 4	2 trains	C	SR 3.3.2.2 SR 3.3.2.4 SR 3.3.2.6	NA
b. Refueling Water Storage Tank (RWST) Level - Low Low	1, 2, 3, 4	4	K	SR 3.3.2.1 SR 3.3.2.5 SR 3.3.2.10 SR 3.3.2.12	≥ 43.9% instrument span (Unit 1) ≥ 44.1% instrument span (Unit 2)
Coincident with Safety Injection	Refer to Function 1 (Safety Injection) for all initiation functions and requirements.				
8. ESFAS Interlocks					
a. Reactor Trip, P-4	1, 2, 3	1 per train, 2 trains	F	SR 3.3.2.11	NA
b. Pressurizer Pressure, P-11	1, 2, 3	3	L	SR 3.3.2.5 SR 3.3.2.9	≤ 1975.2 psig (Unit 1) ≤ 1976.4 psig (Unit 2)

(a) The Allowable Value defines the limiting safety system setting. See the Bases for the Trip Setpoints.