

50-280/281/338/339



**UNITED STATES  
NUCLEAR REGULATORY COMMISSION**

WASHINGTON, D.C. 20555-0001

December 13, 1999

Mr. J. P. O'Hanlon  
Senior Vice President - Nuclear  
Virginia Electric and Power Company  
5000 Dominion Blvd.  
Glen Allen, Virginia 23060

**SUBJECT: SURRY AND NORTH ANNA POWER STATIONS, UNITS 1 AND 2 RE:  
COMPLETION OF LICENSING ACTION FOR GENERIC LETTER 98-04,  
"POTENTIAL FOR DEGRADATION OF THE EMERGENCY CORE COOLING  
SYSTEM AND THE CONTAINMENT SPRAY SYSTEM AFTER A LOSS-OF-  
COOLANT ACCIDENT BECAUSE OF CONSTRUCTION AND PROTECTIVE  
COATING DEFICIENCIES AND FOREIGN MATERIAL IN CONTAINMENT,"  
DATED JULY 14, 1998 (TAC NOS. MA4106, MA4107, MA4072, AND MA4073)**

Dear Mr. O'Hanlon:

On July 14, 1998, the U.S. Nuclear Regulatory Commission (NRC) issued Generic Letter (GL) 98-04, "Potential for Degradation of the Emergency Core Cooling System and the Containment Spray System After a Loss-of-Coolant Accident Because of Construction and Protective Coating Deficiencies and Foreign Material in Containment," to all holders of operating licenses or construction permits. The NRC issued GL 98-04 to determine the status of containment coating programs.

In GL 98-04, the NRC staff specifically requested that the licensees provide information outlined below for each of their facilities.

- (1) A summary description of the plant-specific program or programs implemented to ensure that Service Level 1 protective coatings used inside the containment are procured, applied, and maintained in compliance with applicable regulatory requirements and the plant-specific licensing basis for the facility. Include a discussion of how the plant-specific program meets the applicable criteria of 10 CFR Part 50, Appendix B, as well as information regarding any applicable standards, plant-specific procedures or other guidance used for (a) controlling the procurement of coatings and paints used at the facility; (b) the qualification testing of protective coatings; and (c) surface preparation, application, surveillance, and maintenance activities for protective coatings. Maintenance activities refer to rework of degraded coatings, removing degraded coatings to sound coatings, correctly preparing the surfaces, applying new coating, and verifying the quality of coatings.

**NRC FILE CENTER COPY**

DF01

PDL A0007 05000280

(2) Information demonstrating compliance with item (i) or item (ii).

- (i) For plants with licensing-basis requirements for tracking the amount of unqualified coatings inside the containment and for assessing the impact of potential coating debris on the operation of safety-related systems, structures, and components (SSCs) during a postulated design basis loss-of-coolant accident (DB LOCA), the following information shall be provided to demonstrate compliance:
  - (a) The date and findings of the last assessment of coatings and the planned date of the next assessment of coatings.
  - (b) The limit for the amount of unqualified protective coatings allowed in the containment and how this limit is determined. Discuss any conservatism in the method used to determine this limit.
  - (c) If a commercial-grade dedication program is being used at your facility for dedicating commercial-grade coatings for Service Level 1 applications inside the containment, discuss how the program adequately qualifies a coating for Service Level 1. Identify what standards or other guidance are currently being used to dedicate containment coatings at your facility.
- (ii) For plants without the above licensing-basis requirements, information shall be provided to demonstrate compliance with the requirements of 10 CFR 50.46b(5), "Long-term cooling" and the functional capability of the safety-related containment spray system (CSS) as set forth in your licensing basis. If a licensee can demonstrate this compliance without quantifying the amount of unqualified coatings, this is acceptable. The following information shall be provided:

If a commercial-grade dedication program is not being used at your facility for qualifying and dedicating commercial-grade coatings for Service Level 1 applications, provide the regulatory and safety basis for not controlling these coatings in accordance with such a program. Additionally, explain why the facility's licensing basis does not require such a program.

In response to GL 98-04, you provided a letter dated November 10, 1998, for Surry Power Station, Units 1 and 2, and North Anna Power Station, Units 1 and 2. This submittal provided the information requested by GL 98-04. Clarification was provided during a phone call that took place on October 26, 1999. The staff has reviewed your response and has concluded that all requested information has been provided; therefore, we consider GL 98-04 to be closed for your facilities. We thank you for your prompt and complete response.

J. P. O'Hanlon

- 3 -

If you have any questions regarding this matter, please contact me at (301) 415-1448.

Sincerely,

A handwritten signature in cursive script that reads "Gordon E. Edison". The signature is written in black ink and is positioned below the word "Sincerely,".

Gordon E. Edison, Senior Project Manager, Section 1  
Project Directorate II  
Division of Licensing Project Management  
Office of Nuclear Reactor Regulation

Docket Nos. 50-280, 50-281, 50-338, and 50-339

cc: See next page

If you have any questions regarding this matter, please contact me at (301) 415-1448.

Sincerely,

Original signed by:

Gordon E. Edison, Senior Project Manager, Section 1  
Project Directorate II  
Division of Licensing Project Management  
Office of Nuclear Reactor Regulation

Docket Nos. 50-280, 50-281, 50-338, and 50-339

cc: See next page

DISTRIBUTION:

- File Center
- PUBLIC
- PD II-1 R/F
- REmch
- EDunnington
- GEEdison (2)
- RPulsifer
- CLauron
- JDavis
- OGC
- ACRS
- RHaag, RII

DOCUMENT NAME: G:\PDII-1\NOANNA\gl98-04closeout.wpd

INDICATE IN BOX: "C"=COPY W/O ATTACHMENT/ENCLOSURE, "E"=COPY W/ATT/ENCL, "N"=NO COPY

OFFICE	PDII-1:PM	E	PDII-1:LA	E	SC: EMCB	PDII-1:SC
NAME	GEEdison:cn	A	EDunnington	ETD	ESullivan	REmch RLE
DATE	12/8/99		12/8/99		12/8/99	12/10/99

OFFICIAL RECORD COPY

Mr. J. P. O'Hanlon  
Virginia Electric & Power Company

North Anna Power Station  
Units 1 and 2

cc:

Mr. J. Jeffrey Lunsford  
County Administrator  
Louisa County  
P.O. Box 160  
Louisa, Virginia 23093

Mr. W. R. Matthews  
Site Vice President  
North Anna Power Station  
P. O. Box 402  
Mineral, Virginia 23117

Mr. Donald P. Irwin, Esquire  
Hunton and Williams  
Riverfront Plaza, East Tower  
951 E. Byrd Street  
Richmond, Virginia 23219

Mr. E. S. Grecheck  
Site Vice President  
Surry Power Station  
Virginia Electric and Power Company  
5570 Hog Island Road  
Surry, Virginia 23883

Dr. W. T. Lough  
Virginia State Corporation  
Commission  
Division of Energy Regulation  
P. O. Box 1197  
Richmond, Virginia 23209

Robert B. Strobe, M.D., M.P.H.  
State Health Commissioner  
Office of the Commissioner  
Virginia Department of Health  
P.O. Box 2448  
Richmond, Virginia 23218

Old Dominion Electric Cooperative  
4201 Dominion Blvd.  
Glen Allen, Virginia 23060

Mr. J. H. McCarthy, Manager  
Nuclear Licensing & Operations  
Support  
Virginia Electric and Power Company  
Innsbrook Technical Center  
5000 Dominion Blvd.  
Glen Allen, Virginia 23060

Office of the Attorney General  
Commonwealth of Virginia  
900 East Main Street  
Richmond, Virginia 23219

Senior Resident Inspector  
North Anna Power Station  
U.S. Nuclear Regulatory Commission  
1024 Haley Drive  
Mineral, Virginia 23117

Virginia Electric and Power Company

Surry Power Station

cc:

Mr. Donald P. Irwin, Esq.  
Hunton and Williams  
Riverfront Plaza, East Tower  
951 E. Byrd Street  
Richmond, Virginia 23219

Mr. E. S. Grecheck  
Site Vice President  
Surry Power Station  
Virginia Electric and Power Company  
5570 Hog Island Road  
Surry, Virginia 23883

Senior Resident Inspector  
Surry Power Station  
U. S. Nuclear Regulatory Commission  
5850 Hog Island Road  
Surry, Virginia 23883

Chairman  
Board of Supervisors of Surry County  
Surry County Courthouse  
Surry, Virginia 23683

Dr. W. T. Lough  
Virginia State Corporation  
Commission  
Division of Energy Regulation  
P. O. Box 1197  
Richmond, Virginia 23209

Robert B. Strobe, M.D., M.P.H.  
State Health Commissioner  
Office of the Commissioner  
Virginia Department of Health  
P.O. Box 2448  
Richmond, Virginia 23218

Office of the Attorney General  
Commonwealth of Virginia  
900 East Main Street  
Richmond, Virginia 23219

Mr. J. H. McCarthy, Manager  
Nuclear Licensing & Operations  
Support  
Innsbrook Technical Center  
Virginia Electric and Power Company  
5000 Dominion Blvd.  
Glen Allen, Virginia 23060

Mr. J. P. O'Hanlon  
Senior Vice President - Nuclear  
Virginia Electric and Power Company  
Innsbrook Technical Center  
5000 Dominion Blvd.  
Glen Allen, Virginia 23060

Mr. W. R. Matthews  
Site Vice President  
North Anna Power Station  
Virginia Electric and Power Company  
P. O. Box 402  
Mineral, Virginia 23117