



**Entergy**

**Entergy Operations, Inc.**  
1448 S.R. 333  
Russellville, AR 72801  
Tel 501 858-5000

December 7, 1999

2CAN129906

U. S. Nuclear Regulatory Commission  
Document Control Desk  
Mail Station OP1-17  
Washington, DC 20555


Subject: Arkansas Nuclear One - Unit 2  
Docket Nos. 50-368  
License Nos. NPF-6  
Response to IR 99-09

Gentlemen:

During the telephonic exit meeting for Inspection Report 99-09 that occurred on November 8, 1999, Arkansas Nuclear One (ANO) committed to replace the carbon steel service water pipe on the Unit 2 Loop 1 emergency diesel generator during the Unit 2 mid-cycle outage (2P99). The purpose of this letter is to confirm that ANO replaced this piping in November 1999, during 2P99.

Should you have questions or comments, please call me at 501-858-4601.

Very truly yours,

  
Jimmy D. Vandergrift  
Director, Nuclear Safety

JDV/RMC

IED1

PDR ADOCK 05000368

cc: Mr. Ellis W. Merschhoff  
Regional Administrator  
U. S. Nuclear Regulatory Commission  
Region IV  
611 Ryan Plaza Drive, Suite 400  
Arlington, TX 76011-8064

NRC Senior Resident Inspector  
Arkansas Nuclear One  
P.O. Box 310  
London, AR 72847

Mr. Chris Nolan  
NRR Project Manager Region IV/ANO-2  
U. S. Nuclear Regulatory Commission  
NRR Mail Stop 13-D-18  
One White Flint North  
11555 Rockville Pike  
Rockville, MD 20852