

Commonwealth Edison Company  
Quad Cities Generating Station  
22710 206th Avenue North  
Cordova, IL 61242-9740  
Tel 309-654-2241



December 8, 1999

SVP-99-233

U. S. Nuclear Regulatory Commission  
ATTN: Document Control Desk  
Washington, D.C. 20555

Quad Cities Nuclear Power Station, Unit 1  
Facility Operating License No. DPR-29  
NRC Docket No. 50-254

Enclosed is Licensee Event Report (LER) 254/99-003, Revision 01, for Quad Cities Nuclear Power Station.

This report is submitted in accordance with the requirements of the Code of Federal Regulations, Title 10, Part 50.73(a)(2)(v)(B). The licensee shall report any event or condition that could have prevented the removal of residual heat.

We are committing to the following actions:

1. The rest of the contactors maintained per QCEPM 0400-02 will be reviewed to determine if replacement or repair is required.
2. The failed contactor will be inspected and a determination will be made concerning the need for further failure analysis.
3. QCEPM 0400-02 will be revised to include directions for installing the lever arm bolt, nuts, and roll pin and to include information on the new contactors that do not require lubrication.

Other actions described in the submittal represent intended or planned actions by Commonwealth Edison (ComEd) Company. They are described for the NRC's information and are not regulatory commitments.


PDR ADOCK 05000234

JE22

December 8, 1999  
U.S. Nuclear Regulatory Commission  
Page 2

Should you have any questions concerning this letter, please contact Mr. C.C. Peterson at (309) 654-2241, extension 3609.

Respectfully,



Joel P. Dimmette, Jr.  
Site Vice President  
Quad Cities Nuclear Power Station

cc: Regional Administrator – NRC Region III  
NRC Senior Resident Inspector – Quad Cities Nuclear Power Station