

Commonwealth Edison Company  
Quad Cities Generating Station  
22710 206th Avenue North  
Cordova, IL 61242-9740  
Tel 309-654-2241



December 8, 1999

SVP-99-234

U. S. Nuclear Regulatory Commission  
ATTN: Document Control Desk  
Washington, D.C. 20555

Quad Cities Nuclear Power Station, Unit 1  
Facility Operating License No. DPR-29  
NRC Docket No. 50-254

Enclosed is Licensee Event Report (LER) 254/99-004, Revision 01, for Quad Cities Nuclear Power Station.

This report is submitted in accordance with the requirements of the Code of Federal Regulations, Title 10, 50.73(a)(2)(i)(B), the licensee shall report any operation or condition prohibited by the Plant's Technical Specifications, 50.73(a)(2)(ii)(B), the Licensee shall report any serious degradation in the condition of the plant or safety barriers, or that resulted in a condition that was outside the design basis of the plant, and Part 50.73(a)(2)(v)(D), the licensee shall report any event or condition that alone could have prevented the fulfillment of the safety function of structures or systems that are needed to mitigate the consequences of an accident.

We are committing to the following actions:

1. Control Room HVAC surveillance procedures will be revised to contain appropriate steps to ensure that the correct AFU inlet damper throttle position is checked when the AFU is placed in operation.
2. Instrument Maintenance(IM) Department personnel that perform pitot tube measurements will be briefed on this event and the need to check airflow measuring equipment for fitting and tubing leaks and for pitot tube and sensing line blockage when measuring airflow using a pitot tube.
3. The use of pitot tube airflow instruments when performing flow measurement by pitot tube traverse will be added to the Job Assignment Matrix, and special training and qualification requirements will be incorporated for personnel performing a pitot tube traverse.

Other actions described in the submittal represent intended or planned actions by Commonwealth Edison (ComEd) Company. They are described for the NRC's information and are not regulatory commitments.


PDR ADOCK 05000254

IE22

December 8, 1999  
U.S. Nuclear Regulatory Commission  
Page 2

Should you have any questions concerning this letter, please contact Mr. C.C. Peterson at (309) 654-2241, extension 3609.

Respectfully,

A handwritten signature in cursive script, appearing to read "Joel P. Dimmette, Jr.", written in black ink.

Joel P. Dimmette, Jr.  
Site Vice President  
Quad Cities Nuclear Power Station

cc: Regional Administrator – NRC Region III  
NRC Senior Resident Inspector – Quad Cities Nuclear Power Station