

December 16, 1999

Mr. James Davis, Director
Operations Department
Nuclear Energy Institute
1776 I Street, N. W.
Suite 400
Washington, DC 20006-3708

Dear Mr. Davis:

This is to inform you of our decision on changes to the Standard Technical Specification (STS) NUREGs proposed by the NEI Technical Specification Task Force (TSTF). We propose a modification to TSTF-284, R.2, regarding the guidance in Section 1.4 on the use of surveillance requirement notes that use the terms "met" and "perform." Our comments on this traveler are enclosed.

Please contact me at (301) 415-1161 or e-mail wdb@nrc.gov, if you have any questions or need further information.

Sincerely,

"FRA"

William D. Beckner, Chief
Technical Specifications Branch
Division of Regulatory Improvement Programs
Office of Nuclear Reactor Regulation

Project No. 689
Enclosure: As stated

cc: N. Clarkson, BWOG
H. Pontious, BWROG
T. Weber, CEOG
D. Buschbaum, WOG
D. Hoffman, EXCEL

DISTRIBUTION:

✓ FILE CENTER
PUBLIC
Dmatthews/SNewberry
WDBeckner
RLDennig
TSB R/F
TSB Staff
ADAMS
CHaruck

DOCUMENT NAME:G:\RTSB\Harbuck\Modify TSTF 284 R2 ltr.WPD * see previous concurrences

OFFICE	RTSB/DRIP:NRR	NRR/Proj. 689	SC:RTSB/DRIP:NRR	C:RTSB/DRIP:NRR
NAME	PMCoates <i>per</i>	JBirmingham*	RLDennig	WDBeckner <i>WDB</i>
DATE	12/16/99	12/ /99	12/ 16/99	12/16 /99

OFFICIAL RECORD COPY

ARC FILE CENTER COPY

DB - 217

DF03

PDR REV6P NEI



UNITED STATES
NUCLEAR REGULATORY COMMISSION

WASHINGTON, D.C. 20555-0001

December 16, 1999

Mr. James Davis, Director
Operations Department
Nuclear Energy Institute
1776 I Street, N. W.
Suite 400
Washington, DC 20006-3708

Dear Mr. Davis:

This is to inform you of our decision on changes to the Standard Technical Specification (STS) NUREGs proposed by the NEI Technical Specification Task Force (TSTF). We propose a modification to TSTF-284, R.2, regarding the guidance in Section 1.4 on the use of surveillance requirement notes that use the terms "met" and "perform." Our comments on this traveler are enclosed.

Please contact me at (301) 415-1161 or e-mail wdb@nrc.gov, if you have any questions or need further information.

Sincerely,

A handwritten signature in black ink, appearing to read "William D. Beckner".

William D. Beckner, Chief
Technical Specifications Branch
Division of Regulatory Improvement Programs
Office of Nuclear Reactor Regulation

Project No. 689

Enclosure: As stated

cc: N. Clarkson, BWO
H. Pontious, BWRO
T. Weber, CEOG
D. Buschbaum, WOG
D. Hoffman, EXCEL

cc: Mr. Ralph Beedle
Senior Vice President
and Chief Nuclear Officer
Nuclear Energy Institute
Suite 400
1776 I Street, NW
Washington, DC 20006-3708

Ms. Lynnette Hendricks, Director
Plant Support
Nuclear Energy Institute
Suite 400
1776 I Street, NW
Washington, DC 20006-3708

Mr. Alex Marion, Director
Programs
Nuclear Energy Institute
Suite 400
1776 I Street, NW
Washington, DC 20006-3708

Mr. Charles B. Brinkman, Director
Washington Operations
ABB-Combustion Engineering, Inc.
12300 Twinbrook Parkway, Suite 330
Rockville, Maryland 20852

Mr. David Modeen, Director
Engineering
Nuclear Energy Institute
Suite 400
1776 I Street, NW
Washington, DC 20006-3708

Mr. Anthony Pietrangelo, Director
Licensing
Nuclear Energy Institute
Suite 400
1776 I Street, NW
Washington, DC 20006-3708

Mr. Hank Sepp, Manager
Regulatory and Licensing Engineering
Westinghouse Electric Corporation
P.O. Box 355
Pittsburgh, Pennsylvania 15230

Mr. Jim Davis, Director
Operations
Nuclear Energy Institute
Suite 400
1776 I Street, NW
Washington, DC 20006-3708

Proposed Changes to STS Section 1.4 and TSTF 284, R.2

Modify last sentence of first paragraph of insert 1 as follows:

Examples 1.4-3, 1.4-4, 1.4-5, and 1.4-6 discuss these special situations.

Replace last part of insert 1 beginning with the last sentence of the second paragraph:

Some Surveillances contain notes that modify the Frequency of performance or the conditions during which the acceptance criteria must be satisfied. For these Surveillances, the MODE-entry restrictions of SR 3.0.4 ~~restrictions would~~ may not apply. ~~if both the following conditions are satisfied:~~ a. ~~The~~ Such a Surveillance is not required to be performed prior to entering a MODE or other specified condition in the Applicability of the associated LCO if any of the following three conditions are satisfied:

- a. The Surveillance is not required to be met in the MODE or other specified condition to be entered; or
- b. The Surveillance is required to be met in the MODE or other specified condition to be entered, but has been performed within the specified Frequency (i.e., it is current) and is known not to be failed; or
- c. The Surveillance is required to be met, but not performed, in the MODE or other specified condition to be entered, and is known not to be failed.

~~;~~ and

~~b. The Surveillance is not required to be met or, even if required to be met, is not known to be failed.~~