



GPU Nuclear, Inc.
U.S. Route #9 South
Post Office Box 388
Forked River, NJ 08731-0388
Tel 609-971-4000

December 13, 1999
1940-99-20639

U. S. Nuclear Regulatory Commission
Attention: Document Control Desk
Washington, DC 20555

Dear Sir:

SUBJECT: Oyster Creek Nuclear Generating Station
Docket No. 50-219
Monthly Operating Report - November, 1999

Enclosed are two copies of the November, 1999, Monthly Operating Report for Oyster Creek Nuclear Station. The content and format of information submitted in this report is in accordance with the guidance provided by Generic Letter 97-02.

If you should have any questions, please contact Ms. Brenda DeMerchant, Oyster Creek Regulatory Affairs Engineer, at 609-971-4642.

Very truly yours,

Sander Levin
Acting Site Director

BDeM/gl

Enclosures

cc: Administrator, Region I (2 copies)
NRC Project Manager
NRC Sr. Resident Inspector

IE22

POP ADDCL 0500 0219

APPENDIX A
Operating Data Report

Docket No: 50-219
 Date: 12/03/99
 Completed By: David M. Egan
 Telephone: (609)971- 4818

Reporting Period: November 1999

		MONTH	YEAR TO DATE	CUMULATIVE
1.	DESIGN ELECTRICAL RATING (MWe NET), The nominal net electrical output of the unit specified by the utility and used for the purpose of plant design.	650	*	*
2.	MAXIMUM DEPENDABLE CAPACITY (MWe NET), The gross electrical output as measured at the output terminals of the turbine generator during the most restrictive seasonal conditions minus the normal station service loads.	619	*	*
3.	NUMBER OF HOURS REACTOR WAS CRITICAL. The total number of hours during the gross hours of the reporting period that the reactor was critical.	720.0	8,016.0	185,076.0
4.	HOURS GENERATOR ON LINE. (Service Hours) The total number of hours during the gross hours of the reporting period that the unit operated with the breakers closed to the station bus. The sum of the hours that the generator was on line plus the total outage hours in the reporting period.	720.0	8,016.0	181,194.0
5.	UNIT RESERVE SHUTDOWN HOURS. The total number of hours during the gross hours of the reporting period that the unit was removed from service for economic or similar reasons but was available for operation.	0	0	918.2
6.	NET ELECTRICAL ENERGY (MWH). The gross electrical output of the unit measured at the output terminals of the turbine generator minus the normal station service loads during the gross hours of the reporting period, expressed in megawatt hours. Negative quantities should not be used.	446,150	4,913,878	102,497,961

* Design values have no "Year to Date" or "Cumulative" significance.

Appendix B

Unit Shutdowns

Docket No: 50-219
 Date: 12/03/99
 Completed By: David M. Egan
 Telephone: (609)971- 4818

Reporting Period: November 1999

No.	Date	Type*	Duration (Hours)	Reason ¹	Method of Shutting Down Reactor ²	Cause & Corrective Action to Prevent Recurrence
9	991118	F	0	A	1	On 11/18/99 at 05:55, operators manually reduced power to 70% due to a tube failure in the 'A' main condenser. On 11/21/99 at 01:15, the plant resumed full power operation after the tube was identified and plugged.

*
 F Forced
 S Scheduled

1
Reason:
 A-Equipment Failure (Explain)
 B-Maintenance or Test
 C-Refueling
 D-Regulatory Restriction
 E-Operator Training & Licensing Examination
 F-Administrative
 G-Operational Error (Explain)
 H-Other (Explain)

2
Method:
 1-Manual
 2-Manual Scram
 3-Automatic Scram
 4-Other (Explain)

Summary: During November, Oyster Creek generated 446,150 net MWH electric, which was 100.1% of its MDC rating.