

Mr. J. P. O'Hanlon
Senior Vice President - Nuclear
Virginia Electric and Power Company
5000 Dominion Blvd.
Glen Allen, Virginia 23060

December 16, 1999

SUBJECT: SURRY POWER STATION, UNITS 1 AND 2, AND NORTH ANNA POWER STATION, UNITS 1 AND 2 RE: CLOSEOUT OF GENERIC LETTER 97-06; "DEGRADATION OF STEAM GENERATOR INTERNALS" (TAC NOS. MA0952, MA0953, MA0926 AND MA0927)

Dear Mr. O'Hanlon:

On December 30, 1997, the staff issued Generic Letter (GL) 97-06, "Degradation of Steam Generator Internals." The purpose of GL 97-06 was to obtain information that would enable the staff to verify that the condition of licensees' steam generator internals complies with and conforms to the current licensing bases for their respective facilities.

By letter dated March 30, 1998, you responded to GL-97-06. The staff's review of your response to the GL did not identify any new concerns with the condition of the steam generator internals. The staff did not identify any concerns with the inspection practices employed at your facility to detect degradation of steam generator internals. The staff, therefore, concludes that your response to the GL provides reasonable assurance that the condition of your steam generator internals is in compliance with the current licensing bases for your facilities.

The detailed technical basis that supports the staff's determination for all facilities will be published in a NUREG report. The expected publication date is December 1999. This completes the staff's effort on TAC Nos. MA0952, MA0953, MA0926, and MA0927.

Sincerely,
Original signed by:
Gordon E. Edison, Sr. Project Manager, Section 1
Project Directorate II
Division of Licensing Project Management
Office of Nuclear Reactor Regulation

Docket Nos. 50-280, 50-281, 50-338
and 50-339

cc: See next page

Distribution:

File Center	EDunnington
PUBLIC	GEEdison
PDII-1 Reading	OGC
HBerkow	ACRS
REmch	RHaag, RII

ARC FILE CENTER COPY

DFOI

DOCUMENT NAME: G:\PDII-1\SURRY\MA0952GL97-06.wpd

To receive a copy of this document, indicate in the box C=Copy w/o attachment/enclosure E=Copy with attachment/enclosure N = No copy

OFFICE	PDII-1/PM	E	PDII-1/LA	C	PDII-1/SC				
NAME	GEEdison:mw	A	EDunnington	ETD	REmch	RTE			
DATE	12/10/99		12/9/99		12/10/99				

OFFICIAL RECORD COPY

PDR ADOCK



UNITED STATES
NUCLEAR REGULATORY COMMISSION

WASHINGTON, D.C. 20555-0001

December 16, 1999

Mr. J. P. O'Hanlon
Senior Vice President - Nuclear
Virginia Electric and Power Company
5000 Dominion Blvd.
Glen Allen, Virginia 23060

SUBJECT: SURRY POWER STATION, UNITS 1 AND 2, AND NORTH ANNA POWER STATION, UNITS 1 AND 2 RE: CLOSEOUT OF GENERIC LETTER 97-06, "DEGRADATION OF STEAM GENERATOR INTERNALS" (TAC NOS. MA0952, MA0953, MA0926 AND MA0927)

Dear Mr. O'Hanlon:

On December 30, 1997, the staff issued Generic Letter (GL) 97-06, "Degradation of Steam Generator Internals." The purpose of GL 97-06 was to obtain information that would enable the staff to verify that the condition of licensees' steam generator internals complies with and conforms to the current licensing bases for their respective facilities.

By letter dated March 30, 1998, you responded to GL-97-06. The staff's review of your response to the GL did not identify any new concerns with the condition of the steam generator internals. The staff did not identify any concerns with the inspection practices employed at your facility to detect degradation of steam generator internals. The staff, therefore, concludes that your response to the GL provides reasonable assurance that the condition of your steam generator internals is in compliance with the current licensing bases for your facilities.

The detailed technical basis that supports the staff's determination for all facilities will be published in a NUREG report. The expected publication date is December 1999. This completes the staff's effort on TAC Nos. MA0952, MA0953, MA0926, and MA0927.

Sincerely,

A handwritten signature in cursive script that reads "Gordon E. Edison".

Gordon E. Edison, Sr. Project Manager, Section 1
Project Directorate II
Division of Licensing Project Management
Office of Nuclear Reactor Regulation

Docket Nos. 50-280, 50-281, 50-338
and 50-339

cc: See next page

Mr. J. P. O'Hanlon
Virginia Electric & Power Company

North Anna Power Station
Units 1 and 2

cc:

Mr. J. Jeffrey Lunsford
County Administrator
Louisa County
P.O. Box 160
Louisa, Virginia 23093

Mr. W. R. Matthews
Site Vice President
North Anna Power Station
P. O. Box 402
Mineral, Virginia 23117

Mr. Donald P. Irwin, Esquire
Hunton and Williams
Riverfront Plaza, East Tower
951 E. Byrd Street
Richmond, Virginia 23219

Mr. E. S. Grecheck
Site Vice President
Surry Power Station
Virginia Electric and Power Company
5570 Hog Island Road
Surry, Virginia 23883

Dr. W. T. Lough
Virginia State Corporation
Commission
Division of Energy Regulation
P. O. Box 1197
Richmond, Virginia 23209

Robert B. Strobe, M.D., M.P.H.
State Health Commissioner
Office of the Commissioner
Virginia Department of Health
P.O. Box 2448
Richmond, Virginia 23218

Old Dominion Electric Cooperative
4201 Dominion Blvd.
Glen Allen, Virginia 23060

Mr. J. H. McCarthy, Manager
Nuclear Licensing & Operations
Support
Virginia Electric and Power Company
Innsbrook Technical Center
5000 Dominion Blvd.
Glen Allen, Virginia 23060

Office of the Attorney General
Commonwealth of Virginia
900 East Main Street
Richmond, Virginia 23219

Senior Resident Inspector
North Anna Power Station
U.S. Nuclear Regulatory Commission
1024 Haley Drive
Mineral, Virginia 23117

Mr. J. P. O'Hanlon
Virginia Electric and Power Company

Surry Power Station

cc:

Mr. Donald P. Irwin, Esq.
Hunton and Williams
Riverfront Plaza, East Tower
951 E. Byrd Street
Richmond, Virginia 23219

Office of the Attorney General
Commonwealth of Virginia
900 East Main Street
Richmond, Virginia 23219

Mr. E. S. Grecheck
Site Vice President
Surry Power Station
Virginia Electric and Power Company
5570 Hog Island Road
Surry, Virginia 23883

Mr. J. H. McCarthy, Manager
Nuclear Licensing & Operations
Support
Innsbrook Technical Center
Virginia Electric and Power Company
5000 Dominion Blvd.
Glen Allen, Virginia 23060

Senior Resident Inspector
Surry Power Station
U. S. Nuclear Regulatory Commission
5850 Hog Island Road
Surry, Virginia 23883

Mr. W. R. Matthews
Site Vice President
North Anna Power Station
Virginia Electric and Power Company
P. O. Box 402
Mineral, Virginia 23117

Chairman
Board of Supervisors of Surry County
Surry County Courthouse
Surry, Virginia 23683

Dr. W. T. Lough
Virginia State Corporation
Commission
Division of Energy Regulation
P. O. Box 1197
Richmond, Virginia 23209

Robert B. Strobe, M.D., M.P.H.
State Health Commissioner
Office of the Commissioner
Virginia Department of Health
P.O. Box 2448
Richmond, Virginia 23218