

WOLF CREEK

NUCLEAR OPERATING CORPORATION

Clay C. Warren
Vice President and Chief Operating Officer

DEC 14 1999

WO 99-0105

U. S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Mail Station P1-137
Washington, D. C. 20555

Subject: Docket No. 50-482: November, 1999, Monthly
Operating Report

Gentlemen:

Attached to this letter is the November, 1999, Monthly Operating Report for Wolf Creek Generating Station. This submittal is being made in accordance with the requirements of Technical Specification 6.9.1.8. This submittal also follows the guidance of Generic Letter 97-02, "Revised Contents of the Monthly Operating Report." If you have questions regarding this report, please contact me at (316) 364-4048, or Mr. Michael J. Angus at (316) 364-4077.

Very truly yours,



Clay C. Warren

CCW/rlr

Attachment

cc: J. N. Donohew (NRC), w/a
W. D. Johnson (NRC), w/a
E. W. Merschoff (NRC), w/a
Senior Resident Inspector (NRC), w/a

OPERATING DATA REPORT
Report Number: 177

DOCKET NO.: 50-482
UNIT NAME: Wolf Creek Generating Station
DATE: December 3, 1999
COMPLETED BY: K. A. Harris
TELEPHONE: 316-364-4038

REPORT MONTH: November, 1999

1.	Design Electrical Rating (MWe - Net):	1170
2.	Maximum Dependable Capacity (MWe - Net):	1170

		This Month	Year to Date	Cumulative
3.	Number of Hours Reactor Critical:	720.0	7,146.1	105,001.2
4.	Number of Hours Generator On-Line:	720.0	7,103.4	103,978.4
5.	Unit Reserve Shutdown Hours:	0.0	0.0	339.8
6.	Net Electrical Energy Generated (MWH)	849,182	8,279,306	116,752,198

UNIT SHUTDOWN AND POWER REDUCTIONS

DOCKET NO.: 50-482
 UNIT NAME: Wolf Creek Generating Station
 DATE: December 3, 1999
 COMPLETED BY: K. A. Harris
 TELEPHONE: 316-364-4038

No	Date	Type	DURATION (Hours)	REASON (1)	METHOD OF SHUTTING	CORRECTIVE ACTIONS/COMMENTS
		F: FORCED S: SCHEDULED			DOWN THE REACTOR (2)	
3	11/30/99	F	12	A	1	Equipment reset, and successfully returned to service.

SUMMARY: The unit operated at or near 100% power, Mode 1, from November 1 until 0459, November 30, 1999, when the unit commenced shutdown as required by Technical Specifications to reset an Over Voltage Protection Card. The unit decreased power to 36%, and commenced power increase at 0933, November 30. The unit attained 100% power at 1758, November 30, and continued through the end of November, 1999.

- 1) REASON: A: EQUIPMENT FAILURE (EXPLAIN) E: OPERATOR TRAINING AND LICENSE EXAMINATION (2) METHOD: 1. MANUAL
 B: MAINTENANCE OR TEST F: ADMINISTRATIVE 2. MANUAL SCRAM
 C: REFUELING G: OPERATIONAL ERROR (EXPLAIN) 3. AUTOMATIC SCRAM
 D: REGULATORY RESTRICTION H: OTHER (EXPLAIN) 4. CONTINUATION
 5. OTHER