

December 8, 1999
NMP2L 1918

United States Nuclear Regulatory Commission
Attn: Document Control Desk
Washington, DC 20555

RE: Nine Mile Point Unit 2
Docket No. 50-410
NPF-69

Subject: Monthly Operating Report for November 1999

Dear Sir:

Submitted herewith is the Operating Data Report, the Unit Shutdowns, and Summary of Operating Experience for November 1999.

Very truly yours,



M. F. Peckham
Plant Manager - Unit 2

/db

Attachments

xc: H.J. Miller, Regional Administrator, Region I
G.K. Hunegs, Senior Resident Inspector
Records Management

JE24

PDR ADDCK 0500 0410

NIAGARA MOHAWK POWER CORPORATION
NINE MILE POINT NUCLEAR STATION UNIT #2
SUMMARY OF OPERATING EXPERIENCE

Nine Mile Point Unit Two operated with a capacity factor (MDC) of 102.20% and an availability factor of 100.00% for the month of **November 1999**.

There were no challenges to the safety relief valves during this period.

OPERATING DATA REPORT

DOCKET NO.: 50-410

DATE: 991202

PREPARED BY: C. Caroccio

TELEPHONE: (315) 349-4615

OPERATING STATUS

Unit Name: **Nine Mile Point Unit #2**
Reporting Period: **NOVEMBER 1999**
1. Design Electrical Rating (Net MWe): **1143.3**
2. Maximum Dependable Capacity (Net MWe): **1123.4**

	<u>This Month</u>	<u>Yr-to-Date</u>	<u>Cumulative</u>
3. Number of Hours Reactor was Critical	720.00	7,192.0	79,008.8
4. Hours Generator On-Line	720.00	7,067.9	76,465.2
5. Reactor Reserve Shutdown Hours	0.00	0.0	0.0
6. Net Electrical Energy Gen. (MWH)	826,678.3	7,943,060.8	78,358,722.2

UNIT SHUTDOWNS

DOCKET NO: 50-410

UNIT NAME: NMP#2

DATE: 991202

PREPARED BY: C. Caroccio

TELEPHONE: (315) 349-4615

APPENDIX B

REPORTING PERIOD - NOVEMBER 1999

No.	Date	Type F: Forced S: Scheduled	Duration (Hours)	Reasons ¹	Method of Shutting Down ²	Cause & Corrective Actions Comments
--NONE--						

¹

Reason:

A-Equipment Failure (Explain)

B-Maintenance or Test

C-Refueling

D-Regulatory Restriction

E-Operator Training & License Exam

F-Administrative

G-Operational Error (Explain)

H-Other (Explain)

²

Method:

1-Manual

2-Manual Trip/Scram

3-Automatic Trip/Scram

4-Continuation

5-Other (Explain)