



**Nebraska Public Power District**  
*Nebraska's Energy Leader*

NLS990120

December 15, 1999

U. S. Nuclear Regulatory Commission  
Attention: Document Control Desk  
Washington, D.C. 20555-0001


Gentlemen:

Subject: Monthly Operating Status Report for November 1999, Docket No. 50-298

Enclosed for your information and use is the Cooper Nuclear Station Monthly Operating Status Report for November 1999. In accordance with the guidance provided by Generic Letter 97-02, this report includes an Operating Data Report and Unit Shutdown Report for the month of November. In accordance with Technical Specification 5.6.4, this report also includes documentation of challenges to the safety/relief valves.

Should you have any comments, or require additional information regarding this report, please contact me.

Sincerely,



John A. McDonald  
Plant Manager

JAM:lb  
Enclosures

cc: NRC Regional Administrator  
NRC Senior Resident Inspector  
ANI Library  
R. W. Beck and Associates  
J. M. Cline  
A. L. Dostal  
J. W. Dutton  
M. G. Farschon  
R. L. Gumm  
INPO Records Center

Cooper Nuclear Station  
P.O. Box 98 / Brownville, NE 68321-0098  
Telephone: (402) 825-3811 / Fax: (402) 825-5211  
<http://www.nppd.com>

*JE24*

*PDR ADOCK 03000298*

U.S. Nuclear Regulatory Commission

December 15, 1999

Page 2

R. P. Kosch

E. A. Lanning

B. Lewis

W. R. Mayben

P. Murphy

E. Pasche

R. D. Stoddard

J. H. Swailes

W. Leech

**APPENDIX A  
OPERATING DATA REPORT**

DOCKET NO. 050-0298  
 UNIT NAME Cooper Nuclear Station  
 DATE 12/15/99  
 COMPLETED BY K. E. Nelson  
 TELEPHONE (402) 825-5066

Reporting Period: November 1999

	This Month	Yr.-to-Date	Cumulative
1. Design Electrical Rating (Net MWe). The nominal net electrical output of the unit specified by the utility and used for the purpose of plant design.	<u>778</u>	<u>N/A</u>	<u>N/A</u>
2. Maximum Dependable Capacity (Net MWe): The gross electrical output as measured at the output terminals of the turbine-generator during the most restrictive seasonal conditions minus the normal station service loads.	<u>764</u>	<u>N/A</u>	<u>N/A</u>
3. Number of Hours the Reactor Was Critical. The total number of hours during the gross hours of the reporting period that the reactor was critical.	<u>720.0</u>	<u>7,851.7</u>	<u>169,538.5</u>
4. Number of Hours the Generator Was On Line. (Also called Service Hours). The total number of hours during the gross hours of the reporting period that the unit operated with the breakers closed to the station bus. The sum of the hours the generator was on line plus the total outage hours should equal the gross hours in the reporting period.	<u>720.0</u>	<u>7,819.5</u>	<u>167,185.6</u>
5. Unit Reserve Shutdown Hours. The total number of hours during the gross hours of the reporting period that the unit was removed from service for economic or similar reasons but was available for operation.	<u>0.0</u>	<u>0.0</u>	<u>0.0</u>
6. Net Electrical Energy (MWH). The gross electrical output of the unit measured at the output terminals of the turbine-generator minus the normal station service loads during the gross hours of the reporting period, expressed in megawatt hours. Negative quantities should not be used.	<u>555,810.0</u>	<u>5,938,892.6</u>	<u>111,829,523.2</u>

**APPENDIX B  
UNIT SHUTDOWNS**

<b>DOCKET NO.</b>	<u>050-0298</u>
<b>UNIT NAME</b>	<u>Cooper Nuclear Station</u>
<b>DATE</b>	<u>12/15/99</u>
<b>COMPLETED BY</b>	<u>K. E. Nelson</u>
<b>TELEPHONE</b>	<u>(402) 825-5066</u>

**REPORT MONTH**                      November 1999

No.	Date	Type	Duration (Hours)	Reason (1)	Method Of Shutting Down Reactor (2)	CAUSE/CORRECTIVE ACTIONS COMMENTS	
		F: FORCED S: SCHEDULED					
None							

**SUMMARY:**    **The plant operated near full power for the month.**

- (1) Reason:
- A - Equipment Failure (Explain)
  - B - Maintenance or Test
  - C - Refueling
  - D - Regulatory Restriction
  - E - Operator Training/License Examination
  - F - Administrative
  - G - Operational Error (Explain)
  - H - Other (Explain)

- (2) Method:
- 1 - Manual
  - 2 - Manual Trip/Scram
  - 3 - Automatic Trip/Scram
  - 4 - Continuation
  - 5 - Other (Explain)

**APPENDIX C**  
**SAFETY/RELIEF VALVE CHALLENGES**  
**NOVEMBER 1999**

There were no challenges to the safety/relief valves during the month of November.

