



**Westinghouse
Electric Company LLC**

**Commercial Nuclear
Fuel Division**

Drawer R
Columbia South Carolina 29250
(803) 647 1000

REF-REO-99-027

November 24, 1999

U. S. Nuclear Regulatory Commission
ATTN: Mr. Bill Gloerson
Sam Nunn Atlanta Federal Center
61 Forsyth Street, SW
Suite 23T85
Atlanta, Georgia 30303-3415

Dear Mr. Gloerson:

RE: NRC License SNM 1107 (70-1151)
Reporting SCDHEC NPDES Permit #SC0001848
Notice of Exceedance Verified 11/22/99 (10-14-99)

Attached with this letter is a copy of our report to South Carolina Department of Health and Environmental Control regarding an exceedance in our NPDES Permit Program. We have initiated a comprehensive review of the event and an action plan to prevent recurrence of the situation.

If you need any additional information, please contact me at (803) 776-2610, Extension 3671.

Sincerely,

WESTINGHOUSE ELECTRIC COMPANY

Roger E. Fischer
Senior Engineer
Environment, Health & Safety

PDZ ADD CK 07001151

IE07



**Westinghouse
Electric Company LLC**

**Commercial Nuclear
Fuel Division**

Drawer R
Columbia South Carolina 29250
(803) 647 1000

REO-REF-99-026

November 22, 1999

South Carolina Department of Health
and Environmental Control
ATTN: Compliance Assurance Division
Bureau of Water
2600 Bull Street
Columbia, South Carolina 29201

Dear Sirs:

RE: NPDES Permit #SC0001848
DMR Results 10/99

The enclosed Discharge Monitoring Report is submitted to fulfill the NPDES summary reporting requirements. This monthly summary covers the monitoring period from October 1, 1999 through October 31, 1999. All results were within NPDES permit limits with the exception of the BOD5 parameter Daily Maximum on 10-14-99 (48.8mg/l) equal to 55.4 # BOD5/day (versus a limit of 50 #/day) and the Monthly Average BOD5 result of 25.4 #/day, versus a limit of 25 #/day). BOD5 results for sampling dates since 10/14/99 have met permit limitations.

Westinghouse regrets the occurrence of this situation and has begun an evaluation of the various inputs to the final discharge stream to determine the source of the BOD5 exceedance. Currently, we have not identified a source of elevated BOD5. We remain committed to full compliance with NPDES Permit requirements.

If you have any questions concerning the enclosed report and exceedance, please contact Mr. Roger E. Fischer, Environment, Health & Safety, at (803) 776-2610, Extension 3671.

Sincerely,

WESTINGHOUSE ELECTRIC COMPANY

Jack B. Allen, Manager
Columbia Plant

Enclosure

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if Different)

NAME WESTINGHOUSE ELEC LLC/COLUMBIA
 ADDRESS P. O. Drawer R
 Columbia, SC 29250

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
 DISCHARGE MONITORING REPORT (DMR)
 (2-18) (17-19)

SC0001848
 PERMIT NUMBER

001 1
 DISCHARGE NUMBER

MAJOR

Form Approved.
 OMB No. 2040-0004
 Approval expires 05-31-98

FACILITY WESTINGHOUSE ELEC LLC/COLUMBIA
 LOCATION 5801 BLUFF RD

MONITORING PERIOD					
YEAR	MO	DAY	YEAR	MO	DAY
99	10	01	99	10	31
(20-21) (22-23) (24-25)			(26-27) (28-29) (30-31)		

79 CM FINAL LIMITS
 DMR VALID: 07/01/1999-06/30/2004
 NOTE: Read instructions before completing this form.

PARAMETER (32-37)	X	(3 Card Only) QUANTITY OR LOADING (46-53) (54-61)			(4 Card Only) QUANTITY OR CONCENTRATION (38-45) (46-53) (54-61)				NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			
00300 LAB ID: 40561 Dissolved Oxygen		*****	*****	*****	8.7	*****	*****	*****	0	01/07	GR
4LOC=1		*****	*****	*****	1.0	*****	*****	*****			
00310 LAB ID: 32010 30D - 5 Day (20 Degrees C)		*****	*****	*****	INST MIN	*****	*****	*****			
4LOC=1		*****	*****	*****	*****	*****	*****	*****	1	06/30	24
00400 LAB ID: 40561 pH		*****	*****	*****	*****	*****	*****	*****			
Standard Units		*****	*****	*****	6.1	*****	8.9	*****	0	01/01	RC
4LOC=P		*****	*****	*****	REPORT MINIMUM	*****	REPORT MAXIMUM	*****		01/01	RC
00530 LAB ID: 32010 Total Suspended Solids (TSS)		*****	*****	*****	*****	*****	*****	*****	0	06/30	24
4LOC=1		*****	*****	*****	*****	*****	*****	*****		01/07	24
00610 LAB ID: 40561 Ammonia-Nitrogen Total as N		*****	*****	*****	*****	*****	*****	*****	0	01/01	24
4LOC=1		*****	*****	*****	*****	*****	*****	*****		01/07	24
00951 LAB ID: 40561 Fluoride, Total		*****	*****	*****	*****	*****	*****	*****	0	01/01	24
4LOC=1		*****	*****	*****	*****	*****	*****	*****		02/30	24
00050 LAB ID: 40561 Flow in Conduit		*****	*****	*****	*****	*****	*****	*****	0	01/01	CN
4LOC=1		*****	*****	*****	*****	*****	*****	*****		01/01	CN

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

4LOC=P - ALLOWABLE PH IS 6.0 - 9.0.

MITTEE NAME/ADDRESS (Include Facility Name/ Location if Different)

ME WESTINGHOUSE ELEC LLC/COLUMBIA
 DRESS P. O. Drawer R
 Columbia, SC 29250

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
 DISCHARGE MONITORING REPORT (DMR)
 (2-18) (17-19)

SC0001848
 PERMIT NUMBER

001 1
 DISCHARGE NUMBER

MAJOR

Form Approved.
 OMB No. 2040-0004
 Approval expires 05-31-98

CILITY WESTINGHOUSE ELEC LLC/COLUMBIA
 CATION 5801 BLUFF RD

MONITORING PERIOD					
YEAR	MO	DAY	YEAR	MO	DAY
99	10	01	99	10	31
(20-21)		(22-23)		(24-25)	
		(26-27)		(28-29)	
				(30-31)	

79 CM FINAL LIMITS
 DMR VALID: 07/01/1999-06/30/2004
 NOTE: Read instructions before completing this form.

PARAMETER (32-37)	X	(3 Card Only) QUANTITY OR LOADING (46-53) (54-61)			(4 Card Only) QUANTITY OR CONCENTRATION (38-45) (46-53) (54-61)				NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			
0060 LAB ID:40561 total Residual chlorine LOC=1	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	0.3		0	01/30	GR
	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	1.0 DAILY MX	MG/L		01/30	GR
2107 LAB ID:40561 length of Longest pH Excursion LOC=P	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	0		0	01/01	RC
	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	60 MAXIMUM	MIN-UT ES		01/01	RC
2108 LAB ID:40561 of Time Exceeding PH Limits LOC=P	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	0		0	01/01	RC
	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	1 MAXIMUM	PER- CENT		01/01	RC
4055 LAB ID:32010 ecal Coliform General LOC=1	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	2.0	2.0	0	03/30	GR
	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	200 30DAVGEO	400 DAILY MX	# PER 100ML	01/30	GR
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER
 Jack B. Allen
 Plant Manager
 TYPED OR PRINTED

I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN; AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. SEE 19 U.S.C. § 1001 AND 33 U.S.C. § 1319. (Penalties under these statutes may include fines up to \$10,000 and or maximum imprisonment of between 6 months and 5 years.)

Jack B. Allen
 SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT

TELEPHONE		DATE		
8037762610	99	10	22	
AREA CODE	NUMBER	YEAR	MO	DAY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)
 1 LOC=P - ALLOWABLE PH IS 6.0 - 9.0.