

December 23, 1999

Mr. W. R. McCollum, Jr.
Vice President, Oconee Site
Duke Energy Corporation
7800 Rochester Highway
Seneca, SC 29672

SUBJECT: OCONEE NUCLEAR STATION, UNITS 1, 2, AND 3 RE: TECHNICAL SPECIFICATION BASES CHANGES

Dear Mr. McCollum:

By letter dated December 16, 1999, you informed the staff of changes to the Oconee Nuclear Station, Units 1, 2, and 3 Technical Specifications (TS) Bases Section B 3.4.14, Reactor Coolant System Pressure Isolation Valve (PIV) Leakage. The purpose of the changes is to clarify that while performing testing in accordance with Surveillance Requirement 3.4.14.1, test activities, including contingencies, may be performed prior to declaring a PIV operable.

The purpose of this letter is to distribute the enclosed revised ITS pages to the appropriate TS manual holders.

Sincerely,

Original signed by:

David E. LaBarge, Senior Project Manager, Section 1
Project Directorate II
Division of Licensing Project Management
Office of Nuclear Reactor Regulation

Docket Nos. 50-269, 50-270, and 50-287

Enclosure: Revised Bases Page

cc w/encl: See next page

Distribution:

File Center
PUBLIC
PDII RF
OGC
ACRS

COgle, RII
GHill (6)

ADDC FILE CENTER 1001

Document Name: G:\PDII-1\OCONEE\BAS CHG16.WPD

To receive a copy of this document, indicate in the box:

"C" = Copy without attachment/enclosure "E" = Copy with attachment/enclosure
"N" = No copy

OFFICE	PM:PDII/S1	LA:PDII/S1	RTSB	SC:PDII/S1
NAME	DLBarge:cn	CHawes ETD	WBeckner MW	REmch JET
DATE	12/21/99	12/21/99	12/22/99	12/22/99

OFFICIAL RECORD COPY

DF01

PDR ADOCK 05000269



UNITED STATES
NUCLEAR REGULATORY COMMISSION

WASHINGTON, D.C. 20555-0001

December 23, 1999

Mr. W. R. McCollum, Jr.
Vice President, Oconee Site
Duke Energy Corporation
7800 Rochester Highway
Seneca, SC 29672

SUBJECT: OCONEE NUCLEAR STATION, UNITS 1, 2, AND 3 RE: TECHNICAL
SPECIFICATION BASES CHANGE

Dear Mr. McCollum:

By letter dated December 16, 1999, you informed the staff of changes to the Oconee Nuclear Station, Units 1, 2, and 3 Technical Specifications (TS) Bases Section B 3.4.14, Reactor Coolant System Pressure Isolation Valve (PIV) Leakage. The purpose of the changes is to clarify that while performing testing in accordance with Surveillance Requirement 3.4.14.1, test activities, including contingencies, may be performed prior to declaring a PIV operable.

The purpose of this letter is to distribute the enclosed revised TS pages to the appropriate TS manual holders.

Sincerely,

A handwritten signature in black ink, appearing to read "De LaBarge".

David E. LaBarge, Senior Project Manager, Section 1
Project Directorate II
Division of Licensing Project Management
Office of Nuclear Reactor Regulation

Docket Nos. 50-269, 50-270, and 50-287

Enclosure: Revised Bases Page

cc w/encl: See next page

Oconee Nuclear Station

cc:

Ms. Lisa F. Vaughn
Legal Department (PBO5E)
Duke Energy Corporation
422 South Church Street
Charlotte, North Carolina 28201-1006

Anne W. Cottingham, Esquire
Winston and Strawn
1400 L Street, NW
Washington, DC 20005

Mr. Rick N. Edwards
Framatome Technologies
Suite 525
1700 Rockville Pike
Rockville, Maryland 20852-1631

Manager, LIS
NUS Corporation
2650 McCormick Drive, 3rd Floor
Clearwater, Florida 34619-1035

Senior Resident Inspector
U. S. Nuclear Regulatory
Commission
7812B Rochester Highway
Seneca, South Carolina 29672

Virgil R. Autry, Director
Division of Radioactive Waste Management
Bureau of Land and Waste Management
Department of Health and Environmental
Control
2600 Bull Street
Columbia, South Carolina 29201-1708

Mr. L. E. Nicholson
Compliance Manager
Duke Energy Corporation
Oconee Nuclear Site
7800 Rochester Highway
Seneca, South Carolina 29672

Ms. Karen E. Long
Assistant Attorney General
North Carolina Department of
Justice
P. O. Box 629
Raleigh, North Carolina 27602

L. A. Keller
Manager - Nuclear Regulatory
Licensing
Duke Energy Corporation
526 South Church Street
Charlotte, North Carolina 28201-1006

Mr. Richard M. Fry, Director
Division of Radiation Protection
North Carolina Department of
Environment, Health, and
Natural Resources
3825 Barrett Drive
Raleigh, North Carolina 27609-7721

Mr. Steven P. Shaver
Senior Sales Engineer
Westinghouse Electric Company
5929 Carnegie Blvd.
Suite 500
Charlotte, North Carolina 28209

BASES

SURVEILLANCE
REQUIREMENTS

SR 3.4.14.1 (continued)

Entry into MODES 3 and 4 is allowed to establish the necessary differential pressures and stable conditions to allow for performance of this Surveillance. The Note that allows this provision is complimentary to the Frequency of prior to entry into MODE 2 whenever the unit has been in MODE 5 for 7 days or more, if leakage testing has not been performed in the previous 9 months. In addition, this Surveillance is not required to be performed on the LPI System when the LPI System is aligned to the RCS in the decay heat removal mode of operation. PIVs contained in the DHR flow path must be leakage rate tested after DHR is secured and stable unit conditions and the necessary differential pressures are established. For the purposes of meeting this SR, test activities including contingencies may be performed prior to declaring a PIV inoperable. A PIV will be considered "in testing" until the test procedure is complete, or the test coordinator determines that further test contingencies would not be expected to produce an acceptable result.

REFERENCES

1. 10 CFR 50.2.
2. 10 CFR 50.55a(c).
3. NRC letter to DPC, "Order for Modification of License Concerning Primary Coolant System Pressure Isolation Valves," dated April 20, 1981.
4. NUREG-75/014, Appendix V, October 1975.
5. NUREG-0677, NRC, May 1980.
6. 10 CFR 50.36.
7. ASME, Boiler and Pressure Vessel Code, Section XI.
8. 10 CFR 50.55a(g).