

Mr. Ted C. Feigenbaum
 Executive Vice President and
 Chief Nuclear Officer
 North Atlantic Energy Service Corporation
 c/o Mr. James M. Peschel
 P.O. Box 300
 Seabrook, NH 03874

December 15, 1999

SUBJECT: SEABROOK STATION, ISSUANCE OF AMENDMENT, RE: RELOCATION OF
 RADIOLOGICAL EFFLUENT TECHNICAL SPECIFICATIONS
 (TAC NO. MA1328)

Dear Mr. Feigenbaum:

The Commission has issued the enclosed Amendment No. 66 to Facility Operating License No. NPF-86 for the Seabrook Station, Unit 1. This amendment consists of changes to the Technical Specifications (TSs) in response to your application dated March 5, 1998.

This amendment revises the TSs by relocating the procedural details of the Radiological Effluent Technical Specifications (RETS) to the Offsite Dose Calculation Manual. The TSs were also revised to relocate procedural details associated with solid radioactive wastes to the Process Control Program. In addition, the Administrative Controls section of the TSs was revised to incorporate programmatic controls for radioactive effluents and environmental monitoring. These changes are consistent with the guidance provided in Generic Letter 89-01, "Implementation of Programmatic Controls for Radiological Effluent Technical Specifications in the Administrative Controls Section of the Technical Specifications and the Relocation of Procedural Details of RETS to the Offsite Dose Calculation Manual or to the Process Control Program."

A copy of our Safety Evaluation is also enclosed. Notice of Issuance will be included in the Commission's biweekly Federal Register notice.

Sincerely,
 ORIGINAL SIGNED BY:
 John T. Harrison, Project Manager, Section 2
 Project Directorate I
 Division of Licensing Project Management
 Office of Nuclear Reactor Regulation

Docket No. 50-443

Enclosures: 1. Amendment No. 66 to NPF-86
 2. Safety Evaluation

cc w/encls: See next page

DISTRIBUTION

File Center	JClifford	OGC	CCarpenter
PUBLIC	JHarrison	ACRS	CAnderson, RI
PDI-2 Rdg	TClark	WBeckner	RScholl (E-mail SE)
EAdensam (EGA1)	GHill (2)	RGallo	

OGC FILE CONTROL UNIT

DFOI

FILENAME: G:\PDI-2\Seabrook\amda1328.wpd *see previous concurrence

OFFICE	PDI-2/PM	PDI-2/LA	IOLB/BC*	RGEB/BC*	OGC*	PDI-2/SC
NAME	JHarrison <i>JH</i>	TClark <i>TC</i>	RGallo	CCarpenter	RBachmann	JClifford
DATE	11/28/99	11/30/99	9/21/99	9/21/99	9/23/99	12/6/99

OFFICIAL RECORD COPY

PDR ADOCL 05000443



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555-0001

December 15, 1999

Mr. Ted C. Feigenbaum
Executive Vice President and
Chief Nuclear Officer
North Atlantic Energy Service Corporation
c/o Mr. James M. Peschel
P.O. Box 300
Seabrook, NH 03874

SUBJECT: SEABROOK STATION, ISSUANCE OF AMENDMENT, RE: RELOCATION OF
RADIOLOGICAL EFFLUENT TECHNICAL SPECIFICATIONS
(TAC NO. MA1328)

Dear Mr. Feigenbaum:

The Commission has issued the enclosed Amendment No. 66 to Facility Operating License No. NPF-86 for the Seabrook Station, Unit 1. This amendment consists of changes to the Technical Specifications (TSs) in response to your application dated March 5, 1998.

This amendment revises the TSs by relocating the procedural details of the Radiological Effluent Technical Specifications (RETS) to the Offsite Dose Calculation Manual. The TSs were also revised to relocate procedural details associated with solid radioactive wastes to the Process Control Program. In addition, the Administrative Controls section of the TSs was revised to incorporate programmatic controls for radioactive effluents and environmental monitoring. These changes are consistent with the guidance provided in Generic Letter 89-01, "Implementation of Programmatic Controls for Radiological Effluent Technical Specifications in the Administrative Controls Section of the Technical Specifications and the Relocation of Procedural Details of RETS to the Offsite Dose Calculation Manual or to the Process Control Program."

A copy of our Safety Evaluation is also enclosed. Notice of Issuance will be included in the Commission's biweekly Federal Register notice.

Sincerely,

A handwritten signature in black ink that reads "John T. Harrison".

John T. Harrison, Project Manager, Section 2
Project Directorate I
Division of Licensing Project Management
Office of Nuclear Reactor Regulation

Docket No. 50-443

Enclosures: 1. Amendment No. 66 to NPF-86
2. Safety Evaluation

cc w/encls: See next page

Seabrook Station, Unit No. 1

cc:

Lillian M. Cuoco, Esq.
Senior Nuclear Counsel
Northeast Utilities Service Company
P.O. Box 270
Hartford, CT 06141-0270

Mr. Peter Brann
Assistant Attorney General
State House, Station #6
Augusta, ME 04333

Resident Inspector
U.S. Nuclear Regulatory Commission
Seabrook Nuclear Power Station
P.O. Box 1149
Seabrook, NH 03874

Town of Exeter
10 Front Street
Exeter, NH 03823

Regional Administrator, Region I
U.S. Nuclear Regulatory Commission
475 Allendale Road
King of Prussia, PA 19406

Office of the Attorney General
One Ashburton Place
20th Floor
Boston, MA 02108

Board of Selectmen
Town of Amesbury
Town Hall
Amesbury, MA 01913

Mr. Dan McElhinney
Federal Emergency Management Agency
Region I
J.W. McCormack P.O. &
Courthouse Building, Room 401
Boston, MA 02109

Mr. Stephen McGrail, Director
ATTN: James Muckerheide
Massachusetts Emergency Management
Agency
400 Worcester Road
P.O. Box 1496
Framingham, MA 01701-0317

Philip T. McLaughlin, Attorney General
Steven M. Houran, Deputy Attorney
General
33 Capitol Street
Concord, NH 03301

Mr. Woodbury Fogg, Director
New Hampshire Office of Emergency
Management
State Office Park South
107 Pleasant Street
Concord, NH 03301

Mr. Roy E. Hickok
Nuclear Training Manager
Seabrook Station
North Atlantic Energy Service Corp.
P.O. Box 300
Seabrook, NH 03874

Mr. James M. Peschel
Manager of Regulatory Compliance
Seabrook Station
North Atlantic Energy Service Corp.
P.O. Box 300
Seabrook, NH 03874

Mr. W. A. DiProfio
Station Director
Seabrook Station
North Atlantic Energy Service Corporation
P.O. Box 300
Seabrook, NH 03874

Mr. Frank W. Getman, Jr.
Great Bay Power Corp.
20 International Drive
Suite 301
Portsmouth, NH 03801-6809

Mr. B. D. Kenyon
President - Nuclear Group
Northeast Utilities Service Group
P.O. Box 128
Waterford, CT 06385

Mr. David E. Carriere
Director, Production Services
Canal Electric Company
2421 Cranberry Highway
Wareham, MA 02571

Mr. Steve Allen
Polestar Applied Technology, Inc.
77 Franklin Street, Suite 507
Boston, MA 02110