

December 21, 1999

Mr. Oliver D. Kingsley, President
Nuclear Generation Group
Commonwealth Edison Company
Executive Towers West III
1400 Opus Place, Suite 500
Downers Grove, IL 60515

SUBJECT: ISSUANCE OF AMENDMENTS (TAC NOS. MA6082 AND MA6083)

Dear Mr. Kingsley:

The U.S. Nuclear Regulatory Commission (Commission) has issued the enclosed Amendment No. 192 to Facility Operating License No. DPR-29 and Amendment No. 188 to Facility Operating License No. DPR-30 for the Quad Cities Nuclear Power Station, Units 1 and 2, respectively. The amendments are in response to your application dated July 16, 1999.

The amendments revise Technical Specification 4.7.D.6 by replacing the leakage limit of 11.5 standard cubic feet per hour (scfh) for each main steam isolation valve (MSIV) with a limit of 46 scfh on the total combined leakage for the MSIVs of all four main steam lines.

A copy of the related Safety Evaluation is also enclosed. The Notice of Issuance will be included in the Commission's biweekly Federal Register notice.

Sincerely,

(original signed by)
Stewart N. Bailey, Project Manager, Section 2
Project Directorate III
Division of Licensing Project Management
Office of Nuclear Reactor Regulation

Docket Nos. 50-254 and 50-265

- Enclosures:
1. Amendment No. 192 to DPR-29
 2. Amendment No. 188 to DPR-30
 3. Safety Evaluation

ENC FILE REENTER 1000

cc w/encls: See next page

DISTRIBUTION:

| | | |
|------------------------|-------------------|-----------------|
| OGC, O15B18 | PUBLIC | PD3 r/f |
| OGC, O15B18 | RScholl (SE only) | GHill (4), T5C3 |
| WBeckner, O13H15 | ACRS, T2E26 | MRing, RIII |

DFOI

*See Previous Concurrence Sheet

DOCUMENT NAME: G:\PDIII-2\quad\MA6082AMD.WPD

To receive a copy of this document, indicate in the box: "C" = Copy without enclosures "E" = Copy with enclosures "N" = No copy

| | | | | | |
|--------|-------------|-----------|------------|-----------|-----------|
| OFFICE | PM:LPD3 | E LA:LPD3 | e SPLB:BC* | OGC* | SC:LPD3 |
| NAME | SBailey SMB | CMOORE | JHANNON | RGBACHMAN | AMENDIOLA |
| DATE | 12/26/99 | 12/13/99 | 11/23/99 | 12/1/99 | 12/21/99 |

OFFICIAL RECORD COPY

PDR APOCK 05000254



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555-0001

December 21, 1999

Mr. Oliver D. Kingsley, President
Nuclear Generation Group
Commonwealth Edison Company
Executive Towers West III
1400 Opus Place, Suite 500
Downers Grove, IL 60515

SUBJECT: ISSUANCE OF AMENDMENTS (TAC NOS. MA6082 AND MA6083)

Dear Mr. Kingsley:

The U.S. Nuclear Regulatory Commission (Commission) has issued the enclosed Amendment No. 192 to Facility Operating License No. DPR-29 and Amendment No. 188 to Facility Operating License No. DPR-30 for the Quad Cities Nuclear Power Station, Units 1 and 2, respectively. The amendments are in response to your application dated July 16, 1999.

The amendments revise Technical Specification 4.7.D.6 by replacing the leakage limit of 11.5 standard cubic feet per hour (scfh) for each main steam isolation valve (MSIV) with a limit of 46 scfh on the total combined leakage for the MSIVs of all four main steam lines.

A copy of the related Safety Evaluation is also enclosed. The Notice of Issuance will be included in the Commission's biweekly Federal Register notice.

Sincerely,

A handwritten signature in black ink, appearing to read "Stewart N. Bailey".

Stewart N. Bailey, Project Manager, Section 2
Project Directorate III
Division of Licensing Project Management
Office of Nuclear Reactor Regulation

Docket Nos. 50-254 and 50-265

Enclosures: 1. Amendment No. 192 to DPR-29
2. Amendment No. 188 to DPR-30
3. Safety Evaluation

cc w/encls: See next page

O. Kingsley
Commonwealth Edison Company

Quad Cities Nuclear Power Station -
Units 1 and 2

cc:

Commonwealth Edison Company
Quad Cities Station Manager
22710 206th Avenue North
Cordova, Illinois 61242-9740

Vice President - Law and
Regulatory Affairs
MidAmerican Energy Company
One River Center Place
106 E. Second Street
P.O. Box 4350
Davenport, Iowa 52808

U.S. Nuclear Regulatory Commission
Quad Cities Resident Inspectors Office
22712 206th Avenue N.
Cordova, Illinois 61242

Mr. David Helwig
Senior Vice President
Commonwealth Edison Company
Executive Towers West III
1400 Opus Place, Suite 900
Downers Grove, Illinois 60515

Chairman
Rock Island County Board
of Supervisors
1504 3rd Avenue
Rock Island County Office Bldg.
Rock Island, Illinois 61201

Mr. Gene H. Stanley
PWR Vice President
Commonwealth Edison Company
Executive Towers West III
1400 Opus Place, Suite 900
Downers Grove, Illinois 60515

Illinois Department of Nuclear Safety
Office of Nuclear Facility Safety
1035 Outer Park Drive
Springfield, Illinois 62704

Mr. Christopher Crane
BWR Vice President
Commonwealth Edison Company
Executive Towers West III
1400 Opus Place, Suite 900
Downers Grove, Illinois 60515

Regional Administrator
U.S. NRC, Region III
801 Warrenville Road
Lisle, Illinois 60532-4351

Commonwealth Edison Company
Site Vice President - Quad Cities
22710 206th Avenue North
Cordova, Illinois 61242-9740

William D. Leach
Manager - Nuclear
MidAmerican Energy Company
907 Walnut Street
P.O. Box 657
Des Moines, Iowa 50303

Commonwealth Edison Company
Reg. Affairs Manager - Quad Cities
22710 206th Avenue N.
Cordova, Illinois 61242-9740

Mr. R. M. Krich
Vice President - Regulatory Services
Commonwealth Edison Company
Executive Towers West III
1400 Opus Place, Suite 500
Downers Grove, Illinois 60515

Ms. Pamela B. Stroebel
Senior Vice President and General Counsel
Commonwealth Edison Company
P.O. Box 767
Chicago, Illinois 60690-0767

Document Control Desk-Licensing
Commonwealth Edison Company
1400 Opus Place, Suite 400
Downers Grove, Illinois 60515